

OSIJEK CEPIN, Croatia

WMO: 142800

Lat: 45.5022N

Lon: 18.5617E

Elev: 89

StdP: 100.26

Time Zone: 1.00 (EUC)

Period: 03-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.0	-7.7	-12.9	1.2	-9.4	-10.1	1.6	-7.0	7.0	5.0	6.1	3.7	1.6	90	0.430

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.3	33.9	22.1	32.4	21.5	30.7	20.9	23.3	31.0	22.5	29.9	21.8	28.7	2.3	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.1	15.9	25.7	20.3	15.1	25.1	19.5	14.4	24.5	69.7	31.3	66.7	30.0	63.9	28.9	25.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max	Min		Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
6.4	5.4	4.6	DB	-15.0	36.2	5.0	2.2	-18.6	37.8	-21.5	39.0	-24.4	40.3	-28.0	41.9	
			WB	-15.1	24.6	5.0	0.7	-18.7	25.1	-21.7	25.5	-24.5	25.9	-28.1	26.4	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	12.3	1.0	2.6	7.3	12.9	17.0	20.9	22.6	22.5	17.5	12.5	7.3	2.2
	DBStd	8.67	4.81	5.08	4.69	3.66	3.68	3.57	3.16	3.11	3.64	4.11	4.11	4.33
	HDD10.0	973	278	208	106	16	2	0	0	0	0	22	101	242
	HDD18.3	2647	537	439	341	167	68	16	4	4	57	183	332	499
	CDD10.0	1798	1	2	23	101	220	327	391	387	226	101	18	2
	CDD18.3	429	0	0	0	3	28	93	137	132	33	3	0	0
	CDH23.3	4585	0	0	1	50	318	962	1497	1389	332	36	0	0
	CDH26.7	1798	0	0	0	7	77	353	657	607	96	2	0	0
Wind	WSAvg	2.1	2.2	2.4	2.6	2.3	2.2	2.0	1.9	1.8	1.8	2.0	2.1	2.1
Precipitation	PrecAvg	698	47	45	46	48	80	86	61	63	64	57	53	46
	PrecMax	961	82	82	91	125	182	222	153	210	177	132	114	112
	PrecMin	392	22	3	2	4	23	28	20	3	7	2	3	2
	PrecStd	156	18	22	26	32	43	48	35	48	44	37	25	32
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.2	17.5	22.2	27.6	31.2	34.0	36.6	36.4	32.3	26.6	20.7	14.9
		MCWB	10.3	11.1	13.4	16.9	19.8	22.7	22.7	22.6	20.5	17.7	14.7	11.4
	2%	DB	11.5	13.8	19.8	24.5	28.7	32.3	33.9	34.0	29.4	23.9	17.7	12.2
		MCWB	8.7	9.5	12.3	15.3	19.2	22.1	22.2	21.8	19.0	16.5	13.3	9.9
	5%	DB	9.0	11.3	17.3	22.4	26.9	30.5	32.4	32.1	27.1	22.0	15.3	9.8
		MCWB	7.3	8.4	11.0	14.1	18.3	21.3	21.8	21.1	18.2	15.6	12.5	8.1
	10%	DB	7.2	9.2	14.9	20.3	24.8	28.7	30.5	30.2	25.0	19.6	13.5	7.9
		MCWB	5.9	7.2	10.0	13.3	17.3	20.4	21.1	20.5	17.4	14.7	11.2	6.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.9	11.7	14.1	17.6	21.3	23.8	24.4	24.1	21.7	18.9	15.5	11.9
		MCDB	13.8	16.2	20.8	26.1	27.9	30.9	31.7	32.0	29.6	24.7	19.1	14.1
	2%	WB	9.0	10.2	12.8	16.0	20.0	22.9	23.5	22.9	20.2	17.4	14.0	10.0
		MCDB	10.8	13.2	18.2	22.4	26.9	30.1	31.4	30.7	26.8	22.4	16.6	11.7
	5%	WB	7.4	8.7	11.7	14.9	18.9	22.1	22.6	22.1	19.2	16.3	12.8	8.3
		MCDB	8.8	10.8	16.4	20.7	25.4	28.8	30.1	29.6	24.9	20.6	15.4	9.7
	10%	WB	6.0	7.4	10.5	14.0	18.0	21.3	21.8	21.3	18.2	15.2	11.3	6.7
		MCDB	7.2	9.1	14.4	19.0	23.6	27.3	28.6	28.1	23.1	18.9	13.3	7.7
Mean Daily Temperature Range	5% DB	MDBR	6.1	7.4	9.8	11.5	11.3	11.4	12.3	12.6	11.1	10.4	7.8	5.7
		MCDBR	9.3	11.6	14.5	15.4	14.7	14.1	15.5	15.8	15.0	13.8	11.3	8.8
		MCWBR	6.8	7.6	7.7	7.0	6.0	5.2	5.1	5.1	5.8	7.1	7.2	6.4
	5% WB	MCDBR	9.0	10.5	13.0	13.5	13.6	13.0	14.1	13.9	12.7	12.6	10.4	8.4
		MCWBR	6.7	7.2	7.3	6.6	5.9	5.3	5.2	5.2	5.5	6.8	6.9	6.4
Clear-Sky Solar Irradiance	taub	0.340	0.366	0.399	0.454	0.440	0.438	0.443	0.446	0.429	0.395	0.361	0.340	
	taud	2.364	2.286	2.230	2.083	2.180	2.226	2.210	2.208	2.222	2.313	2.364	2.369	
	Ebn at Noon	752	799	823	805	831	833	824	805	781	754	717	707	
	Edh at Noon	77	100	121	153	143	137	138	133	121	96	77	70	
All-Sky Solar Radiation	RadAvg	1.21	2.03	3.29	4.62	5.62	6.17	6.22	5.54	3.85	2.63	1.52	0.98	
	RadStd	0.19	0.29	0.41	0.43	0.48	0.50	0.46	0.55	0.43	0.27	0.14	0.14	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (39 neighbors)	+0.65	N/A	N/A	N/A	+0.43	+0.43	-115	-172	+101	+60

Nomenclature: See separate page