

PULA, Croatia

WMO: 143070

Lat: 44.894N

Lon: 13.922E

Elev: 84

StdP: 100.33

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-3.0	-1.5	-13.0	1.2	0.5	-10.6	1.5	1.9	13.3	1.8	11.9	3.1	3.9	60	0.449

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.0	33.0	21.4	31.7	21.2	30.1	20.7	23.5	28.6	22.7	28.2	22.0	27.7	3.5	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
22.1	16.9	25.4	21.1	15.9	25.1	20.1	14.9	24.4	70.5	28.4	67.5	28.3	64.8	27.7	26.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
10.8	9.1	7.7	-6.3	34.7	2.2	1.7	-7.8	35.9	-9.1	36.9	-10.3	37.8	-11.9	39.0		
			-7.7	25.0	2.0	0.9	-9.1	25.6	-10.3	26.1	-11.5	26.7	-12.9	27.3		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	14.2	5.6	6.0	8.9	12.4	16.8	21.1	23.7	23.7	19.1	15.0	10.8	6.8
	DBStd	7.07	2.98	3.08	3.03	2.97	2.67	2.87	2.43	2.71	2.75	2.90	3.43	3.17
	HDD10.0	463	141	115	56	12	0	0	0	0	0	2	32	106
	HDD18.3	1997	396	346	292	178	63	8	1	1	23	108	227	356
	CDD10.0	1996	3	3	22	84	210	334	423	424	273	157	55	8
	CDD18.3	489	0	0	0	1	14	92	166	166	46	4	0	0
	CDH23.3	4632	0	0	0	6	137	861	1700	1640	279	9	0	0
	CDH26.7	1593	0	0	0	0	17	255	642	636	43	1	0	0
Wind	WSAvg	3.1	3.0	3.5	3.6	3.2	2.9	2.9	3.0	3.0	3.2	3.0	3.0	3.1
Precipitation	PrecAvg	906	79	71	70	68	61	60	44	76	93	98	111	84
	PrecMax	1376	187	178	206	151	141	184	121	224	238	424	249	269
	PrecMin	626	0	7	7	16	3	12	0	0	0	0	15	14
	PrecStd	167	49	45	48	34	34	39	33	48	62	87	58	50
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.4	15.8	19.8	24.0	28.6	32.9	34.5	35.1	29.7	24.3	19.8	15.9
		MCWB	12.6	9.9	12.1	15.7	19.4	21.8	22.1	21.3	20.3	17.8	16.6	13.6
	2%	DB	13.2	13.8	17.8	22.0	26.5	31.0	32.9	33.2	28.0	22.7	18.1	14.2
		MCWB	11.3	9.8	11.1	14.1	18.3	21.4	21.6	21.1	19.6	17.7	15.7	12.0
	5%	DB	12.1	12.6	16.0	20.2	24.8	29.6	31.5	31.9	26.5	21.2	17.1	13.1
		MCWB	9.9	9.4	10.9	13.2	17.1	20.5	21.1	21.1	19.1	17.4	15.1	11.0
	10%	DB	10.9	11.7	14.5	18.7	23.1	28.0	30.1	30.1	24.9	20.0	16.1	12.1
		MCWB	8.9	8.9	10.3	12.6	16.4	20.0	20.6	20.9	18.6	17.1	14.2	10.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.5	12.4	13.7	16.3	21.0	24.0	24.5	24.9	23.0	20.5	17.6	14.4
		MCDB	14.3	13.8	16.4	21.6	26.4	29.6	29.5	28.1	25.7	21.8	18.8	15.4
	2%	WB	12.0	11.3	12.8	15.3	19.5	22.6	23.3	23.6	21.8	19.6	16.5	12.9
		MCDB	13.1	12.7	15.2	19.8	24.3	28.3	29.1	28.3	25.0	21.0	17.7	14.0
	5%	WB	10.8	10.5	12.1	14.3	18.3	21.6	22.6	22.8	20.7	18.6	15.6	11.7
		MCDB	11.8	11.8	14.7	18.2	22.8	27.4	28.6	28.4	24.3	20.2	16.8	12.9
	10%	WB	9.6	9.5	11.4	13.5	17.4	20.7	21.8	22.0	19.7	17.6	14.6	10.7
		MCDB	10.4	10.9	13.6	17.1	21.7	26.4	27.9	28.0	23.3	19.3	15.9	11.8
Mean Daily Temperature Range	5% DB	MDBR	7.7	8.6	9.1	9.7	10.0	10.4	11.0	10.7	9.3	8.3	7.3	7.7
		MCDBR	8.7	10.4	11.7	12.3	12.6	12.5	12.8	12.8	11.1	9.6	7.2	8.4
		MCWBR	6.7	7.3	7.4	6.8	6.5	5.8	5.8	5.5	5.5	6.0	5.2	6.5
	5% WB	MCDBR	6.2	7.6	9.1	10.2	10.8	11.5	11.5	11.0	9.5	7.3	5.7	6.5
		MCWBR	5.5	6.2	6.3	6.2	6.3	6.1	6.1	6.0	5.8	5.3	4.7	5.6
Clear-Sky Solar Irradiance	taub	0.342	0.364	0.400	0.437	0.436	0.442	0.434	0.429	0.416	0.400	0.368	0.338	
	taud	2.433	2.364	2.273	2.188	2.250	2.284	2.301	2.327	2.335	2.349	2.378	2.449	
	Ebn at Noon	763	811	826	824	837	832	833	824	801	757	718	728	
	Edh at Noon	74	94	117	138	134	130	126	119	109	94	78	67	
All-Sky Solar Radiation	RadAvg	1.32	2.19	3.53	4.83	6.02	6.84	6.94	5.94	4.21	2.63	1.48	1.16	
	RadStd	0.20	0.36	0.45	0.48	0.54	0.37	0.33	0.47	0.35	0.26	0.16	0.16	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (30 neighbors)	+0.41	N/A	N/A	N/A	N/A	N/A	N/A	-97	+107	+58
		+0.42	N/A	N/A	N/A	N/A	N/A	N/A	-101	+84	+60

Nomenclature: See separate page