

GOSPIC, Croatia

WMO: 143300

Lat: 44.5504N

Lon: 15.3732E

Elev: 1845

StdP: 13.74

Time Zone: 1.00 (EUC)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	7.0	12.8	0.6	6.0	10.9	5.6	7.9	17.8	13.7	42.1	12.0	38.9	1.9	230	0.479

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	25.6	88.9	64.3	86.0	63.9	83.3	62.9	67.1	80.8	65.6	80.3	64.3	79.5	5.3	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
62.6	90.9	71.3	60.7	85.0	70.0	59.1	80.1	69.1	32.6	81.2	31.4	80.6	30.3	79.2	72.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.6	10.6	9.4	-0.8	93.6	8.9	2.2	-7.2	95.2	-12.4	96.5	-17.5	97.7	-24.0	99.4		
(5)			-1.5	69.8	8.8	2.1	-7.8	71.3	-12.9	72.5	-17.8	73.6	-24.2	75.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	49.9	30.7	34.6	40.9	49.2	57.2	64.6	67.1	67.3	57.7	52.2	42.1	34.2		
	DBStd	14.57	9.61	8.03	8.20	6.12	5.66	6.26	5.04	5.12	6.10	6.99	8.88	8.35		
	HDD50	2240	600	430	290	86	9	1	0	0	10	58	264	492		
	HDD65	5807	1064	850	747	475	248	83	38	35	229	396	688	954		
	CDD50	2204	1	0	8	61	232	438	530	538	241	127	26	2		
	CDD65	297	0	0	0	0	6	70	103	108	10	0	0	0		
	CDH74	4358	0	0	0	4	170	1085	1475	1470	148	5	1	0		
	CDH80	1411	0	0	0	0	21	328	494	543	25	0	0	0		
(14) Wind	WSAvg	3.9	3.6	4.1	4.5	4.3	4.0	3.6	3.8	3.5	3.5	3.4	4.0	4.1		
(15) Precipitation	PrecAvg	56.3	4.4	4.1	3.8	4.3	4.2	3.4	2.6	3.0	6.2	6.8	7.7	5.9		
	PrecMax	76.5	10.3	10.7	8.0	7.1	8.3	10.5	10.0	8.4	12.4	20.2	12.3	11.1		
	PrecMin	32.2	0.6	0.6	0.2	0.3	0.9	1.0	0.6	0.5	1.7	0.5	0.7	0.1		
	PrecStd	8.7	2.5	2.7	2.1	1.7	1.9	1.7	1.8	2.1	3.0	3.9	3.0	3.1		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.3	59.1	67.0	73.5	83.0	89.5	92.8	92.8	83.5	73.9	65.6	56.3		
		MCWB	46.3	43.5	48.9	54.2	60.6	66.4	64.7	64.4	63.8	58.4	54.0	49.1		
	2%	DB	52.1	52.9	62.1	69.4	78.2	86.6	88.7	89.4	78.1	70.2	60.9	53.3		
		MCWB	45.9	43.1	47.6	52.6	59.2	65.1	63.7	63.8	61.1	57.1	53.1	47.7		
	5%	DB	48.6	50.1	58.6	66.2	75.0	84.0	85.3	86.0	74.2	67.4	58.2	50.4		
		MCWB	43.5	42.7	46.4	50.9	57.9	63.5	63.3	63.5	59.0	56.3	51.2	45.8		
	10%	DB	45.0	47.5	55.2	62.3	71.6	80.9	82.3	82.6	70.9	64.2	55.1	47.8		
		MCWB	41.4	41.7	45.3	49.3	56.4	62.7	62.8	62.9	57.9	55.1	49.4	44.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.3	47.3	51.7	55.6	62.9	69.2	68.0	69.5	65.5	60.9	56.7	50.5		
		MCDB	53.4	52.9	62.1	69.8	77.0	83.7	82.1	81.3	78.7	68.6	62.3	55.0		
	2%	WB	46.5	45.3	49.1	53.7	61.1	67.0	66.2	67.1	62.8	59.1	53.8	48.5		
		MCDB	51.0	50.5	57.8	66.1	75.5	81.5	81.9	79.3	73.4	67.6	60.1	52.4		
	5%	WB	44.0	43.7	47.7	52.1	59.1	65.3	64.8	65.3	60.8	57.7	51.7	46.4		
		MCDB	47.9	48.9	56.0	62.6	72.0	80.0	80.5	79.6	70.3	65.1	57.0	49.8		
	10%	WB	41.6	42.0	46.3	50.5	57.2	63.8	63.6	63.8	59.2	56.0	50.0	44.2		
		MCDB	45.2	47.1	54.0	59.8	68.2	77.8	78.9	79.1	68.5	63.0	54.7	47.8		
(35) Mean Daily Temperature Range	5% DB	MDBR	14.5	17.3	19.3	20.6	22.7	24.8	25.6	26.1	21.8	19.8	14.3	12.5		
		MCDBR	18.3	22.5	28.7	29.1	30.6	30.7	32.7	33.2	28.8	25.0	18.0	14.8		
		MCWBR	12.3	14.1	16.0	14.3	13.8	12.2	12.1	12.1	13.6	13.4	10.9	10.4		
		MCDBR	13.2	17.3	22.1	24.4	27.2	28.1	28.1	27.5	23.8	20.2	15.3	12.7		
	5% WB	MCWBR	9.5	11.4	13.0	12.5	12.9	11.8	11.3	11.2	12.2	11.5	10.3	9.5		
(40) Clear-Sky Solar Irradiance	taub		0.313	0.336	0.372	0.411	0.404	0.403	0.399	0.398	0.384	0.365	0.338	0.313		
	taud		2.460	2.387	2.310	2.222	2.285	2.325	2.331	2.343	2.363	2.407	2.434	2.470		
	Ebn at Noon		256	268	272	270	275	275	271	265	254	242	242	244		
	Edh at Noon		23	29	36	42	41	40	39	37	34	28	23	21		
(44) All-Sky Solar Radiation	RadAvg		420	655	1053	1440	1793	2062	2121	1839	1272	821	475	373		
	RadStd		53	101	148	167	168	133	121	179	133	78	53	55		

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46) Station Only	DBAvg	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(47) Regional (20 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		+0.76	N/A	N/A	+1.37	+0.65	N/A	-191	+171	+110

Nomenclature: See separate page