

GOSPIC, Croatia

WMO: 143300

Lat: 44.5504N

Lon: 15.3732E

Elev: 562

StdP: 94.75

Time Zone: 1.00 (EUC)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-13.9	-10.7	-17.5	0.9	-11.7	-14.7	1.1	-7.9	6.1	5.6	5.4	3.8	0.8	230	0.479

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.2	31.6	17.9	30.0	17.7	28.5	17.2	19.5	27.1	18.7	26.8	17.9	26.4	2.4	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.0	13.0	21.8	16.0	12.1	21.1	15.1	11.4	20.6	57.9	27.3	55.1	27.0	52.5	26.2	22.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.6	4.7	4.2	-18.2	34.2	5.0	1.2	-21.8	35.1	-24.7	35.8	-27.5	36.5	-31.1	37.4		
(5)			-18.6	21.0	4.9	1.1	-22.1	21.8	-24.9	22.5	-27.7	23.1	-31.2	23.9	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.9	-0.7	1.5	5.0	9.5	14.0	18.1	19.5	19.6	14.3	11.2	5.6	1.2	(6)	(7)
	DBStd	8.09	5.34	4.46	4.56	3.40	3.14	3.48	2.80	2.84	3.39	3.89	4.93	4.64	(7)	(8)
	HDD10.0	1244	333	239	161	48	5	1	0	0	6	32	147	273	(8)	(9)
	HDD18.3	3226	591	472	415	264	138	46	21	19	127	220	382	530	(9)	(10)
	CDD10.0	1224	1	0	4	34	129	243	294	299	134	71	14	1	(10)	(11)
	CDD18.3	165	0	0	0	0	3	39	57	60	6	0	0	0	(11)	(12)
	CDH23.3	2421	0	0	0	2	94	603	819	817	82	3	1	0	(12)	(13)
	CDH26.7	784	0	0	0	0	12	182	274	302	14	0	0	0	(13)	(14)
	WSAvg	1.7	1.6	1.8	2.0	1.9	1.8	1.6	1.7	1.5	1.6	1.5	1.8	1.8	(14)	(15)
	PrecAvg	1431	111	103	97	110	107	87	66	75	157	172	195	150	(15)	(16)
(16) Precipitation	PrecMax	1944	262	273	204	181	211	267	253	214	315	514	312	283	(16)	(17)
	PrecMin	818	16	16	4	7	24	26	16	12	42	12	18	3	(17)	(18)
	PrecStd	220	63	68	54	43	49	44	46	53	76	99	77	79	(18)	(19)
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.0	15.0	19.5	23.0	28.3	31.9	33.8	33.8	28.6	23.3	18.7	13.5	(19)	(20)
		MCWB	8.0	6.4	9.4	12.3	15.9	19.1	18.1	18.0	17.7	14.7	12.2	9.5	(20)	(21)
	2%	DB	11.2	11.6	16.7	20.8	25.7	30.3	31.5	31.9	25.6	21.2	16.1	11.8	(21)	(22)
		MCWB	7.7	6.2	8.7	11.5	15.1	18.4	17.6	17.7	16.2	14.0	11.7	8.7	(22)	(23)
	5%	DB	9.2	10.1	14.8	19.0	23.9	28.9	29.6	30.0	23.4	19.7	14.6	10.2	(23)	(24)
		MCWB	6.4	6.0	8.0	10.5	14.4	17.5	17.4	17.5	15.0	13.5	10.7	7.7	(24)	(25)
	10%	DB	7.2	8.6	12.9	16.8	22.0	27.2	28.0	28.1	21.6	17.9	12.9	8.8	(25)	(26)
		MCWB	5.2	5.4	7.4	9.6	13.5	17.0	17.1	17.2	14.4	12.8	9.7	6.7	(26)	(27)
	0.4%	WB	9.1	8.5	10.9	13.1	17.2	20.7	20.0	20.8	18.6	16.1	13.7	10.3	(27)	(28)
		MCDB	11.9	11.6	16.7	21.0	25.0	28.7	27.8	27.4	26.0	20.3	16.8	12.8	(28)	(29)
(30) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	8.0	7.4	9.5	12.1	16.1	19.4	19.0	19.5	17.1	15.1	12.1	9.2	(29)	(30)
		MCDB	10.6	10.3	14.3	18.9	24.2	27.5	27.7	26.3	23.0	19.8	15.6	11.3	(30)	(31)
	5%	WB	6.6	6.5	8.7	11.2	15.1	18.5	18.2	18.5	16.0	14.3	11.0	8.0	(31)	(32)
		MCDB	8.8	9.4	13.3	17.0	22.2	26.7	27.0	26.4	21.3	18.4	13.9	9.9	(32)	(33)
	10%	WB	5.3	5.6	7.9	10.3	14.0	17.6	17.6	17.7	15.1	13.3	10.0	6.8	(33)	(34)
		MCDB	7.3	8.4	12.2	15.5	20.1	25.5	26.1	26.2	20.3	17.2	12.6	8.8	(34)	(35)
	5% DB	MDBR	8.0	9.6	10.7	11.4	12.6	13.8	14.2	14.5	12.1	11.0	7.9	6.9	(35)	(36)
		MCDBR	10.2	12.5	16.0	16.2	17.0	17.0	18.2	18.4	16.0	13.9	10.0	8.2	(36)	(37)
		MCWBR	6.8	7.8	8.9	7.9	7.7	6.8	6.7	6.7	7.6	7.5	6.1	5.8	(37)	(38)
		MCWBR	7.4	9.6	12.3	13.5	15.1	15.6	15.6	15.3	13.2	11.2	8.5	7.1	(38)	(39)
(40) Clear-Sky Solar Irradiance	taub		0.313	0.336	0.372	0.411	0.404	0.403	0.399	0.398	0.384	0.365	0.338	0.313	(40)	(41)
		taud	2.460	2.387	2.310	2.222	2.285	2.325	2.331	2.343	2.363	2.407	2.434	2.470	(41)	(42)
	Ebn at Noon		807	846	858	851	867	867	866	854	836	801	764	768	(42)	(43)
		Edh at Noon	71	91	113	133	129	125	123	117	106	89	73	65	(43)	(44)
(44) All-Sky Solar Radiation	RadAvg		1.32	2.06	3.32	4.54	5.65	6.50	6.69	5.80	4.01	2.59	1.50	1.18	(44)	(45)
	RadStd		0.17	0.32	0.47	0.53	0.53	0.42	0.38	0.56	0.42	0.25	0.17	0.17	(45)	(46)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (20 neighbors)	+0.42	N/A	N/A	+0.76	+0.36	N/A	N/A	-106	+95	+61

Nomenclature: See separate page