

ZADAR, Croatia

WMO: 144310

Lat: 44.108N

Lon: 15.347E

Elev: 289

StdP: 14.54

Time Zone: 1.00 (EUC)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 25.0	(c) 28.1	(d) 8.2	(e) 8.5	(f) 31.7	(g) 12.2	(h) 10.4	(i) 34.4	(j) 25.6	(k) 43.1	(l) 22.8	(m) 44.6	(n) 5.2	(o) 120	(p) 0.451

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.3	94.9	70.9	91.8	70.0	89.6	69.2	73.9	85.9	72.6	85.2	71.3	84.2	9.1	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
71.3	116.6	76.7	69.5	109.5	75.9	67.8	103.2	74.8	37.6	85.5	36.4	85.1	35.3	84.9	80.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
21.9	18.3	15.6		DB	19.1	98.1	3.5	2.5	16.6	99.9	14.6	101.3	12.6	102.7	10.1	104.6
			WB	16.8	76.6	3.1	1.8	14.6	77.9	12.8	79.0	11.1	80.0	8.8	81.3	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	58.5	42.6	43.8	49.3	55.8	63.4	71.4	75.8	75.7	67.2	59.6	51.8	44.6
	DBStd	12.99	5.99	6.10	5.47	4.95	4.97	5.43	4.39	4.91	5.19	5.34	6.40	5.94
	HDD50	761	239	186	79	11	0	0	0	0	4	56	186	
	HDD65	3401	695	595	487	278	90	10	0	1	37	177	398	633
	CDD50	3862	9	11	56	184	416	642	801	798	516	302	109	18
	CDD65	1030	0	0	0	1	41	202	337	334	104	11	0	0
	CDH74	12006	0	0	0	33	516	2369	4156	3989	887	54	2	0
	CDH80	5103	0	0	0	1	92	924	1969	1916	199	2	0	0
(14) Wind	WSAvg	6.4	6.4	7.2	7.5	6.7	6.0	5.8	6.1	5.8	6.0	5.7	6.8	6.3
(15) Precipitation	PrecAvg	36.5	3.0	2.8	3.1	2.4	2.5	2.2	1.5	2.4	3.7	4.5	4.8	3.8
	PrecMax	56.5	5.5	7.0	7.9	5.0	7.3	5.1	5.7	6.9	9.6	14.8	14.3	9.2
	PrecMin	23.5	0.0	0.4	0.5	0.6	0.2	0.2	0.0	0.0	0.0	0.0	0.4	0.7
	PrecStd	8.0	1.6	1.9	1.9	1.2	1.7	1.1	1.4	1.7	2.6	4.1	2.9	2.5
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	60.4	62.9	70.0	78.5	86.3	94.7	97.1	98.7	88.2	78.7	69.7	61.5
		MCWB	55.0	51.8	54.8	60.8	66.8	71.7	71.3	70.7	69.6	63.8	61.1	56.5
	2%	DB	57.3	59.1	66.2	73.5	82.5	91.4	94.7	95.3	84.6	75.2	66.5	59.0
		MCWB	52.7	50.6	53.4	57.9	65.0	71.0	71.2	70.6	67.3	63.7	60.5	53.9
	5%	DB	55.2	57.0	63.0	70.4	79.3	88.4	91.8	92.8	82.2	73.0	64.5	57.1
		MCWB	51.0	49.9	52.4	56.2	62.9	68.9	69.8	69.8	66.5	63.4	59.2	52.5
	10%	DB	52.8	54.3	60.6	67.8	76.7	85.8	89.5	89.7	79.2	70.0	62.5	55.1
		MCWB	48.5	48.7	51.8	55.2	62.0	67.8	69.0	69.1	65.3	62.1	58.0	51.0
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	56.3	55.7	58.2	62.1	69.7	74.7	76.2	75.8	73.1	69.7	65.0	58.1
		MCDB	58.7	59.1	63.9	72.2	80.1	86.8	88.4	84.9	80.8	72.5	67.8	60.2
	2%	WB	54.2	53.5	56.3	60.2	67.1	72.7	73.9	73.7	70.8	67.5	62.7	55.6
		MCDB	56.5	56.6	61.6	68.9	77.8	85.4	86.5	85.8	78.9	70.7	65.1	57.9
	5%	WB	51.9	51.9	54.9	58.6	65.3	71.1	72.4	72.5	69.2	65.5	60.7	53.9
		MCDB	54.5	54.9	60.2	66.5	75.3	84.3	85.5	85.6	77.7	69.7	63.5	56.2
	10%	WB	49.8	50.2	53.3	57.1	63.6	69.6	70.9	71.1	67.5	63.6	58.5	51.9
		MCDB	51.6	53.2	58.9	64.4	73.2	81.8	84.3	84.7	75.9	68.3	61.6	54.1
(35) Mean Daily Temperature Range	5% DB	MDBR	15.7	17.2	18.5	19.4	20.9	22.1	23.3	23.6	20.5	18.8	16.0	16.1
		MCDBR	16.9	20.1	23.4	25.0	25.4	26.1	27.3	27.3	23.6	20.7	16.4	17.5
		MCWBR	12.4	13.5	13.5	12.0	11.0	9.7	9.3	9.5	10.5	11.8	11.4	13.0
	5% WB	MCDBR	13.9	15.5	18.5	20.0	22.5	24.2	23.7	23.4	20.1	16.5	13.5	13.2
		MCWBR	11.3	11.9	12.2	11.2	11.4	10.3	10.1	10.2	11.1	11.4	10.9	11.4
(40) Clear-Sky Solar Irradiance	taub		0.335	0.359	0.396	0.437	0.431	0.428	0.423	0.423	0.406	0.388	0.361	0.333
	taud		2.444	2.367	2.276	2.178	2.254	2.311	2.316	2.322	2.348	2.379	2.398	2.451
	Ebn at Noon		248	261	265	262	267	268	268	264	259	247	234	236
	Edh at Noon		23	30	37	44	43	40	40	38	34	30	24	22
(44) All-Sky Solar Radiation	RadAvg		450	707	1132	1534	1911	2163	2223	1921	1362	883	510	400
(45)	RadStd		54	97	141	155	154	125	110	153	110	75	48	56

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	-1.67	N/A	N/A	N/A	N/A
Regional (13 neighbors)	+0.70	N/A	N/A	N/A	N/A	N/A	N/A	-166	+149	N/A

Nomenclature: See separate page