

ZADAR, Croatia

WMO: 144310

Lat: **44.108N**Lon: **15.347E**Elev: **88**StdP: **100.27**Time Zone: **1.00 (EUC)**Period: **97-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-3.9	-2.2	-13.2	1.2	-0.1	-11.0	1.5	1.3	11.4	6.2	10.2	7.0	2.3	120	0.451

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.9	34.9	21.6	33.2	21.1	32.0	20.7	23.3	29.9	22.6	29.6	21.8	29.0	4.1	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.8	16.7	24.8	20.8	15.6	24.4	19.9	14.7	23.8	69.6	29.7	66.7	29.5	64.2	29.4	27.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.8	8.2	7.0	DB	-7.1	36.7	1.9	1.4	-8.5	37.7	-9.7	38.5	-10.8	39.3	-12.2	40.3	
(5)			WB	-8.4	24.8	1.7	1.0	-9.7	25.5	-10.7	26.1	-11.6	26.6	-12.9	27.4	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	14.7	5.9	6.5	9.6	13.2	17.5	21.9	24.4	24.3	19.6	15.4	11.0	7.0
	DBStd	7.21	3.33	3.39	3.04	2.75	2.76	3.01	2.44	2.73	2.88	2.97	3.55	3.30
	HDD10.0	423	133	103	44	6	0	0	0	0	0	2	31	103
	HDD18.3	1889	386	331	271	154	50	6	0	1	21	98	221	352
	CDD10.0	2146	5	6	31	102	231	357	445	443	287	168	61	10
	CDD18.3	572	0	0	0	1	23	112	187	186	58	6	0	0
	CDH23.3	6670	0	0	0	18	287	1316	2309	2216	493	30	1	0
	CDH26.7	2835	0	0	0	1	51	513	1094	1064	111	1	0	0
Wind	WSAvg	2.8	2.9	3.2	3.4	3.0	2.7	2.6	2.7	2.6	2.7	2.5	3.0	2.8
Precipitation	PrecAvg	928	76	70	78	60	64	55	38	62	93	114	121	96
	PrecMax	1434	140	178	200	128	186	129	145	176	245	376	364	233
	PrecMin	596	1	9	13	16	6	6	0	0	0	0	11	19
	PrecStd	203	41	47	47	30	44	29	35	42	65	103	73	64
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.8	17.1	21.1	25.8	30.1	34.8	36.2	37.0	31.2	25.9	20.9	16.4
		MCWB	12.8	11.0	12.6	16.0	19.3	22.1	21.8	21.5	20.9	17.7	16.2	13.6
	2%	DB	14.0	15.1	19.0	23.0	28.0	33.0	34.9	35.2	29.2	24.0	19.1	15.0
		MCWB	11.5	10.4	11.9	14.4	18.3	21.6	21.8	21.4	19.6	17.6	15.8	12.2
	5%	DB	12.9	13.9	17.2	21.3	26.3	31.3	33.2	33.8	27.9	22.8	18.1	13.9
		MCWB	10.6	10.0	11.4	13.5	17.2	20.5	21.0	21.0	19.2	17.4	15.1	11.4
	10%	DB	11.5	12.4	15.9	19.9	24.8	29.9	32.0	32.0	26.2	21.1	16.9	12.8
		MCWB	9.1	9.3	11.0	12.9	16.7	19.9	20.5	20.6	18.5	16.7	14.4	10.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.5	13.2	14.6	16.7	20.9	23.7	24.5	24.3	22.8	21.0	18.3	14.5
		MCDB	14.9	15.0	17.7	22.3	26.7	30.4	31.3	29.4	27.1	22.5	19.9	15.6
	2%	WB	12.3	12.0	13.5	15.7	19.5	22.6	23.3	23.2	21.5	19.7	17.1	13.1
		MCDB	13.6	13.6	16.4	20.5	25.4	29.7	30.3	29.9	26.0	21.5	18.4	14.4
	5%	WB	11.1	11.1	12.7	14.8	18.5	21.7	22.4	22.5	20.7	18.6	15.9	12.1
		MCDB	12.5	12.7	15.7	19.2	24.0	29.0	29.7	29.8	25.4	20.9	17.5	13.4
	10%	WB	9.9	10.1	11.8	14.0	17.6	20.9	21.6	21.7	19.7	17.6	14.7	11.0
		MCDB	10.9	11.8	15.0	18.0	22.9	27.7	29.0	29.3	24.4	20.2	16.4	12.3
Mean Daily Temperature Range	5% DB	MDBR	8.7	9.5	10.3	10.8	11.6	12.3	12.9	13.1	11.4	10.5	8.9	9.0
		MCDBR	9.4	11.2	13.0	13.9	14.1	14.5	15.2	15.1	13.1	11.5	9.1	9.7
		MCWBR	6.9	7.5	7.5	6.7	6.1	5.4	5.2	5.3	5.8	6.6	6.3	7.2
	5% WB	MCDBR	7.7	8.6	10.3	11.1	12.5	13.4	13.1	13.0	11.1	9.2	7.5	7.3
		MCWBR	6.3	6.6	6.8	6.2	6.3	5.7	5.6	5.7	6.2	6.3	6.1	6.3
Clear-Sky Solar Irradiance	taub		0.335	0.359	0.396	0.437	0.431	0.428	0.423	0.423	0.406	0.388	0.361	0.333
	taud		2.444	2.367	2.276	2.178	2.254	2.311	2.316	2.322	2.348	2.379	2.398	2.451
	Ebn at Noon		782	823	834	827	843	846	845	831	816	778	738	745
	Edh at Noon		74	94	117	140	134	127	125	120	108	93	77	68
All-Sky Solar Radiation	RadAvg		1.42	2.23	3.57	4.84	6.03	6.82	7.01	6.06	4.29	2.78	1.61	1.26
	RadStd		0.17	0.31	0.44	0.49	0.49	0.39	0.35	0.48	0.35	0.24	0.15	0.18