

SPLIT RESNIK, Croatia

WMO: 144440

Lat: 43.5394N

Lon: 16.3015E

Elev: 79

StdP: 14.65

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 30.3	(c) 33.4	(d) 4.4	(e) 6.9	(f) 36.3	(g) 8.9	(h) 8.7	(i) 37.9	(j) 29.8	(k) 39.9	(l) 25.3	(m) 42.5	(n) 9.4	(o) 330	(p) 0.418

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.2	93.5	70.0	91.4	69.9	89.3	69.3	73.7	86.1	72.5	85.4	71.3	84.5	10.4	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.9	110.2	80.1	68.1	103.7	78.9	66.5	97.8	78.0	37.3	86.1	36.1	85.3	35.0	84.3	80.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 22.3	(b) 18.5	(c) 16.0	(e) 25.8	(f) 98.1	(g) 2.7	(h) 3.1	(i) 23.9	(j) 100.4	(k) 22.3	(l) 102.2	(m) 20.8	(n) 104.0	(o) 18.9	(p) 106.3		
(a) 22.3	(b) 18.5	(c) 16.0	(e) 20.6	(f) 76.8	(g) 2.4	(h) 1.6	(i) 18.8	(j) 78.0	(k) 17.4	(l) 79.0	(m) 16.1	(n) 79.9	(o) 14.3	(p) 81.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	61.4	46.1	47.1	51.7	57.8	65.7	73.5	78.6	78.5	70.1	62.9	55.1	48.5
	DBStd	12.62	5.38	5.67	5.14	5.01	4.83	5.53	4.20	4.60	5.06	4.91	6.24	5.64
	HDD50	418	142	110	42	5	0	0	0	0	13	97	299	93
	HDD65	2694	585	501	413	220	51	5	0	0	13	97	299	510
	CDD50	4578	22	29	94	240	486	706	887	884	603	400	179	48
	CDD65	1379	0	0	0	5	72	261	422	419	166	31	3	0
	CDH74	13368	0	0	0	27	468	2475	4697	4550	1076	72	3	0
	CDH80	5187	0	0	0	1	63	860	2035	1995	231	2	0	0
(14) Wind	WSAvg	6.7	7.0	7.4	7.6	6.8	6.2	6.1	6.7	6.1	6.2	6.0	7.1	7.1
(15) Precipitation	PrecAvg	38.9	3.4	3.0	2.8	3.3	2.6	2.6	1.1	1.7	3.8	4.1	5.8	4.7
	PrecMax	58.3	8.3	7.1	7.9	5.7	5.9	7.6	4.9	6.7	10.0	10.4	10.2	10.7
	PrecMin	27.3	0.4	0.4	0.2	0.7	0.7	0.7	0.1	0.2	0.5	0.4	2.0	0.2
	PrecStd	7.9	2.2	2.0	1.9	1.3	1.3	1.7	1.0	1.6	2.6	2.4	2.4	3.0
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	60.9	63.7	69.2	77.5	84.6	93.5	96.6	98.2	88.2	78.8	71.7	63.0
		MCWB	54.8	52.4	54.0	60.4	65.9	70.6	70.7	70.6	68.5	64.0	61.8	57.6
	2%	DB	59.0	60.5	65.8	73.1	81.7	90.9	93.4	94.7	85.1	75.6	68.3	61.1
		MCWB	53.6	51.3	53.1	57.7	64.9	70.1	70.1	70.0	67.9	63.7	61.1	55.6
	5%	DB	57.1	58.4	62.9	70.1	78.9	87.8	91.4	91.6	82.6	73.7	66.4	59.4
		MCWB	52.0	50.7	52.5	56.5	63.1	69.0	69.8	69.8	66.6	63.3	60.3	54.2
	10%	DB	55.2	56.5	60.9	67.7	76.6	84.9	89.4	89.3	80.3	71.7	64.7	57.5
		MCWB	50.1	49.9	51.7	55.6	62.7	67.6	69.2	69.4	65.9	62.9	58.6	52.2
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	56.9	56.7	58.0	62.5	69.3	74.0	75.5	76.0	72.9	69.1	64.7	59.5
		MCDB	59.8	60.3	64.1	73.0	80.4	86.8	87.6	87.3	81.5	73.7	68.4	62.2
	2%	WB	54.9	54.4	56.1	60.3	66.8	72.3	73.5	73.8	71.2	67.4	63.1	57.4
		MCDB	58.0	58.2	61.6	69.6	77.9	85.3	86.8	85.9	79.8	72.6	67.3	60.4
	5%	WB	53.0	52.7	54.9	58.8	65.1	70.8	72.3	72.4	69.6	65.8	61.3	55.6
		MCDB	56.2	56.6	60.2	66.6	75.8	83.9	86.2	85.6	78.3	71.2	65.7	58.8
	10%	WB	51.2	51.3	53.4	57.3	63.7	69.4	70.9	71.1	68.1	64.4	59.5	53.6
		MCDB	54.3	55.3	59.0	64.7	74.0	82.5	85.2	85.1	77.4	70.0	63.9	56.9
(35) Mean Daily Temperature Range	5% DB	MDBR	13.1	14.2	14.9	15.3	16.4	17.3	18.2	18.5	16.3	15.2	13.3	13.2
		MCDBR	13.8	15.6	17.7	19.4	19.6	20.4	21.0	21.2	18.2	16.9	13.5	13.9
		MCWBR	9.8	10.2	11.1	10.6	9.9	9.6	9.6	9.5	9.2	9.8	9.2	10.0
	5% WB	MCDBR	10.7	11.9	14.5	16.1	17.8	19.0	19.0	19.1	16.3	13.8	10.8	10.5
		MCWBR	9.1	8.9	10.0	9.8	10.2	9.8	10.1	10.2	9.8	9.1	8.5	9.1
(40) Clear-Sky Solar Irradiance	taub		0.337	0.362	0.401	0.446	0.440	0.434	0.429	0.432	0.410	0.392	0.365	0.335
	taud		2.439	2.359	2.262	2.156	2.233	2.298	2.304	2.296	2.341	2.375	2.393	2.449
	Ebn at Noon		249	261	264	260	265	267	267	262	258	247	234	238
	Edh at Noon		24	30	38	46	43	41	40	39	35	30	25	22
(44) All-Sky Solar Radiation	RadAvg		521	768	1195	1582	1980	2218	2297	1997	1447	955	563	454
	RadStd		54	103	144	150	148	126	118	129	80	78	55	67

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		+0.86	N/A	N/A	N/A	+0.88	N/A	N/A	-202	+277
(47) Regional (12 neighbors)		+0.58	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page