

SPLIT RESNIK, Croatia

WMO: 144440

Lat: 43.5394N

Lon: 16.3015E

Elev: 24

StdP: 101.04

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-0.9	0.8	-15.3	1.0	2.4	-12.8	1.2	3.3	13.3	4.4	11.3	5.8	4.2	330	0.418

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.1	34.2	21.1	33.0	21.1	31.9	20.7	23.2	30.1	22.5	29.6	21.8	29.2	4.6	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.0	15.7	26.7	20.1	14.8	26.1	19.2	14.0	25.6	68.8	30.0	66.1	29.6	63.6	29.1	27.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
10.0	8.3	7.2	-3.4	36.7	1.5	1.7	-4.5	38.0	-5.4	39.0	-6.2	40.0	-7.3	41.3		
			-6.3	24.9	1.3	0.9	-7.3	25.6	-8.1	26.1	-8.8	26.6	-9.8	27.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	16.3	7.8	8.4	10.9	14.3	18.7	23.1	25.9	25.8	21.2	17.2	12.9	9.2
	DBStd	7.01	2.99	3.15	2.86	2.79	2.69	3.07	2.33	2.56	2.81	2.73	3.46	3.13
	HDD10.0	232	79	61	23	3	0	0	0	0	0	1	14	52
	HDD18.3	1497	325	278	229	122	28	3	0	0	7	54	166	283
	CDD10.0	2543	12	16	52	133	270	392	493	491	335	222	99	27
	CDD18.3	766	0	0	0	3	40	145	234	233	92	17	2	0
	CDH23.3	7427	0	0	0	15	260	1375	2609	2528	598	40	2	0
	CDH26.7	2882	0	0	0	1	35	478	1131	1108	128	1	0	0
Wind	WSAvg	3.0	3.1	3.3	3.4	3.0	2.8	2.7	3.0	2.7	2.8	2.7	3.2	3.2
Precipitation	PrecAvg	987	86	77	71	83	66	66	29	42	96	105	148	119
	PrecMax	1482	212	180	201	144	149	194	124	171	253	264	259	271
	PrecMin	694	11	9	6	17	19	19	3	5	12	10	52	4
	PrecStd	200	56	50	47	33	32	42	26	40	65	61	60	75
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.1	17.6	20.7	25.3	29.2	34.2	35.9	36.8	31.2	26.0	22.1	17.2
		MCWB	12.7	11.4	12.2	15.8	18.8	21.4	21.5	21.4	20.3	17.8	16.6	14.2
	2%	DB	15.0	15.8	18.8	22.8	27.6	32.7	34.1	34.8	29.5	24.2	20.2	16.2
		MCWB	12.0	10.7	11.7	14.3	18.3	21.2	21.1	21.1	19.9	17.6	16.2	13.1
	5%	DB	14.0	14.7	17.2	21.1	26.1	31.0	33.0	33.1	28.1	23.2	19.1	15.2
		MCWB	11.1	10.4	11.4	13.6	17.3	20.5	21.0	21.0	19.2	17.4	15.7	12.3
	10%	DB	12.9	13.6	16.0	19.9	24.8	29.4	31.9	31.9	26.8	22.1	18.2	14.2
		MCWB	10.1	9.9	10.9	13.1	17.0	19.8	20.7	20.8	18.9	17.2	14.8	11.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.8	13.7	14.5	17.0	20.7	23.4	24.2	24.4	22.7	20.6	18.2	15.3
		MCDB	15.4	15.7	17.8	22.8	26.9	30.4	30.9	30.7	27.5	23.1	20.2	16.8
	2%	WB	12.7	12.4	13.4	15.7	19.3	22.4	23.1	23.2	21.8	19.6	17.3	14.1
		MCDB	14.4	14.6	16.4	20.9	25.5	29.6	30.4	30.0	26.6	22.6	19.6	15.8
	5%	WB	11.7	11.5	12.7	14.9	18.4	21.6	22.4	22.5	20.9	18.8	16.3	13.1
		MCDB	13.5	13.7	15.7	19.2	24.3	28.8	30.1	29.8	25.7	21.8	18.7	14.9
	10%	WB	10.7	10.7	11.9	14.1	17.6	20.8	21.6	21.7	20.0	18.0	15.3	12.0
		MCDB	12.4	13.0	15.0	18.2	23.3	28.1	29.6	29.5	25.2	21.1	17.7	13.8
Mean Daily Temperature Range	5% DB	MDBR	7.3	7.9	8.3	8.5	9.1	9.6	10.1	10.3	9.1	8.5	7.4	7.3
		MCDBR	7.6	8.7	9.8	10.8	10.9	11.4	11.7	11.8	10.1	9.4	7.5	7.7
		MCWBR	5.5	5.7	6.2	5.9	5.5	5.3	5.3	5.3	5.1	5.5	5.1	5.6
	5% WB	MCDBR	5.9	6.6	8.0	9.0	9.9	10.5	10.5	10.6	9.1	7.7	6.0	5.8
		MCWBR	5.1	4.9	5.6	5.4	5.7	5.5	5.6	5.6	5.4	5.1	4.7	5.1
Clear-Sky Solar Irradiance	taub	0.337	0.362	0.401	0.446	0.440	0.434	0.429	0.432	0.410	0.392	0.365	0.335	
	taud	2.439	2.359	2.262	2.156	2.233	2.298	2.304	2.296	2.341	2.375	2.393	2.449	
	Ebn at Noon	785	823	831	820	836	841	841	825	814	778	739	750	
	Edh at Noon	76	96	120	144	137	129	127	124	110	94	79	69	
All-Sky Solar Radiation	RadAvg	1.64	2.42	3.77	4.99	6.24	6.99	7.24	6.29	4.56	3.01	1.77	1.43	
	RadStd	0.17	0.33	0.45	0.47	0.47	0.40	0.37	0.41	0.25	0.24	0.17	0.21	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46)	Station Only		+0.48	N/A	N/A	N/A	+0.49	N/A	N/A	-112	+154
(47)	Regional (12 neighbors)		+0.32	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page