

SPLIT MARJAN, Croatia

WMO: 144450

Lat: 43.508N

Lon: 16.426E

Elev: 420

StdP: 14.47

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 31.4	(c) 34.5	(d) 6.0	(e) 7.6	(f) 34.5	(g) 9.9	(h) 9.3	(i) 37.0	(j) 37.7	(k) 38.5	(l) 33.6	(m) 46.1	(n) 17.4	(o) 60	(p) 0.444

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.8	93.4	71.6	91.3	71.0	89.1	70.2	74.4	87.4	73.0	86.5	71.9	85.5	7.0	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
70.4	113.9	81.3	68.7	107.0	80.4	67.1	101.2	79.8	38.2	87.9	36.9	86.7	35.8	85.4	81.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
32.4	27.8	24.2	27.4	96.9	3.9	2.6	24.5	98.8	22.2	100.3	20.0	101.8	17.2	103.6
			21.9	77.1	3.3	1.7	19.5	78.3	17.6	79.2	15.7	80.2	13.3	81.4
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	62.7	46.7	47.6	52.7	59.5	68.0	76.0	80.7	80.5	71.3	63.8	55.8	49.3
	DBStd	13.30	5.69	6.00	5.68	5.62	5.68	6.15	4.82	5.16	5.51	5.28	6.18	5.91
	HDD50	381	129	101	39	5	0	0	0	0	0	1	22	84
	HDD65	2507	566	486	380	179	34	4	0	0	0	83	277	488
	CDD50	5036	28	36	124	289	558	779	953	944	638	429	197	61
	CDD65	1686	0	0	0	12	126	333	488	480	198	46	3	0
	CDH74	14837	0	0	0	27	567	2908	5275	5023	1004	31	2	0
	CDH80	5518	0	0	0	1	87	991	2196	2050	193	0	0	0
(14) Wind	WSAvg	9.4	10.4	11.2	11.3	9.4	8.3	7.3	7.4	7.0	8.6	9.0	11.4	11.3
(15) Precipitation	PrecAvg	32.8	3.1	2.7	2.9	2.6	2.2	2.0	1.1	1.7	2.7	3.3	4.3	3.8
	PrecMax	47.6	8.2	6.9	7.6	5.0	7.9	6.8	4.3	8.1	7.4	9.4	11.7	9.3
	PrecMin	19.2	0.0	0.2	0.0	0.3	0.1	0.2	0.0	0.0	0.0	0.0	1.3	0.0
	PrecStd	6.2	1.9	1.7	1.9	1.2	1.5	1.3	1.0	1.7	1.9	2.2	2.4	2.5
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	59.3	61.4	67.4	77.9	85.8	93.9	95.8	96.8	87.7	77.1	71.8	62.1
		MCWB	54.1	51.8	54.0	60.6	66.1	72.2	72.6	71.9	69.1	63.0	60.4	57.5
	2%	DB	57.6	58.7	64.4	72.7	82.4	90.9	93.4	93.7	84.5	74.4	67.2	60.1
		MCWB	53.2	51.5	52.6	57.9	65.1	71.2	71.8	71.4	67.7	63.2	60.7	55.8
	5%	DB	55.9	56.8	62.0	70.1	79.7	88.2	91.4	91.3	82.1	72.5	65.5	58.5
		MCWB	51.6	50.4	51.9	56.6	64.0	70.0	71.0	70.8	66.9	62.8	59.4	54.0
	10%	DB	54.3	55.3	60.1	67.7	77.1	85.6	89.3	88.9	79.5	70.8	63.8	56.8
		MCWB	50.0	49.6	51.4	55.6	62.9	68.9	70.2	70.2	66.1	62.5	57.9	51.7
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	55.8	55.5	57.2	62.0	69.4	75.1	76.1	76.3	72.6	67.9	63.8	59.0
		MCDB	58.0	58.8	63.5	73.1	80.9	89.3	89.1	86.3	81.3	71.9	67.5	61.2
	2%	WB	54.2	53.7	55.6	60.1	67.1	73.0	74.4	74.5	70.8	66.4	62.0	56.6
		MCDB	56.8	56.7	60.6	70.0	78.8	86.7	88.0	86.5	79.3	71.2	66.2	59.4
	5%	WB	52.5	52.2	54.4	58.5	65.4	71.6	73.0	72.9	69.4	65.2	60.5	55.1
		MCDB	55.3	55.4	59.4	66.9	76.8	85.2	86.9	86.5	78.3	70.1	64.7	58.1
	10%	WB	50.7	50.9	53.1	57.1	63.9	70.1	71.7	71.8	67.9	63.9	58.8	53.0
		MCDB	53.8	54.3	58.3	64.7	74.9	83.5	86.1	85.5	77.1	69.1	63.1	56.1
(35) Mean Daily Temperature Range	MDBR		7.7	8.8	9.7	10.7	12.1	13.1	13.8	13.2	11.5	9.5	7.7	7.5
	5% DB	MCDBR	7.0	8.6	10.8	12.9	13.9	14.4	15.0	14.2	12.6	10.3	7.1	7.7
		MCWBR	6.7	7.1	8.0	7.7	7.5	7.8	8.2	8.2	8.1	7.7	6.4	7.0
	5% WB	MCDBR	6.4	7.0	9.0	11.4	12.9	13.8	14.1	13.6	11.6	8.7	6.4	6.3
		MCWBR	6.8	6.4	7.1	7.4	7.7	8.2	8.6	8.8	8.6	7.2	6.5	6.7
(40) Clear-Sky Solar Irradiance	taub		0.330	0.354	0.392	0.436	0.430	0.424	0.420	0.423	0.401	0.383	0.357	0.328
	taud		2.454	2.378	2.285	2.182	2.255	2.315	2.320	2.311	2.358	2.395	2.414	2.464
	Ebn at Noon		252	265	267	263	268	270	269	264	261	250	238	241
	Edh at Noon		23	30	37	44	43	40	40	39	34	29	24	22
(44) All-Sky Solar Radiation	RadAvg		528	771	1194	1578	1976	2215	2297	1999	1450	958	567	459
	RadStd		54	105	146	150	149	127	121	129	77	78	58	69

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	+0.70	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (12 neighbors)	+0.58	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page