

SPLIT MARJAN, Croatia

WMO: 144450

Lat: 43.508N

Lon: 16.426E

Elev: 128

StdP: 99.80

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-0.3	1.4	-14.4	1.1	1.4	-12.3	1.3	2.8	16.9	3.6	15.0	7.8	7.8	60	0.444

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.7	34.1	22.0	33.0	21.6	31.7	21.2	23.6	30.8	22.8	30.3	22.1	29.7	3.1	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.4	16.3	27.4	20.4	15.3	26.9	19.5	14.5	26.6	70.9	31.1	67.9	30.4	65.4	29.7	27.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.5	12.4	10.8	-2.6	36.1	2.2	1.4	-4.1	37.1	-5.4	38.0	-6.7	38.8	-8.2	39.8
			-5.6	25.0	1.8	0.9	-6.9	25.7	-8.0	26.2	-9.0	26.8	-10.4	27.4
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	17.1	8.2	8.7	11.5	15.3	20.0	24.4	27.1	26.9	21.8	17.7	13.2	9.6	(6)
(7)		DBStd	7.39	3.16	3.33	3.16	3.12	3.15	3.41	2.68	2.87	3.06	2.93	3.44	3.28	(7)
(8)		HDD10.0	212	72	56	22	3	0	0	0	0	0	1	12	47	(8)
(9)		HDD18.3	1393	314	270	211	99	19	2	0	0	6	46	154	271	(9)
(10)		CDD10.0	2798	16	20	69	161	310	433	529	524	354	238	109	34	(10)
(11)		CDD18.3	937	0	0	0	7	70	185	271	267	110	26	2	0	(11)
(12)		CDH23.3	8243	0	0	0	15	315	1616	2931	2791	558	17	1	0	(12)
(13)		CDH26.7	3066	0	0	0	1	48	551	1220	1139	107	0	0	0	(13)
(14)	Wind	WSAvg	4.2	4.7	5.0	5.1	4.2	3.7	3.2	3.3	3.1	3.8	4.0	5.1	5.0	(14)
(15)	Precipitation	PrecAvg	833	79	69	74	65	55	51	27	43	69	85	110	96	(15)
(16)		PrecMax	1209	208	176	193	127	201	173	110	206	189	240	296	236	(16)
(17)		PrecMin	488	1	4	1	7	2	4	0	0	0	0	33	0	(17)
(18)		PrecStd	158	49	42	47	30	39	33	26	44	47	57	60	63	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.2	16.4	19.6	25.5	29.9	34.4	35.5	36.0	30.9	25.1	22.1	16.7	(19)
(20)			MCWB	12.3	11.0	12.2	15.9	19.0	22.4	22.6	22.2	20.6	17.2	15.8	14.2	(20)
(21)		2%	DB	14.2	14.8	18.0	22.6	28.0	32.7	34.1	34.3	29.2	23.5	19.6	15.6	(21)
(22)			MCWB	11.8	10.8	11.5	14.4	18.4	21.8	22.1	21.9	19.8	17.3	15.9	13.2	(22)
(23)		5%	DB	13.3	13.8	16.7	21.2	26.5	31.2	33.0	32.9	27.8	22.5	18.6	14.7	(23)
(24)			MCWB	10.9	10.2	11.0	13.7	17.8	21.1	21.7	21.5	19.4	17.1	15.2	12.2	(24)
(25)		10%	DB	12.4	12.9	15.6	19.8	25.0	29.8	31.8	31.6	26.4	21.6	17.7	13.8	(25)
(26)			MCWB	10.0	9.8	10.8	13.1	17.2	20.5	21.2	21.2	18.9	16.9	14.4	10.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.2	13.1	14.0	16.7	20.8	23.9	24.5	24.6	22.5	20.0	17.7	15.0	(27)
(28)			MCD B	14.4	14.9	17.5	22.8	27.2	31.8	31.7	30.2	27.4	22.2	19.7	16.2	(28)
(29)		2%	WB	12.4	12.0	13.1	15.6	19.5	22.8	23.6	23.6	21.6	19.1	16.7	13.7	(29)
(30)			MCD B	13.8	13.7	15.9	21.1	26.0	30.4	31.1	30.3	26.3	21.8	19.0	15.2	(30)
(31)		5%	WB	11.4	11.2	12.4	14.7	18.6	22.0	22.8	22.7	20.8	18.4	15.9	12.8	(31)
(32)			MCD B	12.9	13.0	15.2	19.4	24.9	29.5	30.5	30.3	25.7	21.2	18.2	14.5	(32)
(33)		10%	WB	10.4	10.5	11.7	13.9	17.7	21.2	22.1	22.1	20.0	17.7	14.9	11.6	(33)
(34)			MCD B	12.1	12.4	14.6	18.2	23.8	28.6	30.1	29.7	25.1	20.6	17.3	13.4	(34)
(35)	Mean Daily Temperature Range	MDBR	4.3	4.9	5.4	6.0	6.7	7.3	7.7	7.3	6.4	5.3	4.3	4.2	(35)	
(36)		5% DB	MCD BR	3.9	4.8	6.0	7.2	7.7	8.0	8.3	7.9	7.0	5.7	3.9	4.3	(36)
(37)			MCWBR	3.7	3.9	4.4	4.3	4.1	4.3	4.5	4.5	4.5	4.3	3.5	3.9	(37)
(38)		5% WB	MCD BR	3.5	3.9	5.0	6.3	7.2	7.7	7.9	7.6	6.4	4.8	3.6	3.5	(38)
(39)			MCWBR	3.8	3.5	4.0	4.1	4.3	4.5	4.8	4.9	4.8	4.0	3.6	3.7	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.330	0.354	0.392	0.436	0.430	0.424	0.420	0.423	0.401	0.383	0.357	0.328	(40)	
(41)		taud	2.454	2.378	2.285	2.182	2.255	2.315	2.320	2.311	2.358	2.395	2.414	2.464	(41)	
(42)		Ebn at Noon	796	834	841	830	845	850	849	833	824	789	751	761	(42)	
(43)		Edh at Noon	74	94	117	140	134	127	125	122	108	92	77	68	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.67	2.43	3.76	4.97	6.23	6.98	7.24	6.30	4.57	3.02	1.79	1.45	(44)	
(45)		RadStd	0.17	0.33	0.46	0.47	0.47	0.40	0.38	0.41	0.24	0.25	0.18	0.22	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(46)
		+0.39	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (12 neighbors)	+0.32	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page