

BIHAC, Bosnia and Herzegovina

WMO: 145280

Lat: 44.8076N

Lon: 15.8667E

Elev: 814

StdP: 14.27

Time Zone: 1.00 (EUC)

Period: 82-92

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.9	14.7	4.3	7.1	12.3	8.8	8.9	16.6	20.2	47.1	17.3	51.4	2.1	230	0.429

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.5	89.3	68.9	85.6	68.0	82.6	66.6	71.8	84.0	69.9	82.1	68.2	80.0	3.8	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.6	104.7	77.6	65.6	97.4	75.3	64.1	92.4	73.0	36.0	83.8	34.4	82.2	32.9	80.7	76.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.4	11.9	9.0	5.5	94.7	7.1	3.2	0.4	97.1	-3.7	99.0	-7.7	100.8	-12.9	103.1		
(5)			4.9	74.3	7.0	1.9	-0.2	75.7	-4.3	76.8	-8.3	77.9	-13.4	79.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	51.8	33.8	34.8	43.2	51.6	59.6	64.1	69.5	68.5	62.7	53.0	42.4	37.0		
	DBStd	15.03	10.83	10.30	9.01	7.58	6.81	5.70	5.94	5.69	6.13	7.90	9.54	9.93		
	HDD50	2034	512	431	248	70	12	1	0	0	1	63	269	427		
	HDD65	5253	967	846	676	406	188	81	24	32	114	373	678	868		
	CDD50	2682	9	6	37	116	309	423	605	573	382	158	41	23		
	CDD65	428	0	0	0	3	21	54	164	139	45	2	0	0		
	CDH74	4283	0	0	4	19	179	534	1745	1310	454	38	0	0		
	CDH80	1326	0	0	0	1	24	109	642	440	104	6	0	0		
(14) Wind	WSAvg	3.2	3.6	3.3	3.6	4.0	3.3	2.9	2.5	2.5	2.8	3.1	3.4	3.8		
(15) Precipitation	PrecAvg	53.0	3.7	3.5	3.9	4.2	4.6	3.6	3.6	3.3	5.7	5.2	5.7	4.5		
	PrecMax	74.8	8.5	8.2	7.6	8.2	8.8	7.1	8.1	8.5	11.8	10.4	12.4	11.1		
	PrecMin	32.0	0.4	0.4	0.6	0.0	1.4	1.6	0.5	0.7	1.2	1.0	0.0	0.0		
	PrecStd	9.1	2.1	2.0	1.8	2.0	2.0	1.3	2.2	2.4	3.1	2.1	2.5	2.8		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	60.2	61.7	72.8	76.5	82.6	87.9	94.7	92.9	88.1	79.3	67.8	64.8		
		MCWB	48.6	49.3	54.4	57.2	64.8	68.4	70.8	69.6	66.4	59.8	55.1	54.5		
	2%	DB	57.3	57.4	66.4	72.4	78.5	83.6	90.1	88.1	82.7	72.6	64.4	60.5		
		MCWB	48.3	47.1	50.2	55.0	62.4	65.4	69.5	68.1	65.8	60.0	54.0	51.2		
	5%	DB	54.8	54.4	61.8	69.0	75.2	80.5	86.5	84.5	79.3	69.2	61.3	57.4		
		MCWB	46.6	45.9	48.8	53.4	60.7	65.1	68.9	68.1	64.5	58.3	52.4	48.4		
	10%	DB	51.8	50.4	58.0	64.8	72.1	77.2	83.0	81.0	75.5	66.2	58.2	53.9		
		MCWB	44.5	42.3	46.9	51.8	59.5	63.7	67.6	66.3	62.5	57.0	50.7	46.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.1	50.5	54.9	58.5	67.2	71.4	74.6	73.3	70.2	63.5	56.6	55.4		
		MCDB	57.5	59.1	70.1	71.9	78.6	81.4	87.2	85.0	81.4	72.2	64.3	64.0		
	2%	WB	48.7	48.4	51.8	56.1	64.3	68.6	72.3	71.3	67.3	61.1	54.5	51.2		
		MCDB	56.2	55.8	63.6	69.7	75.5	80.1	85.2	83.2	78.9	69.9	63.3	59.0		
	5%	WB	46.9	46.1	49.3	54.2	62.1	66.0	70.3	69.7	65.6	59.4	52.8	48.7		
		MCDB	54.2	53.8	59.9	66.4	72.7	77.3	83.3	81.2	76.5	67.4	61.3	56.4		
	10%	WB	44.6	43.0	47.5	52.5	60.3	64.3	68.5	67.8	64.0	57.7	50.6	46.5		
		MCDB	52.0	50.0	57.1	63.2	70.1	75.7	81.4	78.3	73.2	64.5	57.9	54.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	11.9	13.9	16.2	16.4	17.5	19.2	21.5	21.2	20.9	16.7	11.8	10.5		
		MCDBR	15.4	20.7	25.6	23.5	24.1	25.5	28.1	27.3	27.0	23.4	15.6	13.5		
	5% WB	MCWBR	9.7	12.3	13.1	11.2	11.9	12.2	11.8	11.3	12.3	12.8	9.2	7.7		
		MCWBR	14.6	18.0	22.9	19.6	21.3	21.3	25.1	23.9	24.4	20.2	15.6	12.6		
(40) Clear-Sky Solar Irradiance	taub		0.334	0.364	0.405	0.454	0.442	0.441	0.437	0.437	0.421	0.395	0.360	0.334		
	taud		2.370	2.270	2.192	2.084	2.165	2.217	2.230	2.241	2.253	2.308	2.355	2.384		
	Ebn at Noon		244	256	260	256	264	264	263	259	252	241	230	231		
	Edh at Noon		25	32	40	49	46	44	43	41	37	31	25	22		
(44) All-Sky Solar Radiation	RadAvg		407	633	1016	1383	1722	1980	2028	1772	1220	796	461	354		
	RadStd		54	101	149	171	166	142	126	190	143	86	56	57		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (23 neighbors)	+0.81	N/A	N/A	+1.42	+0.77	N/A	N/A	-200	+176	+110

Nomenclature: See separate page