

BIHAC, Bosnia and Herzegovina

WMO: 145280

Lat: 44.8076N

Lon: 15.8667E

Elev: 248

StdP: 98.38

Time Zone: 1.00 (EUC)

Period: 82-92

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.3	-9.6	-15.4	1.0	-10.9	-12.9	1.3	-8.5	9.0	8.4	7.7	10.8	0.9	230	0.429

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.0	31.8	20.5	29.8	20.0	28.1	19.2	22.1	28.9	21.1	27.9	20.1	26.7	1.7	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.8	15.0	25.3	18.7	13.9	24.1	17.8	13.2	22.8	65.7	28.8	62.0	27.9	58.7	27.1	24.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.9	5.3	4.0	DB	-14.7	34.9	4.0	1.8	-17.5	36.2	-19.9	37.2	-22.1	38.2	-25.0	39.5	(4)
(5)			WB	-15.1	23.5	3.9	1.1	-17.9	24.3	-20.2	24.9	-22.4	25.5	-25.2	26.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	11.0	1.0	1.6	6.2	10.9	15.3	17.8	20.8	20.3	17.1	11.7	5.8	2.8	(6)
(7)		DBStd	8.35	6.01	5.72	5.00	4.21	3.78	3.17	3.30	3.16	3.41	4.39	5.30	5.52	(7)
(8)		HDD10.0	1130	284	239	138	39	7	1	0	0	1	35	149	237	(8)
(9)		HDD18.3	2918	537	470	376	226	104	45	13	18	63	207	377	482	(9)
(10)		CDD10.0	1490	5	3	21	64	172	235	336	318	212	88	23	13	(10)
(11)		CDD18.3	238	0	0	0	2	12	30	91	77	25	1	0	0	(11)
(12)		CDH23.3	2379	0	0	2	11	99	297	969	728	252	21	0	0	(12)
(13)		CDH26.7	737	0	0	0	1	13	61	357	244	58	3	0	0	(13)
(14)	Wind	WSAvg	1.4	1.6	1.5	1.6	1.8	1.5	1.3	1.1	1.1	1.3	1.4	1.5	1.7	(14)
(15)	Precipitation	PrecAvg	1345	95	90	98	107	117	92	91	83	145	132	145	115	(15)
(16)		PrecMax	1899	215	208	193	208	223	180	206	215	299	263	315	283	(16)
(17)		PrecMin	814	9	11	16	0	35	41	12	17	31	26	0	0	(17)
(18)		PrecStd	231	54	50	45	50	50	32	56	60	79	53	64	71	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.6	16.5	22.7	24.7	28.1	31.1	34.8	33.8	31.2	26.3	19.9	18.2	(19)
(20)			MCWB	9.2	9.6	12.5	14.0	18.2	20.2	21.5	20.9	19.1	15.5	12.8	12.5	(20)
(21)		2%	DB	14.1	14.1	19.1	22.4	25.8	28.7	32.3	31.1	28.2	22.5	18.0	15.8	(21)
(22)			MCWB	9.0	8.4	10.1	12.8	16.9	18.5	20.9	20.1	18.8	15.5	12.2	10.7	(22)
(23)		5%	DB	12.7	12.4	16.6	20.5	24.0	27.0	30.3	29.2	26.3	20.6	16.3	14.1	(23)
(24)			MCWB	8.1	7.7	9.3	11.9	16.0	18.4	20.5	20.0	18.1	14.6	11.4	9.1	(24)
(25)		10%	DB	11.0	10.2	14.5	18.2	22.3	25.1	28.3	27.2	24.2	19.0	14.6	12.1	(25)
(26)			MCWB	7.0	5.7	8.3	11.0	15.3	17.6	19.8	19.1	17.0	13.9	10.4	8.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.1	10.3	12.7	14.7	19.5	21.9	23.7	22.9	21.2	17.5	13.7	13.0	(27)
(28)			MCDWB	14.1	15.1	21.2	22.2	25.9	27.4	30.7	29.4	27.4	22.3	18.0	17.8	(28)
(29)		2%	WB	9.3	9.1	11.0	13.4	18.0	20.3	22.4	21.8	19.6	16.2	12.5	10.7	(29)
(30)			MCDWB	13.4	13.2	17.6	21.0	24.2	26.7	29.6	28.4	26.1	21.1	17.4	15.0	(30)
(31)		5%	WB	8.3	7.8	9.6	12.3	16.7	18.9	21.3	21.0	18.7	15.2	11.5	9.3	(31)
(32)			MCDWB	12.3	12.1	15.5	19.1	22.6	25.2	28.5	27.3	24.7	19.7	16.3	13.6	(32)
(33)		10%	WB	7.0	6.1	8.6	11.4	15.7	18.0	20.3	19.9	17.8	14.3	10.3	8.0	(33)
(34)			MCDWB	11.1	10.0	13.9	17.3	21.2	24.3	27.4	25.7	22.9	18.1	14.4	12.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.6	7.7	9.0	9.1	9.7	10.6	12.0	11.8	11.6	9.3	6.6	5.8	(35)
(36)			MCDBR	8.5	11.5	14.2	13.0	13.4	14.2	15.6	15.1	15.0	13.0	8.6	7.5	(36)
(37)			MCWBR	5.4	6.8	7.3	6.2	6.6	6.8	6.5	6.3	6.8	7.1	5.1	4.3	(37)
(38)		5% WB	MCDWR	8.1	10.0	12.7	10.9	11.9	11.8	14.0	13.3	13.5	11.2	8.6	7.0	(38)
(39)			MCWBR	5.5	6.2	6.8	5.7	6.2	6.3	6.6	6.2	6.7	6.5	5.5	4.2	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.334	0.364	0.405	0.454	0.442	0.441	0.437	0.437	0.421	0.395	0.360	0.334	(40)	
(41)		taud	2.370	2.270	2.192	2.084	2.165	2.217	2.230	2.241	2.253	2.308	2.355	2.384	(41)	
(42)		Ebn at Noon	768	806	819	807	831	832	830	815	794	760	726	727	(42)	
(43)		Edh at Noon	78	102	126	153	146	139	136	129	118	98	79	70	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.28	2.00	3.20	4.36	5.43	6.24	6.39	5.59	3.85	2.51	1.45	1.11	(44)	
(45)		RadStd	0.17	0.32	0.47	0.54	0.52	0.45	0.40	0.60	0.45	0.27	0.18	0.18	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (23 neighbors)	+0.45	N/A	N/A	+0.79	+0.43	N/A	N/A	-111	+98	+61

Nomenclature: See separate page