

BJELASNICA, Bosnia and HerzegovinaWMO: **146520**Lat: **43.7037N**Lon: **18.2573E**Elev: **6781**StdP: **11.43**Time Zone: **1.00 (EUC)**Period: **99-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-1.7	2.7	-10.4	4.0	6.8	-4.7	5.5	11.2	84.5	21.0	80.2	13.4	40.9	0	1.115

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.4	67.2	54.9	64.6	54.2	62.2	53.2	58.4	63.5	56.6	61.6	54.9	59.8	13.1	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
56.3	87.2	61.5	54.5	81.5	59.5	52.7	76.4	57.8	28.6	63.7	27.3	61.8	26.0	59.8	65.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 74.8	67.3	59.6	-6.2	70.7	4.9	2.6	-9.7	72.5	-12.6	74.1	-15.3	75.5	-18.9	77.4		
(5)			-6.7	60.6	4.7	2.6	-10.1	62.5	-12.9	64.0	-15.5	65.4	-18.9	67.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	35.6	20.2	20.2	24.6	32.5	40.4	47.7	52.0	52.9	43.9	38.2	30.7	23.2
	DBStd	13.92	8.67	8.61	7.65	6.66	7.53	7.79	6.76	6.66	7.31	8.07	8.58	8.88
	HDD50	5600	923	834	788	526	308	132	57	46	208	369	579	830
	HDD65	10717	1388	1254	1253	976	763	518	403	376	634	829	1028	1295
	CDD50	359	0	0	0	0	10	64	120	136	24	4	1	0
	CDD65	3	0	0	0	0	0	0	1	2	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	24.2	31.8	31.1	30.8	25.0	22.8	18.6	17.2	15.2	19.6	21.1	28.2	30.0
Precipitation	PrecAvg	49.9	3.7	3.9	3.8	4.0	3.8	3.9	3.3	3.0	4.5	5.4	5.7	4.6
	PrecMax	73.2	8.0	8.2	7.4	7.9	7.2	10.2	6.0	7.2	11.3	10.6	11.3	9.8
	PrecMin	35.6	0.7	0.8	0.4	0.9	1.7	0.6	0.6	0.4	1.9	1.2	1.2	0.6
	PrecStd	10.0	2.0	2.1	2.1	1.8	1.6	2.3	1.6	2.2	2.5	2.5	2.4	2.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	39.1	41.0	42.1	52.4	60.6	67.2	69.9	71.0	64.3	56.1	52.5	41.9
		MCWB	32.2	31.0	37.2	43.8	47.2	54.6	55.4	55.7	54.5	45.9	37.8	32.8
	2%	DB	35.7	36.5	38.1	48.0	56.4	63.7	67.1	67.5	59.8	53.2	47.2	39.3
		MCWB	30.3	31.8	33.3	41.2	46.8	53.6	54.8	55.0	51.9	44.7	37.7	31.8
	5%	DB	32.8	32.3	35.6	44.6	53.4	61.2	64.5	64.6	56.4	50.7	43.4	36.8
		MCWB	30.5	30.0	31.9	39.1	45.9	52.7	54.5	54.1	49.9	43.6	36.8	31.4
	10%	DB	30.7	30.5	33.6	41.2	50.6	58.8	61.9	62.2	53.3	47.8	40.7	34.0
		MCWB	29.2	29.2	31.3	36.6	44.4	51.2	53.3	53.1	48.4	42.6	36.6	31.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	34.8	35.5	37.6	45.7	52.4	58.5	60.9	60.8	56.5	48.6	43.5	38.0
		MCDB	37.3	38.5	41.2	50.9	57.4	62.8	66.2	67.1	62.5	53.2	45.6	38.1
	2%	WB	32.5	32.3	35.0	42.1	49.5	56.3	58.6	58.4	53.2	46.9	41.2	34.8
		MCDB	33.6	33.6	36.9	47.2	54.2	61.4	63.3	64.2	57.6	50.4	42.7	36.2
	5%	WB	31.1	30.8	33.1	39.2	47.3	54.0	56.6	56.5	50.9	45.5	39.4	32.9
		MCDB	32.2	31.8	34.4	43.5	51.0	59.6	61.3	61.7	55.1	48.4	42.0	34.3
	10%	WB	29.4	29.1	31.6	37.3	45.4	52.1	54.8	54.7	49.0	44.1	37.5	31.5
		MCDB	30.5	30.2	32.9	40.3	49.2	57.5	59.6	59.6	52.4	46.6	39.5	33.2
Mean Daily Temperature Range	5% DB	MDBR	6.6	6.6	6.1	6.4	7.9	8.4	8.8	8.4	7.2	6.7	6.5	7.0
		MCDBR	7.3	7.7	6.5	9.6	10.5	10.3	10.9	10.5	9.5	7.8	7.4	8.1
		MCWBR	5.8	6.0	5.5	7.1	7.6	8.2	8.0	7.4	7.4	7.0	6.3	5.9
	5% WB	MCDBR	6.0	6.7	6.1	8.8	9.7	10.1	9.8	9.6	9.1	7.1	6.5	6.2
		MCWBR	5.7	6.1	5.7	6.8	7.7	8.6	8.4	7.9	7.6	6.7	6.2	5.9
Clear-Sky Solar Irradiance	taub	0.248	0.267	0.298	0.334	0.333	0.328	0.328	0.329	0.312	0.291	0.267	0.248	
	taud	2.511	2.452	2.434	2.373	2.400	2.435	2.423	2.418	2.469	2.541	2.561	2.532	
	Ebn at Noon	289	299	300	295	297	298	297	293	292	286	279	279	
	Edh at Noon	21	27	31	36	36	36	36	34	30	24	20	19	
All-Sky Solar Radiation	RadAvg	463	687	1058	1352	1676	1930	2001	1800	1263	873	532	399	
	RadStd	64	82	144	177	148	160	151	164	118	96	67	71	