

IEZER, Romania

WMO: 150330

Lat: 47.6025N

Lon: 24.6489E

Elev: 1787

StdP: 81.62

Time Zone: 2.00 (EUE)

Period: 86-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-17.5	-15.5	-29.5	0.3	-7.3	-25.0	0.5	-9.7	17.5	-6.7	13.9	-4.4	2.4	70	0.745

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.0	19.2	14.2	17.9	13.3	16.5	12.5	15.2	18.4	14.2	17.1	13.3	16.2	2.9	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.9	12.3	17.1	12.9	11.5	16.2	11.9	10.8	15.2	49.1	18.6	46.2	17.3	43.2	16.3	19.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
12.3	10.1	8.3	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	2.2	-6.8	-5.1	-3.6	0.9	6.5	9.9	10.5	11.1	6.7	3.0	-1.2	-5.4
	DBStd	7.74	4.80	4.53	4.67	5.16	3.50	3.57	3.49	3.49	4.66	5.11	5.13	4.49
	HDD10.0	3022	521	422	422	274	118	46	38	31	121	218	336	477
	HDD18.3	5874	779	655	680	523	367	253	244	226	351	474	586	736
	CDD10.0	191	0	0	0	1	9	43	52	63	21	3	0	0
	CDD18.3	1	0	0	0	0	0	0	0	1	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	2.8	3.2	3.6	3.1	3.1	2.6	2.3	2.1	2.0	2.6	2.3	3.0	3.5
Precipitation	PrecAvg	1102	55	59	75	85	123	129	137	95	104	100	82	74
	PrecMax	1531	106	127	199	145	219	191	257	152	204	243	175	136
	PrecMin	918	22	24	6	36	56	45	31	34	40	8	1	28
	PrecStd	158	23	25	42	26	41	38	61	34	41	64	44	30
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	4.2	8.1	8.7	13.0	16.5	20.4	20.3	21.7	19.9	14.6	10.6	7.2
		MCWB	-1.5	3.5	4.0	7.0	9.3	14.1	14.7	15.4	14.4	6.4	5.2	2.1
	2%	DB	2.2	3.8	6.0	10.6	14.6	18.5	18.7	18.9	16.8	12.6	8.7	3.5
		MCWB	-0.9	0.2	2.4	5.9	9.5	13.3	14.2	14.0	12.2	5.9	3.6	0.3
	5%	DB	0.9	2.1	4.4	9.2	12.8	17.0	17.3	17.4	14.8	11.1	6.9	1.8
		MCWB	-1.3	-0.8	1.4	5.1	8.8	12.5	13.6	13.3	10.9	5.7	3.4	0.2
	10%	DB	-0.3	0.7	2.9	7.7	11.4	15.2	15.9	15.9	13.0	9.6	5.4	0.3
		MCWB	-2.2	-1.5	0.3	4.3	8.2	11.6	12.9	12.4	9.9	5.2	2.5	-1.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	1.3	3.4	4.8	8.1	11.9	16.3	16.1	16.5	14.8	9.0	7.3	3.2
		MCDB	1.7	6.6	8.0	11.6	14.7	18.9	18.9	20.3	19.4	11.2	9.6	4.5
	2%	WB	0.3	1.1	3.3	6.9	10.5	14.3	15.1	15.0	12.8	8.0	5.4	1.7
		MCDB	1.2	3.2	5.5	10.0	13.1	17.5	17.9	18.5	16.4	10.9	7.1	3.0
	5%	WB	-0.7	0.1	2.1	5.9	9.4	13.1	14.2	14.0	11.5	7.1	4.1	0.6
		MCDB	0.4	1.2	4.0	8.7	12.2	16.6	16.7	17.0	14.4	10.1	6.2	1.9
	10%	WB	-2.0	-0.9	0.8	4.6	8.4	12.0	13.1	13.1	10.4	5.9	2.9	-0.5
		MCDB	-0.5	0.3	2.6	7.7	11.1	14.9	15.6	15.9	13.1	8.8	4.8	0.5
Mean Daily Temperature Range	5% DB	MDBR	5.1	5.2	5.7	5.6	5.8	6.2	5.7	6.0	5.3	5.7	4.9	4.8
		MCDBR	5.9	6.0	6.8	6.2	7.6	8.1	7.5	7.8	7.6	7.4	5.5	5.3
		MCWBR	4.5	4.4	5.0	4.3	5.4	6.0	5.8	5.7	5.2	5.2	3.8	4.1
	5% WB	MCDBR	5.0	5.5	6.3	5.6	7.1	7.0	6.4	7.2	6.8	6.5	5.1	5.2
		MCWBR	4.7	4.4	5.0	4.2	5.2	5.9	5.7	5.7	5.1	5.4	4.1	4.6
Clear-Sky Solar Irradiance	taub	0.243	0.264	0.297	0.338	0.328	0.327	0.342	0.343	0.314	0.290	0.269	0.246	
	taud	2.404	2.368	2.374	2.369	2.435	2.452	2.403	2.400	2.470	2.532	2.534	2.472	
	Ebn at Noon	865	913	928	915	935	935	914	899	899	875	830	822	
	Edh at Noon	65	85	101	112	109	108	112	108	91	73	59	55	
All-Sky Solar Radiation	RadAvg	1.18	2.00	3.08	4.14	5.08	5.39	5.37	4.96	3.54	2.39	1.34	0.91	
	RadStd	0.18	0.24	0.41	0.42	0.52	0.44	0.51	0.46	0.47	0.34	0.19	0.13	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (42 neighbors)	+0.75	N/A	N/A	+1.10	N/A	N/A	-169	-243	+109	+30	

Nomenclature: See separate page