

POIANA STAMPEI, Romania

WMO: 150690

Lat: 47.3247N

Lon: 25.1344E

Elev: 3032

StdP: 13.16

Time Zone: 2.00 (EUE)

Period: 90-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	0.0	4.4	-3.2	5.2	2.4	1.0	6.5	5.6	26.3	22.2	18.9	21.7	2.7	50	0.607

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.4	80.1	63.9	77.1	62.7	74.1	61.7	65.8	75.9	64.4	74.1	63.0	71.9	7.0	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
62.4	94.4	69.9	61.0	89.8	68.4	59.7	85.6	66.7	32.4	76.5	31.2	74.1	30.1	72.3	70.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.8	15.2	13.5	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	42.5	21.9	26.1	32.5	41.6	51.8	58.8	59.9	60.4	51.4	43.0	35.2	26.1		
	DBStd	15.15	8.23	8.14	7.81	7.69	5.62	5.25	4.98	5.50	7.09	6.88	7.02	8.03		
	HDD50	3890	870	670	544	267	45	3	1	2	71	229	446	742		
	HDD65	8257	1335	1090	1009	703	409	192	168	158	408	683	895	1207		
	CDD50	1141	0	0	0	14	101	268	308	323	115	11	1	0		
	CDD65	33	0	0	0	0	0	7	10	15	1	0	0	0		
	CDH74	710	0	0	0	1	9	158	188	314	40	0	0	0		
	CDH80	92	0	0	0	0	0	17	21	50	4	0	0	0		
(14) Wind	WSAvg	4.5	4.5	4.8	5.1	4.6	5.0	4.7	4.7	3.8	4.4	4.2	3.5	4.4		
(15) Precipitation	PrecAvg	30.2	1.2	1.4	1.7	2.3	3.6	4.3	4.4	3.1	2.7	2.2	1.7	1.7		
	PrecMax	45.1	2.5	3.0	4.7	4.7	6.4	7.1	8.4	5.2	6.4	4.6	3.3	3.1		
	PrecMin	20.0	0.2	0.3	0.2	1.0	1.4	2.0	1.9	1.3	0.9	0.2	0.0	0.6		
	PrecStd	5.6	0.6	0.6	0.9	0.8	1.3	1.4	1.8	1.1	1.2	1.3	0.9	0.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	41.3	48.0	62.3	70.3	75.1	82.3	82.6	84.8	78.0	69.0	58.5	46.0		
		MCWB	39.2	43.0	48.0	53.1	58.5	64.5	65.3	64.5	60.6	54.5	50.2	42.8		
	2%	DB	37.6	43.4	54.7	66.5	70.3	78.4	79.0	80.3	73.8	65.1	53.3	41.2		
		MCWB	35.7	39.4	44.6	51.8	57.3	63.1	64.6	63.9	59.7	53.6	47.4	39.5		
	5%	DB	34.9	39.9	48.8	62.2	67.6	74.7	75.3	77.1	69.9	60.9	49.7	37.7		
		MCWB	33.7	37.3	40.9	50.1	56.2	62.1	62.8	63.0	58.4	52.3	45.6	36.6		
	10%	DB	32.8	37.2	43.8	56.4	64.1	70.9	72.0	73.5	64.7	55.5	45.9	35.2		
		MCWB	32.0	35.2	38.6	47.4	54.4	60.2	61.6	62.1	56.3	49.9	43.2	34.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	39.6	44.3	50.1	55.3	60.9	67.5	67.2	67.9	63.0	57.0	50.8	43.0		
		MCDB	41.1	48.1	59.7	66.2	69.4	78.0	78.9	79.7	74.4	64.0	56.4	45.3		
	2%	WB	36.4	40.1	45.2	53.3	59.0	65.1	65.4	65.7	61.0	55.2	48.5	39.7		
		MCDB	37.4	42.3	53.2	64.3	67.2	74.5	75.6	75.8	71.3	63.1	52.9	41.5		
	5%	WB	34.0	38.0	42.3	51.1	57.4	63.1	64.2	64.3	59.2	53.1	46.7	36.7		
		MCDB	34.7	39.9	48.0	61.6	65.7	72.0	72.8	74.8	68.9	60.2	49.8	37.5		
	10%	WB	32.2	35.7	39.3	48.5	55.6	61.5	62.7	62.9	57.5	50.4	43.7	34.6		
		MCDB	33.0	37.1	42.9	56.3	63.0	69.6	70.3	72.4	64.3	55.1	46.1	35.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	13.3	15.3	17.4	19.9	20.2	21.0	20.4	21.7	19.4	19.3	14.5	10.8		
		MCDBR	15.1	18.4	27.9	32.1	26.4	27.2	26.9	28.6	28.8	31.1	22.9	13.1		
		MCWBR	12.2	13.7	16.7	17.5	14.3	13.3	13.6	13.5	14.8	19.7	15.8	10.7		
	5% WB	MCDBR	11.8	16.0	24.7	29.5	24.0	24.7	23.9	25.5	26.2	27.6	20.1	12.9		
		MCWBR	10.4	12.5	15.7	16.6	13.6	13.0	12.7	13.1	14.5	18.4	14.8	10.6		
(40) Clear-Sky Solar Irradiance	taub		0.287	0.317	0.362	0.420	0.399	0.394	0.417	0.423	0.380	0.345	0.317	0.290		
	taud		2.327	2.249	2.208	2.126	2.261	2.307	2.244	2.228	2.314	2.402	2.417	2.380		
	Ebn at Noon		252	266	270	263	274	276	267	260	261	254	239	237		
	Edh at Noon		23	31	38	46	42	40	42	41	34	27	22	20		
(44) All-Sky Solar Radiation	RadAvg		384	647	993	1327	1629	1735	1727	1596	1141	775	437	297		
	RadStd		57	75	128	134	165	144	161	148	146	106	62	41		

Historical Trends

		Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (53 neighbors)		+1.31	N/A	N/A	+1.78	N/A	N/A	-283	-405	+189	+67

Nomenclature: See separate page