

POIANA STAMPEI, Romania

WMO: 150690

Lat: 47.3247N

Lon: 25.1344E

Elev: 924

StdP: 90.70

Time Zone: 2.00 (EUE)

Period: 90-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-17.8	-15.4	-19.6	0.7	-16.5	-17.2	0.9	-14.7	11.8	-5.4	8.4	-5.7	1.2	50	0.607

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.3	26.7	17.7	25.0	17.1	23.4	16.5	18.8	24.4	18.0	23.4	17.2	22.2	3.1	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
16.9	13.5	21.1	16.1	12.8	20.2	15.4	12.2	19.3	57.4	24.7	54.7	23.4	52.2	22.4	21.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.9	6.8	6.0	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	5.8	-5.6	-3.3	0.3	5.3	11.0	14.9	15.5	15.8	10.8	6.1	1.8	-3.3		
	DBStd	8.42	4.57	4.52	4.34	4.27	3.12	2.92	2.77	3.06	3.94	3.82	3.90	4.46		
	HDD10.0	2161	483	372	302	148	25	2	1	1	39	127	248	412		
	HDD18.3	4587	742	606	561	391	227	107	93	88	227	379	497	671		
	CDD10.0	634	0	0	0	8	56	149	171	179	64	6	1	0		
	CDD18.3	18	0	0	0	0	0	4	6	8	1	0	0	0		
	CDH23.3	394	0	0	0	1	5	88	104	174	22	0	0	0		
	CDH26.7	51	0	0	0	0	0	9	12	28	2	0	0	0		
(14) Wind	WSAvg	2.0	2.0	2.2	2.3	2.1	2.3	2.1	2.1	1.7	2.0	1.9	1.5	2.0		
(15) Precipitation	PrecAvg	767	30	35	44	58	92	109	112	79	68	56	43	42		
	PrecMax	1145	63	76	120	119	163	181	213	131	162	116	83	78		
	PrecMin	507	6	8	6	26	36	52	48	34	24	5	0	15		
	PrecStd	142	14	16	24	21	34	36	45	28	31	32	24	19		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.2	8.9	16.8	21.3	23.9	27.9	28.1	29.3	25.5	20.6	14.7	7.8		
		MCWB	4.0	6.1	8.9	11.7	14.7	18.0	18.5	18.1	15.9	12.5	10.1	6.0		
	2%	DB	3.1	6.3	12.6	19.2	21.3	25.8	26.1	26.8	23.2	18.4	11.8	5.1		
		MCWB	2.0	4.1	7.0	11.0	14.1	17.3	18.1	17.7	15.4	12.0	8.5	4.2		
	5%	DB	1.6	4.4	9.3	16.8	19.8	23.7	24.1	25.0	21.1	16.0	9.8	3.2		
		MCWB	1.0	2.9	5.0	10.0	13.5	16.7	17.1	17.2	14.7	11.3	7.6	2.5		
	10%	DB	0.5	2.9	6.5	13.6	17.8	21.6	22.2	23.0	18.2	13.1	7.7	1.8		
		MCWB	0.0	1.8	3.7	8.6	12.5	15.7	16.4	16.7	13.5	9.9	6.2	1.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.2	6.8	10.1	12.9	16.1	19.7	19.6	20.0	17.2	13.9	10.5	6.1		
		MCDB	5.1	9.0	15.4	19.0	20.8	25.5	26.0	26.5	23.6	17.8	13.6	7.4		
	2%	WB	2.5	4.5	7.4	11.8	15.0	18.4	18.6	18.7	16.1	12.9	9.2	4.3		
		MCDB	3.0	5.7	11.8	17.9	19.5	23.6	24.2	24.3	21.8	17.3	11.6	5.3		
	5%	WB	1.1	3.3	5.7	10.6	14.1	17.3	17.9	17.9	15.1	11.7	8.2	2.6		
		MCDB	1.5	4.4	8.9	16.4	18.7	22.2	22.7	23.8	20.5	15.6	9.9	3.1		
	10%	WB	0.1	2.0	4.0	9.2	13.1	16.4	17.1	17.2	14.1	10.2	6.5	1.4		
		MCDB	0.5	2.8	6.1	13.5	17.2	20.9	21.3	22.4	18.0	12.8	7.8	1.7		
(35) Mean Daily Temperature Range	5% DB	MDBR	7.4	8.5	9.7	11.1	11.2	11.7	11.3	12.1	10.8	10.7	8.0	6.0		
		MCDBR	8.4	10.2	15.5	17.9	14.7	15.1	15.0	15.9	16.0	17.3	12.7	7.3		
	5% WB	MCWBR	6.8	7.6	9.3	9.7	7.9	7.4	7.6	7.5	8.2	11.0	8.8	6.0		
		MCWBR	6.5	8.9	13.7	16.4	13.3	13.7	13.3	14.2	14.6	15.4	11.2	7.1		
(40) Clear-Sky Solar Irradiance	taub		0.287	0.317	0.362	0.420	0.399	0.394	0.417	0.423	0.380	0.345	0.317	0.290		
		taud	2.327	2.249	2.208	2.126	2.261	2.307	2.244	2.228	2.314	2.402	2.417	2.380		
	Ebn at Noon		794	837	850	830	865	870	842	820	824	801	753	746		
		Edh at Noon	73	98	120	144	131	126	132	129	108	84	68	62		
(44) All-Sky Solar Radiation	RadAvg		1.21	2.04	3.13	4.18	5.13	5.47	5.44	5.03	3.60	2.44	1.38	0.94		
	RadStd		0.18	0.24	0.41	0.42	0.52	0.46	0.51	0.47	0.46	0.33	0.20	0.13		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (53 neighbors)		+0.73	N/A	N/A	+0.99	N/A	N/A	-157	-225	+105	+37	

Nomenclature: See separate page