

TARGU NEAMT, Romania

WMO: 150730

Lat: 47.2122N

Lon: 26.3792E

Elev: 1274

StdP: 14.03

Time Zone: 2.00 (EUE)

Period: 86-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	7.7	11.2	3.8	7.0	10.6	7.3	8.4	13.7	27.4	29.6	21.2	28.9	3.5	330	0.481

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.2	86.8	67.8	84.0	67.3	81.2	66.2	70.8	81.2	69.3	79.7	67.9	78.0	5.0	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
67.7	106.8	75.3	65.9	100.1	73.7	64.3	94.7	72.3	35.4	80.8	34.2	80.1	33.0	78.4	77.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.8	18.3	15.5	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	49.1	28.0	32.1	39.0	48.4	58.9	66.3	67.8	67.9	59.5	48.8	39.3	32.2	
	DBStd	16.20	9.18	9.48	8.94	8.45	6.37	5.63	5.12	5.60	7.37	7.69	8.52	9.48	
	HDD50	2689	683	501	352	129	11	0	0	0	9	115	333	556	
	HDD65	6181	1148	920	805	498	203	53	30	37	195	504	770	1018	
	CDD50	2363	0	1	12	82	287	489	551	555	293	76	14	3	
	CDD65	379	0	0	0	1	13	92	117	127	29	0	0	0	
	CDH74	3351	0	0	0	17	158	751	926	1172	317	10	0	0	
	CDH80	880	0	0	0	1	25	149	248	375	82	0	0	0	
Wind	WSAvg	5.0	5.1	5.2	5.7	6.3	5.5	4.8	4.2	4.2	4.6	4.3	4.8	4.9	
Precipitation	PrecAvg	24.4	0.7	0.8	1.2	2.1	3.0	4.1	4.1	2.5	2.0	1.9	1.1	1.1	
	PrecMax	36.3	1.7	1.4	2.5	4.5	6.7	8.7	10.6	6.0	5.0	7.3	2.3	2.4	
	PrecMin	15.7	0.1	0.2	0.3	0.3	0.7	1.2	0.9	0.7	0.4	0.2	0.0	0.1	
	PrecStd	5.5	0.4	0.3	0.5	1.1	1.7	2.1	2.4	1.5	1.2	1.4	0.6	0.7	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.3	59.2	68.4	75.9	83.0	86.6	89.7	90.8	86.1	75.0	65.8	59.6	
		MCWB	44.2	48.1	53.9	58.6	63.7	69.7	68.3	69.2	64.2	58.6	54.3	49.7	
	2%	DB	47.6	53.7	62.4	72.4	78.1	83.8	85.8	87.2	81.4	70.4	59.9	53.5	
		MCWB	41.0	45.9	50.0	57.2	62.2	68.5	68.4	67.0	64.8	57.9	51.1	46.0	
	5%	DB	44.0	48.4	56.7	68.2	75.0	81.2	82.3	84.2	77.1	65.5	55.4	49.1	
		MCWB	39.1	42.6	47.3	54.5	61.8	66.6	67.4	66.8	62.1	55.3	50.1	42.9	
	10%	DB	40.5	44.4	51.8	63.1	71.4	78.7	79.0	80.9	72.8	60.8	51.4	44.8	
		MCWB	36.2	39.8	44.6	52.5	59.8	65.7	66.4	66.3	61.4	53.3	47.3	40.1	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	45.3	49.7	54.7	60.4	69.0	74.6	72.2	73.0	69.9	61.0	55.4	50.9
			MCDB	51.8	58.2	65.5	72.9	79.6	83.6	83.7	84.5	78.0	71.1	63.7	58.2
2%		WB	41.9	46.0	51.0	58.1	65.2	70.3	70.1	70.5	66.4	58.9	52.5	46.8	
		MCDB	46.6	53.3	60.9	70.5	74.2	80.6	80.8	81.0	77.6	68.3	58.4	52.6	
5%		WB	39.3	43.2	47.8	55.7	63.0	68.7	68.8	68.9	64.3	56.9	50.4	43.5	
		MCDB	42.9	47.9	54.5	65.8	71.5	78.8	78.9	79.5	74.1	64.1	54.6	49.1	
10%		WB	36.7	40.7	45.4	53.5	61.0	66.8	67.3	67.4	62.2	54.4	47.9	40.6	
		MCDB	39.8	43.9	51.1	62.3	69.2	76.3	76.6	77.7	71.2	60.7	51.4	44.9	
Mean Daily Temperature Range	5% DB	MDBR	11.7	12.9	15.1	17.4	18.3	18.0	18.2	19.6	18.1	16.8	12.9	11.3	
		MCDBR	17.6	19.2	23.7	26.8	23.6	23.0	23.7	25.5	25.5	25.3	20.0	18.0	
		MCWBR	12.4	12.8	13.7	13.8	10.7	9.9	9.9	9.7	10.5	13.7	12.3	11.7	
	5% WB	MCDBR	17.8	18.0	22.5	24.8	20.8	21.6	20.5	22.0	22.9	23.0	18.0	17.6	
		MCWBR	12.2	12.3	13.5	12.9	11.1	10.3	9.6	9.9	10.5	12.9	11.5	11.5	
Clear-Sky Solar Irradiance	taub	0.307	0.336	0.375	0.435	0.410	0.408	0.434	0.441	0.396	0.361	0.332	0.306		
	taud	2.341	2.280	2.246	2.114	2.257	2.295	2.295	2.229	2.203	2.291	2.377	2.402	2.375	
	Ebn at Noon	244	259	266	259	271	272	262	254	256	248	233	230		
	Edh at Noon	23	30	37	46	42	40	43	42	35	28	22	20		
All-Sky Solar Radiation	RadAvg	383	626	1006	1394	1770	1863	1866	1692	1192	768	399	298		
	RadStd	54	85	108	124	149	161	147	130	137	95	38	37		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (46 neighbors)	+1.21	N/A	N/A	+1.44	N/A	N/A	-256	-364	+176	+56

Nomenclature: See separate page