

HUEDIN, Romania

WMO: 150990

Lat: 46.8572N

Lon: 23.0325E

Elev: 1842

StdP: 13.74

Time Zone: 2.00 (EUE)

Period: 86-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	7.4	11.5	2.4	6.6	10.8	6.7	8.3	13.1	21.4	37.9	16.3	36.0	1.0	210	0.484

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	19.0	85.1	67.5	82.0	66.8	79.1	65.7	69.9	80.9	68.4	79.2	67.0	77.2	5.2	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.1	103.1	74.9	64.6	97.8	74.0	63.2	92.9	72.3	35.0	80.7	33.8	79.8	32.6	77.4	75.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.6	13.7	11.4	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	48.4	27.0	33.2	39.4	48.8	58.1	64.3	66.1	66.7	58.4	49.1	37.9	30.5
	DBStd	15.74	7.59	8.13	8.86	8.82	6.31	6.15	5.53	6.02	7.14	7.74	8.85	7.86
	HDD50	2760	712	470	343	124	12	0	0	0	10	112	372	605
	HDD65	6359	1177	889	794	487	225	87	55	52	219	493	812	1069
	CDD50	2171	0	1	14	88	263	430	499	519	262	84	10	1
	CDD65	295	0	0	0	1	12	66	89	106	21	0	0	0
	CDH74	2298	0	0	0	11	92	510	678	854	150	3	0	0
	CDH80	502	0	0	0	0	8	105	146	222	21	0	0	0
(14) Wind	WSAvg	3.7	2.4	3.3	4.2	4.7	4.6	4.4	4.3	3.7	3.8	3.4	2.6	2.9
(15) Precipitation	PrecAvg	28.0	1.4	1.3	1.6	2.1	3.0	4.2	3.8	2.5	2.6	2.0	1.8	1.9
	PrecMax	39.5	2.4	3.1	4.3	3.8	5.8	8.0	7.7	4.6	6.5	4.8	4.2	3.6
	PrecMin	17.8	0.4	0.4	0.4	0.4	1.4	0.7	1.3	0.2	0.4	0.1	0.0	0.4
	PrecStd	5.3	0.6	0.6	0.9	0.8	1.2	1.7	1.7	1.1	1.3	1.2	0.9	1.0
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	49.5	57.4	67.9	75.1	80.2	86.5	87.6	89.0	83.9	73.7	63.8	55.7
		MCWB	43.8	46.5	52.8	57.4	62.2	69.7	68.0	68.4	64.4	57.9	53.6	48.9
	2%	DB	43.9	52.3	61.6	71.3	76.5	83.5	83.9	85.2	78.2	70.4	59.0	50.0
		MCWB	40.1	44.1	49.3	55.8	61.5	68.5	67.8	66.5	62.9	56.5	51.1	44.6
	5%	DB	39.6	48.8	56.4	67.0	73.1	79.8	80.5	81.7	74.8	66.6	54.8	45.4
		MCWB	37.0	42.7	47.3	53.7	60.6	67.0	66.7	66.6	61.6	55.2	49.0	42.1
	10%	DB	36.7	45.5	52.1	62.6	69.9	76.3	77.4	78.4	70.6	61.9	50.7	40.9
		MCWB	34.4	40.9	44.3	51.4	58.4	65.0	65.3	65.8	59.8	52.6	46.6	38.5
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	44.9	47.4	55.0	59.4	64.8	72.6	71.1	71.0	67.0	59.9	53.8	50.1
		MCDB	49.3	55.4	66.0	72.5	75.0	82.5	82.1	83.8	79.5	69.8	61.2	54.1
	2%	WB	41.1	45.2	50.9	57.3	63.3	69.6	69.5	69.4	64.3	57.8	52.0	45.4
		MCDB	44.2	50.6	60.0	69.3	73.6	80.5	79.5	81.3	75.4	68.6	58.7	49.8
	5%	WB	37.4	43.3	47.7	55.0	61.3	67.9	68.0	68.1	62.6	56.0	49.8	42.1
		MCDB	39.9	48.1	55.9	66.1	71.0	78.3	78.0	79.4	72.9	65.4	55.0	45.6
	10%	WB	35.1	41.2	45.1	52.4	59.5	66.0	66.5	66.5	60.9	53.7	47.3	39.0
		MCDB	36.6	45.7	52.0	61.1	68.4	75.4	75.8	77.1	69.7	61.3	51.4	41.0
(35) Mean Daily Temperature Range	5% DB	MDBR	12.7	14.5	16.8	18.1	17.8	17.7	18.2	19.0	17.2	18.5	13.9	11.3
		MCDBR	14.8	18.8	22.9	23.4	21.5	21.9	21.5	22.9	22.9	25.4	18.1	16.2
		MCWBR	11.7	12.0	12.8	11.5	11.0	10.5	9.9	9.8	10.4	13.3	11.6	10.4
		MCDBR	14.7	17.5	22.3	21.6	19.0	20.6	19.4	20.9	19.9	23.3	17.4	15.2
	5% WB	MCWBR	10.6	11.7	13.0	11.2	10.8	10.6	9.8	9.7	9.8	12.7	11.1	10.4
(40) Clear-Sky Solar Irradiance	taub		0.316	0.346	0.391	0.442	0.425	0.421	0.440	0.443	0.404	0.372	0.343	0.316
	taud		2.306	2.244	2.173	2.073	2.184	2.234	2.189	2.174	2.249	2.317	2.342	2.338
	Ebn at Noon		240	256	260	257	267	268	261	254	253	244	228	226
	Edh at Noon		24	32	40	49	45	43	44	43	37	30	24	21
(44) All-Sky Solar Radiation	RadAvg		364	620	995	1391	1687	1855	1818	1675	1181	793	448	281
	RadStd		52	85	146	143	165	144	160	156	137	97	62	39

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (59 neighbors)	+1.26	N/A	N/A	N/A	+1.78	N/A	N/A	-232	-351	+211	+104

Nomenclature: See separate page