

NEGRESTI, Romania

WMO: 151130

Lat: 46.8381N

Lon: 27.4422E

Elev: 431

StdP: 14.47

Time Zone: 2.00 (EUE)

Period: 90-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	4.3	9.7	1.4	6.0	5.6	6.1	7.7	10.8	30.6	19.6	26.3	21.3	2.5	320	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.7	90.5	68.3	87.8	67.9	85.2	67.2	72.7	83.8	71.0	82.2	69.5	80.3	6.9	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.2	108.9	77.4	67.5	102.7	75.1	66.0	97.3	72.9	36.5	83.5	35.1	82.5	33.7	80.4	83.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.6	19.0	16.7	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	50.5	26.0	32.0	39.7	50.2	61.1	68.2	70.6	70.5	62.4	50.4	41.9	31.7		
	DBStd	17.18	8.28	9.32	9.30	7.98	6.22	5.28	5.02	5.71	8.07	7.01	8.21	8.56		
	HDD50	2603	745	504	332	99	6	0	0	0	5	81	263	568		
	HDD65	5890	1210	924	784	445	149	28	12	18	141	454	692	1033		
	CDD50	2778	0	0	13	105	350	546	639	635	376	93	21	0		
	CDD65	590	0	0	0	1	28	124	186	188	62	1	0	0		
	CDH74	6270	0	0	1	36	394	1241	1779	2028	770	20	1	0		
	CDH80	2197	0	0	0	3	86	370	635	848	254	1	0	0		
	WSAvg	6.3	6.6	6.5	7.0	7.9	6.5	6.5	5.7	5.5	5.7	5.8	6.2	6.1		
	PrecAvg	20.7	0.9	0.8	1.1	1.7	2.3	3.2	2.8	1.8	1.9	1.9	1.3	1.1		
(15) Precipitation	PrecMax	30.5	1.9	2.1	2.5	3.7	7.1	6.8	6.9	4.3	6.1	7.8	2.4	3.3		
	PrecMin	14.4	0.2	0.1	0.0	0.2	0.2	0.7	0.3	0.6	0.3	0.3	0.0	0.1		
	PrecStd	4.3	0.6	0.5	0.6	0.8	1.6	1.5	1.7	1.1	1.6	1.5	0.8	0.8		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	46.3	59.3	71.1	78.0	86.9	90.0	93.1	94.5	89.9	77.1	68.2	53.7		
		MCWB	42.4	48.3	56.1	60.6	65.0	71.6	68.2	70.2	67.2	61.8	57.3	48.0		
	2%	DB	42.1	52.3	64.0	74.1	82.1	86.8	89.8	90.9	86.1	71.5	62.1	50.4		
		MCWB	38.9	44.4	52.0	57.9	64.0	70.2	67.5	67.7	65.2	58.5	54.2	46.7		
	5%	DB	39.3	48.3	58.6	69.9	78.5	84.3	86.6	88.2	82.7	67.6	57.1	47.1		
		MCWB	36.4	42.1	48.7	55.5	62.4	68.6	68.0	67.3	63.3	57.2	52.2	44.1		
	10%	DB	36.8	44.4	53.8	66.0	74.9	81.5	83.4	85.1	78.3	63.0	53.1	42.3		
		MCWB	34.7	40.4	45.9	54.3	60.8	67.3	66.8	67.0	62.4	55.0	49.8	39.5		
	0.4%	WB	43.0	49.3	56.7	62.1	68.2	75.6	73.5	74.7	69.1	64.1	58.5	50.8		
		MCDB	45.4	57.1	68.6	76.8	80.6	86.4	85.1	88.1	84.2	72.6	66.7	52.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	39.9	45.2	52.7	59.4	66.3	73.0	71.5	72.0	67.0	60.7	55.3	46.9		
		MCDB	41.9	50.8	62.4	71.6	79.1	83.3	83.1	84.3	80.5	69.1	60.7	49.3		
	5%	WB	37.0	43.1	49.8	57.0	64.0	71.2	70.1	70.4	65.5	58.2	52.8	43.8		
		MCDB	38.8	46.8	57.3	67.8	74.8	81.2	81.1	82.0	77.3	65.3	57.2	47.1		
	10%	WB	34.8	40.5	46.9	54.7	62.2	69.0	68.7	68.8	63.9	55.7	50.2	39.9		
		MCDB	36.4	44.1	53.0	64.1	71.5	78.9	79.1	79.6	75.2	62.1	53.2	42.4		
(35) Mean Daily Temperature Range	5% DB	MDBR	11.9	14.5	17.9	20.6	21.9	21.2	21.7	23.3	22.9	19.1	12.8	10.9		
		MCDBR	14.6	21.0	27.9	29.1	27.7	25.9	27.3	29.5	30.3	28.9	21.9	16.4		
		MCWBR	12.3	13.2	16.2	15.3	11.9	10.8	9.6	9.6	12.1	16.4	12.8	13.3		
		MCDBR	13.2	17.3	26.5	26.5	23.7	23.8	23.1	24.9	27.0	25.9	17.8	16.4		
	5% WB	MCWBR	10.8	11.7	16.3	14.1	11.8	11.6	9.9	10.2	11.5	15.5	11.8	12.9		
(40) Clear-Sky Solar Irradiance	taub		0.326	0.357	0.394	0.453	0.424	0.421	0.447	0.456	0.412	0.378	0.352	0.324		
	taud		2.266	2.225	2.194	2.062	2.222	2.266	2.201	2.167	2.248	2.321	2.332	2.308		
	Ebn at Noon		235	251	259	254	267	268	259	251	251	242	224	221		
	Edh at Noon		25	33	39	49	43	42	44	44	37	30	24	22		
(44) All-Sky Solar Radiation	RadAvg		395	638	1016	1394	1784	1872	1888	1712	1212	777	409	312		
	RadStd		53	83	103	125	152	166	152	129	130	93	37	35		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (42 neighbors)	+1.15	N/A	N/A	+1.30	N/A	N/A	-241	-346	+176	+67	

Nomenclature: See separate page