

JOSENI, Romania

WMO: 151270

Lat: 46.7058N

Lon: 25.5125E

Elev: 751

StdP: 92.62

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-20.3	-17.6	-21.5	0.6	-19.8	-19.0	0.8	-17.0	10.1	-6.3	9.4	-4.7	0.3	110	0.561

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.0	28.5	18.7	26.8	18.0	25.2	17.4	20.0	26.0	19.1	24.8	18.3	23.8	3.0	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.2	14.3	22.2	17.1	13.4	21.4	16.3	12.7	20.7	60.9	26.3	57.7	24.8	55.0	24.0	23.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 7.9	(b) 6.8	(c) 5.9	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		
(a) 7.9	(b) 6.8	(c) 5.9	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	6.7	-6.1	-3.4	1.8	6.9	12.3	16.1	16.9	17.3	12.3	7.2	2.1	-3.3
	DBStd	9.10	5.62	5.80	4.36	4.44	3.19	2.75	2.53	2.81	4.01	3.92	4.31	5.27
	HDD10.0	2029	500	376	256	110	14	0	0	0	24	100	237	411
	HDD18.3	4278	758	609	513	343	186	77	57	51	184	344	486	669
	CDD10.0	838	0	0	1	17	87	184	215	227	92	14	2	0
	CDD18.3	46	0	0	0	0	1	10	13	19	2	0	0	0
	CDH23.3	860	0	0	0	2	31	151	235	371	71	1	0	0
CDH26.7	171	0	0	0	0	1	21	49	89	11	0	0	0	
Wind	WSAvg	1.8	1.5	1.6	2.1	2.3	1.9	1.8	1.9	1.7	1.8	1.6	1.4	1.7
Precipitation	PrecAvg	620	23	25	33	51	71	96	89	66	53	47	32	38
	PrecMax	852	49	53	73	93	117	178	163	115	131	101	76	110
	PrecMin	443	9	7	6	21	18	26	36	20	5	2	0	8
	PrecStd	94	11	11	17	22	26	34	35	23	30	25	17	26
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.8	11.3	17.4	23.2	26.1	29.0	30.2	31.5	27.8	21.7	15.1	9.0
		MCWB	5.2	8.1	9.3	12.6	15.9	19.7	19.6	19.2	17.1	13.8	10.7	7.2
	2%	DB	4.3	7.6	13.8	21.1	23.8	26.7	27.9	28.7	25.1	19.6	12.7	6.8
		MCWB	3.1	5.4	7.8	12.3	15.3	18.5	19.2	18.1	15.8	13.1	9.8	5.4
	5%	DB	2.5	5.7	10.7	18.5	21.8	25.1	25.9	27.1	22.9	17.0	10.6	4.8
		MCWB	1.6	4.1	6.3	11.1	14.6	17.8	18.6	17.9	15.1	12.0	8.1	3.6
	10%	DB	1.0	3.8	8.1	15.6	19.9	23.1	24.0	25.2	20.6	14.2	8.8	3.1
		MCWB	0.2	2.5	4.7	9.7	13.9	17.1	17.5	17.4	14.5	10.9	6.9	2.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.4	8.2	10.5	13.7	18.2	21.2	21.2	21.1	18.3	15.5	11.2	7.8
		MCDB	6.7	11.5	16.7	21.3	23.0	26.9	27.2	27.8	25.9	19.3	14.2	8.3
	2%	WB	3.3	5.7	8.3	12.7	16.7	19.7	20.0	19.6	16.8	13.7	10.0	5.5
		MCDB	4.1	7.4	12.8	19.9	21.6	25.1	26.1	25.9	23.2	17.8	13.0	6.5
	5%	WB	1.9	4.2	6.7	11.7	15.4	18.7	19.1	18.7	15.9	12.5	8.7	3.8
		MCDB	2.7	5.5	10.7	18.0	20.2	23.9	24.3	25.0	22.1	16.4	10.5	4.7
	10%	WB	0.4	2.6	5.3	10.3	14.3	17.7	18.2	18.0	14.8	11.0	7.1	2.1
		MCDB	1.0	3.6	7.8	14.9	18.9	22.3	23.3	24.1	19.9	13.8	8.8	3.1
Mean Daily Temperature Range	5% DB	MDBR	7.3	8.6	9.9	12.0	12.3	12.2	13.0	14.3	12.6	12.0	7.7	5.9
		MCDBR	6.8	9.4	15.1	18.1	16.4	15.9	17.1	18.1	17.8	18.1	11.1	7.3
		MCWBR	5.9	7.6	9.7	9.9	8.9	8.2	8.7	8.5	8.8	11.2	8.1	6.2
	5% WB	MCDBR	6.3	9.4	14.5	16.5	14.8	14.3	15.1	15.9	16.5	16.2	10.5	7.7
		MCWBR	5.4	7.4	9.5	9.1	8.7	8.0	8.0	7.9	8.3	10.4	7.9	6.2
Clear-Sky Solar Irradiance	taub	0.301	0.333	0.380	0.441	0.416	0.411	0.434	0.442	0.397	0.358	0.331	0.303	
	taud	2.303	2.227	2.175	2.061	2.211	2.263	2.203	2.175	2.266	2.366	2.376	2.346	
	Ebn at Noon	780	822	833	811	851	855	828	803	808	789	739	733	
	Edh at Noon	77	102	125	154	138	132	138	136	114	89	72	66	
All-Sky Solar Radiation	RadAvg	1.27	2.12	3.23	4.32	5.34	5.76	5.71	5.26	3.74	2.56	1.44	0.97	
	RadStd	0.17	0.23	0.39	0.43	0.50	0.48	0.49	0.47	0.43	0.32	0.19	0.12	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (66 neighbors)		+0.70	N/A	N/A	+0.85	N/A	N/A	-158	-220	+83	+19

Nomenclature: See separate page