

TARGU MURES, Romania

WMO: 151450

Lat: 46.5281N

Lon: 24.5227E

Elev: 1021

StdP: 14.16

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	3.4	9.0	0.0	5.7	5.0	6.1	7.8	10.4	20.5	31.4	16.5	32.8	2.3	90	0.483

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.6	90.0	69.2	87.5	68.2	84.3	67.1	71.8	84.6	70.1	82.7	68.5	80.5	5.3	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
68.0	106.9	76.4	66.2	100.4	74.4	64.6	94.8	72.7	36.3	84.8	34.7	83.0	33.3	80.8	79.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.9	13.7	11.0	-3.2	95.1	6.7	3.3	-8.0	97.5	-12.0	99.5	-15.7	101.3	-20.6	103.7
			-3.5	74.4	6.7	2.4	-8.3	76.1	-12.2	77.5	-15.9	78.8	-20.8	80.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	50.1	27.7	32.7	41.1	51.7	60.2	66.5	69.7	69.3	60.5	50.4	40.0	30.2	(6)
	DBStd	16.43	8.99	8.96	7.87	6.59	5.95	5.44	5.09	5.17	6.47	7.35	8.26	8.55	(7)
	HDD50	2540	691	484	285	58	4	0	0	0	4	87	312	615	(8)
	HDD65	5894	1156	904	740	401	168	47	17	19	161	452	749	1080	(9)
	CDD50	2573	0	0	10	107	320	495	609	599	319	101	13	0	(10)
	CDD65	454	0	0	0	1	19	92	161	153	27	1	0	0	(11)
	CDH74	5270	0	0	1	52	360	1011	1697	1690	431	28	0	0	(12)
	CDH80	1801	0	0	0	6	62	307	642	663	118	3	0	0	(13)
(14) Wind	WSAvg	4.2	3.6	4.0	5.2	5.1	4.7	4.5	4.3	4.1	4.1	3.5	3.6	3.4	(14)
(15) Precipitation	PrecAvg	23.8	1.1	1.0	1.3	2.0	2.8	3.6	3.0	2.2	2.2	1.9	1.5	1.5	(15)
	PrecMax	31.0	2.4	2.4	3.0	3.6	6.0	7.6	4.9	4.3	5.2	3.7	2.9	3.4	(16)
	PrecMin	17.2	0.4	0.3	0.3	0.2	0.9	1.0	1.1	0.6	0.2	0.1	0.0	0.4	(17)
	PrecStd	3.7	0.6	0.5	0.7	1.0	1.1	1.5	1.2	1.1	1.2	1.0	0.6	0.8	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.1	59.0	69.7	80.2	85.6	91.0	94.8	94.9	88.1	77.3	67.6	52.2	(19)
		MCWB	45.2	49.0	53.5	59.5	64.9	70.2	69.1	69.0	65.2	60.6	56.6	47.0	(20)
	2%	DB	44.6	53.2	64.2	73.7	81.1	87.4	90.0	90.8	82.9	73.2	61.1	46.7	(21)
		MCWB	41.9	46.0	50.7	56.8	63.0	68.8	70.1	68.6	63.8	59.1	53.2	44.0	(22)
	5%	DB	41.0	48.2	59.1	69.7	78.4	84.0	87.2	87.4	78.9	68.3	56.7	43.0	(23)
		MCWB	39.0	43.0	48.5	54.9	62.3	67.7	68.7	68.1	62.5	57.6	50.6	41.5	(24)
	10%	DB	37.6	44.3	55.0	66.0	74.5	80.5	83.4	83.8	74.9	63.6	51.9	40.4	(25)
		MCWB	36.3	40.7	46.4	53.2	60.8	66.3	67.4	66.9	61.5	55.2	47.8	39.2	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.1	49.8	55.3	61.1	69.1	73.7	74.2	74.1	68.3	63.1	57.6	48.0	(27)
		MCDB	49.2	57.3	66.0	75.4	79.5	85.9	87.2	86.6	82.9	73.6	64.8	50.8	(28)
	2%	WB	42.1	46.5	52.1	58.7	65.6	71.0	71.7	71.4	65.6	60.5	54.0	44.1	(29)
		MCDB	43.7	51.9	61.6	71.0	76.6	82.9	84.8	84.2	77.8	69.6	59.8	46.0	(30)
	5%	WB	39.0	43.6	49.4	56.4	63.4	68.8	70.1	69.6	63.9	58.5	51.2	41.5	(31)
		MCDB	40.5	47.2	57.8	66.6	74.6	80.3	82.8	82.5	75.0	66.5	56.0	42.8	(32)
	10%	WB	36.3	40.6	46.9	54.4	61.7	67.1	68.5	67.9	62.3	56.3	48.3	39.0	(33)
		MCDB	37.4	43.7	53.7	63.3	72.0	77.7	80.3	80.1	72.1	62.8	51.7	39.9	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	12.5	15.9	20.4	22.6	22.8	22.7	23.6	24.8	22.9	22.0	16.2	10.9	(35)
		MCDBR	15.1	21.7	29.3	30.3	29.9	28.7	29.9	31.1	30.9	29.5	24.4	15.1	(36)
	5% WB	MCWBR	11.8	14.7	16.9	15.2	13.8	12.6	11.7	11.6	13.2	16.5	16.1	12.1	(37)
		MCWBR	14.4	20.6	26.1	26.1	26.1	25.9	26.7	27.2	27.1	26.3	21.8	14.6	(38)
(40) Clear-Sky Solar Irradiance	taub		0.313	0.341	0.382	0.434	0.416	0.413	0.433	0.438	0.398	0.363	0.340	0.315	(40)
		taud	2.331	2.291	2.240	2.123	2.238	2.280	2.229	2.211	2.292	2.377	2.389	2.359	(41)
	Ebn at Noon		244	260	265	260	270	271	263	256	257	249	232	229	(42)
		Edh at Noon	24	31	37	46	43	41	43	42	35	28	23	21	(43)
(44) All-Sky Solar Radiation	RadAvg		410	681	1033	1383	1712	1853	1835	1687	1200	822	462	310	(44)
	RadStd		54	74	121	136	155	155	154	150	135	100	59	38	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+1.17	N/A	N/A	+1.96	N/A	N/A	N/A	-301	+171	+97
(47)	Regional (72 neighbors)	+1.30	N/A	N/A	+1.69	N/A	N/A	-279	-396	+157	+32

Nomenclature: See separate page