

VASLUI, Romania

WMO: 151540

Lat: 46.6461N

Lon: 27.7144E

Elev: 385

StdP: 14.49

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	5.1	10.0	1.3	6.0	5.0	6.1	7.6	11.4	21.2	22.9	19.1	22.5	3.9	310	0.474

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.9	91.2	69.3	88.6	68.2	86.3	67.8	72.6	85.4	71.0	83.5	69.6	81.7	5.1	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.9	107.6	76.9	67.1	101.2	74.9	65.7	96.2	73.5	36.5	85.6	35.1	83.4	33.8	81.9	77.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.5	15.4	12.7	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	51.0	26.4	33.6	40.7	51.0	61.9	69.1	71.1	71.1	62.4	50.9	41.6	31.1		
	DBStd	17.34	8.43	9.91	8.93	8.12	6.19	5.45	4.91	5.65	8.07	7.71	8.43	9.52		
	HDD50	2535	730	462	303	89	5	0	0	0	4	82	275	585		
	HDD65	5758	1195	879	752	420	131	23	9	16	141	440	702	1050		
	CDD50	2902	0	2	16	120	374	574	654	653	377	109	23	0		
	CDD65	650	0	0	0	1	35	146	198	204	64	2	0	0		
	CDH74	7297	0	0	1	52	500	1577	2044	2300	791	32	0	0		
	CDH80	2707	0	0	0	4	114	539	775	1013	260	2	0	0		
(14) Wind	WSAvg	5.0	5.3	5.5	5.7	6.2	4.8	5.0	4.4	4.4	4.4	4.4	5.4	4.8		
(15) Precipitation	PrecAvg	21.1	1.0	0.9	1.2	1.7	2.6	3.0	2.7	1.8	1.8	1.9	1.3	1.3		
	PrecMax	28.3	2.2	2.7	2.4	3.9	7.0	6.5	6.6	4.3	5.5	7.6	3.3	4.5		
	PrecMin	14.1	0.2	0.1	0.0	0.2	0.1	0.8	0.2	0.3	0.1	0.2	0.0	0.1		
	PrecStd	4.1	0.6	0.7	0.6	0.8	1.7	1.4	1.5	1.1	1.4	1.5	0.9	1.1		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	48.2	61.9	70.2	79.1	87.9	91.5	94.0	95.6	89.9	78.0	67.8	54.9		
		MCWB	43.1	52.1	53.6	60.0	63.9	73.3	69.8	70.1	66.1	63.1	56.5	48.1		
	2%	DB	43.6	54.8	63.4	74.9	83.4	88.2	90.1	91.7	86.2	72.4	62.5	50.6		
		MCWB	40.7	47.8	51.1	58.1	64.1	70.4	69.0	68.6	64.7	59.2	54.1	46.4		
	5%	DB	40.3	49.3	58.7	70.7	79.7	86.1	87.5	89.0	82.4	68.2	57.0	46.8		
		MCWB	37.8	43.6	47.9	56.1	63.3	69.2	68.7	67.5	63.0	57.1	51.7	44.0		
	10%	DB	37.4	45.4	54.6	66.7	76.2	83.3	84.5	86.1	78.4	63.6	53.3	41.9		
		MCWB	35.5	41.8	45.9	54.5	61.2	68.0	68.1	67.4	62.7	55.5	49.0	38.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	44.0	52.9	54.8	62.1	69.3	75.6	73.2	73.7	68.8	64.4	58.2	50.9		
		MCDB	46.3	61.2	67.5	75.7	83.2	87.6	85.0	89.5	82.7	75.8	65.1	52.7		
	2%	WB	41.2	47.6	51.7	59.5	66.4	73.3	71.6	71.9	66.7	61.1	55.2	46.9		
		MCDB	43.3	53.6	62.7	71.4	78.7	84.7	84.9	85.7	79.5	69.3	61.9	49.9		
	5%	WB	38.3	44.2	49.1	57.2	64.3	71.3	70.2	70.2	65.3	58.8	52.5	43.5		
		MCDB	40.0	47.8	56.9	68.2	75.3	82.6	82.5	83.3	77.4	65.7	57.1	47.3		
	10%	WB	35.7	42.2	46.7	55.2	62.7	69.3	69.1	68.7	63.8	56.6	49.7	39.6		
		MCDB	37.0	45.2	52.9	65.3	73.0	80.2	80.7	81.1	75.4	62.4	53.1	41.6		
(35) Mean Daily Temperature Range	5% DB	MDBR	11.6	13.6	18.1	20.6	23.0	22.8	22.9	24.7	22.6	18.6	12.3	11.5		
		MCDBR	15.3	20.8	26.0	29.1	28.9	26.9	28.1	30.6	30.3	26.6	20.1	17.5		
		MCWBR	12.0	13.2	15.2	15.0	12.7	10.9	10.0	10.4	12.3	14.0	12.1	12.7		
	5% WB	MCDBR	14.6	17.8	24.6	25.8	24.0	25.0	23.6	26.3	26.4	23.1	17.9	17.3		
		MCWBR	11.5	11.8	15.0	13.9	11.4	11.1	9.2	9.7	10.8	12.5	11.3	12.7		
(40) Clear-Sky Solar Irradiance	taub		0.329	0.359	0.396	0.454	0.425	0.422	0.447	0.456	0.413	0.380	0.354	0.327		
	taud		2.261	2.225	2.192	2.060	2.222	2.265	2.203	2.168	2.247	2.319	2.327	2.302		
	Ebn at Noon		234	251	259	254	267	268	259	251	251	241	224	221		
	Edh at Noon		26	33	39	49	43	42	44	44	37	30	24	22		
(44) All-Sky Solar Radiation	RadAvg		391	634	1020	1406	1806	1896	1906	1730	1229	787	410	311		
	RadStd		56	84	100	126	155	163	149	124	130	90	41	39		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (40 neighbors)	+1.13	N/A	N/A	+1.28	N/A	N/A	-238	-328	+164	+58

Nomenclature: See separate page