

SIRIA, Romania

WMO: 151790

Lat: 46.2647N

Lon: 21.6628E

Elev: 1556

StdP: 13.89

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.5	18.4	3.7	7.1	24.5	9.4	9.4	23.7	39.5	37.9	33.0	41.0	7.7	20	0.509

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	14.3	88.7	67.0	85.5	67.1	82.5	66.1	70.3	81.5	68.8	80.7	67.5	79.5	7.6	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.7	104.2	76.3	64.9	97.6	74.2	63.3	92.2	72.5	35.2	80.6	33.9	81.2	32.8	79.4	77.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 36.0	27.8	22.7	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	52.7	31.3	37.1	42.9	52.3	61.5	67.9	70.5	72.0	62.8	53.8	45.2	34.6		
	DBStd	16.20	8.90	8.67	8.49	10.17	7.07	6.86	6.89	8.08	9.11	9.20	9.42	8.26		
	HDD50	2052	581	365	249	96	6	0	0	0	5	69	199	482		
	HDD65	5202	1045	781	685	391	154	48	25	25	151	362	593	942		
	CDD50	3049	1	4	30	164	361	536	636	683	389	185	56	4		
	CDD65	723	0	0	0	9	44	134	196	242	85	13	0	0		
	CDH74	4622	0	0	0	17	128	747	1318	1943	455	14	0	0		
	CDH80	1316	0	0	0	0	6	144	389	675	102	0	0	0		
(14) Wind	WSAvg	8.9	8.6	11.0	9.8	9.9	8.5	7.3	6.8	7.0	7.8	8.5	11.6	9.6		
(15) Precipitation	PrecAvg	24.9	1.4	1.3	1.3	2.0	2.5	3.3	3.0	2.0	2.3	2.2	2.0	2.2		
	PrecMax	36.4	3.1	4.0	3.0	3.5	5.9	7.8	7.1	4.3	5.5	5.2	4.9	4.2		
	PrecMin	13.5	0.4	0.0	0.2	0.8	0.6	0.6	0.9	0.1	0.4	0.0	0.0	0.6		
	PrecStd	6.1	0.7	1.0	0.8	0.8	1.3	1.7	1.7	1.3	1.1	1.3	1.1	1.1		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.1	58.4	67.6	76.0	80.3	86.4	92.1	94.2	87.5	75.7	66.9	57.4		
		MCWB	45.6	47.9	53.3	60.0	63.2	69.3	67.7	67.5	66.4	59.5	53.9	48.2		
	2%	DB	49.9	54.7	62.4	72.3	77.5	83.9	87.7	90.0	83.0	71.8	63.0	52.9		
		MCWB	42.6	46.1	50.4	57.0	62.8	69.2	67.2	66.7	65.1	58.6	52.3	46.3		
	5%	DB	47.3	51.8	58.7	69.2	74.6	80.9	84.0	86.6	79.0	69.1	60.6	49.0		
		MCWB	41.1	44.5	47.8	54.9	61.1	67.4	66.5	66.3	63.6	57.1	51.8	43.4		
	10%	DB	44.2	49.0	54.8	66.2	72.0	78.1	80.8	83.2	75.9	66.3	57.3	46.0		
		MCWB	39.1	42.6	45.5	52.8	59.8	66.0	65.8	65.7	62.0	56.2	50.0	41.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.8	50.1	54.3	61.1	65.7	74.4	71.4	71.3	69.0	62.3	55.8	49.9		
		MCDB	52.1	57.3	66.3	74.7	77.1	83.3	82.6	82.0	84.7	70.3	63.0	56.2		
	2%	WB	44.4	47.0	51.4	58.5	64.2	71.1	69.4	69.2	66.6	60.3	54.3	47.2		
		MCDB	48.8	52.2	61.5	70.7	75.1	80.2	81.3	82.5	80.4	68.8	60.7	52.9		
	5%	WB	42.3	45.2	48.9	56.2	62.5	69.1	68.1	68.0	64.3	58.6	52.8	44.1		
		MCDB	46.0	50.9	58.0	67.3	73.1	78.9	80.0	81.4	76.7	67.3	58.7	48.8		
	10%	WB	39.2	43.4	46.5	54.1	60.7	67.2	66.8	66.7	62.7	56.8	51.1	42.0		
		MCDB	43.7	48.6	53.8	65.1	70.4	77.2	78.6	80.1	73.6	65.1	56.9	45.4		
(35) Mean Daily Temperature Range	5% DB	MDBR	8.4	9.8	12.5	14.2	13.8	13.9	14.4	14.3	12.6	10.4	8.9	7.9		
		MCDBR	9.8	12.6	16.4	15.9	15.2	15.8	16.4	16.2	14.9	12.9	11.2	10.8		
		MCWBR	6.9	7.6	9.9	9.6	9.1	8.5	7.0	5.9	6.6	6.5	6.2	6.8		
		MCDBR	10.3	12.5	15.4	15.4	14.4	14.9	15.2	15.7	14.2	11.3	10.3	10.4		
	5% WB	MCWBR	6.9	8.1	9.5	9.7	8.7	9.1	7.4	6.9	6.7	6.7	6.4	7.1		
(40) Clear-Sky Solar Irradiance	taub		0.319	0.344	0.379	0.430	0.415	0.411	0.425	0.429	0.403	0.367	0.341	0.320		
	taud		2.366	2.313	2.255	2.121	2.224	2.265	2.229	2.218	2.264	2.361	2.390	2.388		
	Ebn at Noon		244	260	266	262	271	272	266	259	255	248	233	229		
	Edh at Noon		23	30	37	46	43	42	43	42	36	29	23	21		
(44) All-Sky Solar Radiation	RadAvg		362	628	1023	1456	1762	1933	1909	1723	1206	812	469	283		
	RadStd		42	92	139	140	164	151	151	162	132	88	44	40		

Historical Trends

		Heating			Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (65 neighbors)	+1.28	N/A	N/A	+1.71	N/A	-225	-344	+212	+106	

Nomenclature: See separate page