

SIRIA, Romania

WMO: 151790

Lat: 46.2647N

Lon: 21.6628E

Elev: 474

StdP: 95.76

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-9.7	-7.6	-15.7	1.0	-4.2	-12.6	1.3	-4.6	17.6	3.3	14.8	5.0	3.4	20	0.509

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.0	31.5	19.4	29.7	19.5	28.1	18.9	21.3	27.5	20.5	27.1	19.7	26.4	3.4	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.3	14.9	24.6	18.3	13.9	23.4	17.4	13.2	22.5	64.0	27.0	60.9	27.3	58.3	26.4	25.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.1	12.4	10.2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	11.5	-0.4	2.8	6.1	11.3	16.4	19.9	21.4	22.2	17.1	12.1	7.4	1.4	(6)
(7)		DBStd	9.00	4.94	4.82	4.71	5.65	3.93	3.81	3.83	4.49	5.06	5.11	5.23	4.59	(7)
(8)		HDD10.0	1140	323	203	138	53	3	0	0	0	3	38	111	268	(8)
(9)		HDD18.3	2890	581	434	381	217	86	27	14	14	84	201	329	523	(9)
(10)		CDD10.0	1694	1	2	17	91	201	298	353	379	216	103	31	2	(10)
(11)		CDD18.3	402	0	0	0	5	24	74	109	134	47	7	0	0	(11)
(12)		CDH23.3	2568	0	0	0	9	71	415	732	1079	253	8	0	0	(12)
(13)		CDH26.7	731	0	0	0	0	3	80	216	375	57	0	0	0	(13)
(14)	Wind	WSAvg	4.0	3.8	4.9	4.4	4.4	3.8	3.3	3.1	3.1	3.5	3.8	5.2	4.3	(14)
(15)	Precipitation	PrecAvg	633	36	33	32	50	63	84	75	52	59	57	51	56	(15)
(16)		PrecMax	925	80	101	77	90	151	198	181	108	140	132	125	107	(16)
(17)		PrecMin	342	9	1	5	21	14	15	22	3	9	1	0	16	(17)
(18)		PrecStd	156	19	25	21	21	32	44	43	33	29	34	28	27	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.7	14.7	19.8	24.4	26.8	30.2	33.4	34.5	30.8	24.3	19.4	14.1	(19)
(20)			MCWB	7.6	8.8	11.8	15.5	17.3	20.7	19.8	19.7	19.1	15.3	12.2	9.0	(20)
(21)		2%	DB	9.9	12.6	16.9	22.4	25.3	28.8	30.9	32.2	28.3	22.1	17.2	11.6	(21)
(22)			MCWB	5.9	7.8	10.2	13.9	17.1	20.7	19.6	19.3	18.4	14.8	11.3	7.9	(22)
(23)		5%	DB	8.5	11.0	14.8	20.7	23.7	27.1	28.9	30.3	26.1	20.6	15.9	9.5	(23)
(24)			MCWB	5.1	6.9	8.8	12.7	16.2	19.6	19.2	19.0	17.6	13.9	11.0	6.3	(24)
(25)		10%	DB	6.8	9.4	12.7	19.0	22.2	25.6	27.1	28.5	24.4	19.1	14.1	7.8	(25)
(26)			MCWB	3.9	5.9	7.5	11.6	15.4	18.9	18.8	18.7	16.7	13.5	10.0	5.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.2	10.1	12.4	16.2	18.7	23.5	21.9	21.8	20.6	16.8	13.2	9.9	(27)
(28)			MCDWB	11.2	14.0	19.0	23.7	25.1	28.5	28.1	27.8	29.3	21.3	17.2	13.4	(28)
(29)		2%	WB	6.9	8.4	10.8	14.7	17.9	21.7	20.8	20.6	19.2	15.7	12.4	8.5	(29)
(30)			MCDWB	9.3	11.2	16.4	21.5	23.9	26.8	27.4	28.0	26.9	20.4	15.9	11.6	(30)
(31)		5%	WB	5.7	7.3	9.4	13.4	17.0	20.6	20.1	20.0	17.9	14.8	11.5	6.7	(31)
(32)			MCDWB	7.8	10.5	14.4	19.6	22.8	26.0	26.7	27.5	24.8	19.6	14.8	9.3	(32)
(33)		10%	WB	4.0	6.3	8.0	12.3	16.0	19.6	19.3	19.3	17.0	13.8	10.6	5.6	(33)
(34)			MCDWB	6.5	9.2	12.1	18.4	21.3	25.1	25.9	26.7	23.1	18.4	13.8	7.5	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.6	5.4	6.9	7.9	7.6	7.7	8.0	8.0	7.0	5.8	5.0	4.4	(35)
(36)			MCDBR	5.4	7.0	9.1	8.8	8.5	8.8	9.1	9.0	8.3	7.2	6.2	6.0	(36)
(37)			MCWBR	3.8	4.2	5.5	5.3	5.0	4.7	3.9	3.3	3.7	3.6	3.5	3.8	(37)
(38)		5% WB	MCDWB	5.7	6.9	8.6	8.6	8.0	8.3	8.5	8.7	7.9	6.3	5.7	5.8	(38)
(39)			MCWBR	3.8	4.5	5.3	5.4	4.8	5.1	4.1	3.8	3.7	3.7	3.6	4.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.319	0.344	0.379	0.430	0.415	0.411	0.425	0.429	0.403	0.367	0.341	0.320	(40)	
(41)		taud	2.366	2.313	2.255	2.121	2.224	2.265	2.229	2.218	2.264	2.361	2.390	2.388	(41)	
(42)		Ebn at Noon	768	819	839	825	853	856	838	817	804	782	734	723	(42)	
(43)		Edh at Noon	74	95	117	146	136	132	135	131	115	90	73	66	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.14	1.98	3.22	4.59	5.56	6.09	6.02	5.43	3.80	2.56	1.48	0.89	(44)	
(45)		RadStd	0.13	0.29	0.44	0.44	0.52	0.48	0.48	0.51	0.42	0.28	0.14	0.13	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (65 neighbors)	+0.71	N/A	N/A	+0.95	N/A	N/A	-125	-191	+118	+59

Nomenclature: See separate page