

GURAHONT, Romania

WMO: 151820

Lat: 46.2792N

Lon: 22.3333E

Elev: 585

StdP: 14.39

Time Zone: 2.00 (EUE)

Period: 90-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.1	17.1	8.2	8.6	16.3	12.5	10.6	19.0	15.2	34.8	11.8	37.0	2.1	120	0.447

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	23.9	91.7	70.0	88.3	69.5	85.2	68.8	72.8	85.4	71.5	84.1	70.2	82.2	4.3	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.3	110.2	76.8	67.8	104.4	75.3	66.4	99.4	74.3	36.8	85.1	35.6	84.4	34.4	81.9	78.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.6	11.1	9.2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	52.4	31.2	37.0	42.6	52.0	61.4	68.0	69.7	71.4	61.3	52.8	45.0	35.5		
	DBStd	15.27	8.28	7.82	7.52	8.17	5.48	5.86	5.32	5.77	7.34	7.62	8.24	7.02		
	HDD50	1982	582	367	248	74	2	0	0	0	3	61	195	450		
	HDD65	5171	1047	784	694	391	136	35	18	14	157	380	601	914		
	CDD50	2860	0	3	19	135	356	539	611	662	343	148	44	0		
	CDD65	577	0	0	0	2	25	125	165	211	47	2	0	0		
	CDH74	6217	0	0	1	93	347	1255	1699	2224	522	76	0	0		
	CDH80	2288	0	0	0	9	52	411	640	1004	168	4	0	0		
(14) Wind	WSAvg	3.3	2.6	3.4	3.9	4.0	3.6	3.3	3.5	3.3	3.2	3.2	3.1	2.9		
(15) Precipitation	PrecAvg	32.9	2.3	1.7	2.2	2.6	3.2	3.8	3.9	2.5	3.0	2.6	2.5	2.6		
	PrecMax	43.2	3.7	5.0	6.5	4.6	5.9	7.1	7.0	5.2	7.2	5.6	5.0	5.7		
	PrecMin	22.8	0.9	0.4	0.6	0.7	1.5	1.2	1.3	0.5	0.6	0.2	0.2	0.4		
	PrecStd	5.3	0.8	1.1	1.4	1.1	1.1	1.4	1.8	1.3	1.5	1.5	1.0	1.3		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.5	61.5	71.0	80.8	84.6	90.9	94.2	96.7	90.4	79.8	69.8	56.6		
		MCWB	48.6	50.3	55.2	61.0	65.0	72.0	70.3	70.8	67.3	61.5	56.4	48.7		
	2%	DB	48.4	57.0	65.4	76.4	81.2	87.7	90.9	93.3	84.1	75.8	66.0	51.4		
		MCWB	44.1	47.6	51.7	58.6	64.6	70.8	70.2	69.2	65.3	60.3	55.3	46.5		
	5%	DB	45.0	52.6	59.9	72.1	78.0	84.7	86.9	89.1	80.0	71.3	61.6	48.0		
		MCWB	41.8	45.6	49.1	57.0	63.0	69.5	69.4	69.4	64.8	59.0	53.4	44.3		
	10%	DB	41.8	48.7	55.3	67.5	74.7	81.4	83.0	85.5	75.0	65.6	57.2	44.6		
		MCWB	39.3	43.5	46.4	54.6	61.6	68.3	68.3	69.2	63.5	56.8	51.5	41.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.3	52.1	56.1	62.8	69.1	75.4	73.7	74.9	69.5	64.1	58.0	50.2		
		MCDB	55.1	59.7	70.8	76.8	80.6	86.1	85.3	87.1	86.2	73.4	66.9	55.2		
	2%	WB	45.2	48.9	52.7	60.5	66.4	72.8	72.1	72.7	67.7	61.7	56.2	46.7		
		MCDB	47.7	55.1	63.7	73.8	76.8	84.1	84.8	86.2	79.3	72.3	64.1	51.1		
	5%	WB	42.3	46.6	50.0	58.2	64.5	71.0	70.9	71.3	66.0	60.2	54.5	44.5		
		MCDB	44.6	52.0	57.7	70.5	74.7	82.0	83.1	84.4	77.1	69.7	61.5	48.2		
	10%	WB	39.1	43.7	47.7	56.1	62.8	69.2	69.6	69.9	64.3	57.8	52.1	42.1		
		MCDB	41.5	48.1	54.4	66.4	72.0	79.5	80.5	82.8	72.9	64.9	56.8	44.4		
(35) Mean Daily Temperature Range	5% DB	MDBR	11.7	15.4	18.9	21.2	21.1	21.4	22.8	23.9	20.9	20.5	15.8	10.8		
		MCDBR	15.4	21.5	26.4	29.1	27.4	26.1	29.1	30.2	28.4	29.8	22.0	16.0		
		MCWBR	11.2	13.3	14.6	13.8	12.7	11.0	10.8	10.2	10.9	14.8	12.6	11.0		
	5% WB	MCDBR	14.9	19.7	24.0	26.2	24.9	24.6	24.7	26.7	24.2	26.6	20.1	16.1		
		MCWBR	10.7	12.3	13.8	12.7	12.3	10.9	10.3	10.4	9.8	13.4	11.4	11.1		
(40) Clear-Sky Solar Irradiance	taub		0.327	0.355	0.397	0.452	0.438	0.432	0.449	0.455	0.421	0.381	0.352	0.328		
	taud		2.337	2.271	2.209	2.078	2.180	2.235	2.195	2.176	2.239	2.342	2.373	2.370		
	Ebn at Noon		239	255	260	255	264	266	259	252	249	243	228	225		
	Edh at Noon		24	31	39	48	45	43	44	43	37	29	23	21		
(44) All-Sky Solar Radiation	RadAvg		384	640	1008	1391	1674	1853	1819	1669	1183	813	469	305		
	RadStd		51	85	144	143	158	158	157	161	131	95	59	41		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (67 neighbors)	+1.28	N/A	N/A	N/A	+1.75	N/A	N/A	-229	-347	+211	+104

Nomenclature: See separate page