

TARGU OCNA, Romania

WMO: 151940

Lat: 46.2728N

Lon: 26.6411E

Elev: 243

StdP: 98.44

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.7	-10.5	-15.6	1.0	-11.4	-13.5	1.2	-9.2	9.1	6.0	7.6	1.7	1.5	290	0.482

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.7	31.9	21.0	30.2	20.5	28.8	20.1	22.8	29.3	21.8	28.0	21.0	27.1	2.5	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.8	15.9	25.8	19.7	14.9	24.6	18.9	14.1	23.6	68.5	29.8	64.6	28.1	61.7	27.3	26.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.5	6.4	5.6	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	10.8	-1.9	1.5	5.2	10.5	16.3	20.3	21.4	21.7	16.7	10.6	5.5	1.1
	DBStd	9.11	4.59	5.08	4.80	4.54	3.39	2.98	2.73	2.95	4.19	4.00	4.32	5.04
	HDD10.0	1286	368	240	158	51	3	0	0	0	2	41	147	277
	HDD18.3	3084	627	472	406	236	78	15	6	7	78	240	386	534
	CDD10.0	1577	0	1	10	65	199	309	354	362	204	59	11	1
	CDD18.3	335	0	0	0	1	16	75	102	111	30	1	0	0
	CDH23.3	2957	0	0	2	32	188	648	814	981	278	13	1	0
	CDH26.7	936	0	0	0	3	33	186	267	374	73	0	0	0
(14) Wind	WSAvg	2.2	2.0	2.0	2.3	2.6	2.5	2.5	2.3	2.5	2.4	2.1	1.7	2.2
(15) Precipitation	PrecAvg	590	22	21	28	53	77	87	92	57	50	47	27	30
	PrecMax	857	50	56	65	99	167	185	192	177	149	164	57	79
	PrecMin	363	4	4	1	19	16	28	11	15	11	1	2	4
	PrecStd	133	14	13	14	24	44	44	51	36	34	33	16	21
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.7	16.8	22.0	26.0	29.8	32.1	34.1	34.2	31.6	25.1	20.1	15.7
		MCWB	7.9	10.7	12.2	15.9	18.2	22.8	20.7	21.9	19.9	16.5	13.3	9.4
	2%	DB	9.1	14.0	18.2	24.0	27.4	30.3	31.4	32.1	28.4	22.2	16.9	12.0
		MCWB	5.3	8.6	10.6	14.6	17.9	21.9	21.0	20.3	18.3	14.9	11.4	7.2
	5%	DB	6.6	11.1	15.1	21.3	25.5	28.9	29.5	30.4	26.4	20.0	14.0	9.8
		MCWB	3.6	6.9	8.8	13.2	17.0	20.8	20.4	20.3	17.7	14.1	10.1	6.4
	10%	DB	4.6	8.5	12.9	18.8	23.5	27.5	27.7	28.7	24.1	17.1	11.5	7.8
		MCWB	2.6	5.3	7.6	12.2	16.0	20.0	19.9	20.0	16.7	12.7	9.0	4.8
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.4	10.7	12.9	16.6	20.7	24.3	24.1	24.1	21.1	17.7	14.4	10.1
		MCDB	12.4	16.3	20.4	24.3	29.1	31.0	30.1	30.0	29.2	22.9	19.9	13.8
	2%	WB	6.1	8.8	11.0	15.3	19.0	22.7	22.2	22.6	19.5	15.9	12.2	7.9
		MCDB	9.0	13.1	17.9	22.8	25.3	29.2	28.2	29.3	26.4	20.6	15.8	11.9
	5%	WB	4.3	7.3	9.5	14.0	17.8	21.7	21.3	21.5	18.5	14.5	10.7	6.6
		MCDB	6.2	10.8	14.7	20.6	23.2	27.8	27.1	28.0	24.6	18.7	13.3	9.7
	10%	WB	2.7	5.6	8.1	12.7	16.8	20.7	20.6	20.6	17.6	13.1	9.3	5.2
		MCDB	4.5	7.9	12.0	17.8	21.8	26.5	26.1	26.9	23.1	16.7	11.5	7.7
(35) Mean Daily Temperature Range	5% DB	MDBR	7.7	8.7	9.5	10.6	11.2	11.0	11.1	11.7	10.9	10.2	8.0	7.1
		MCDBR	11.0	12.8	14.8	16.1	14.2	13.4	13.7	14.4	14.8	14.6	12.4	11.0
	5% WB	MCWBR	7.8	8.2	8.4	8.0	6.4	6.0	5.6	5.5	6.2	8.2	7.4	7.0
		MCWBR	10.7	12.0	13.9	15.0	12.7	12.5	12.0	13.0	13.5	13.4	10.9	10.5
(40) Clear-Sky Solar Irradiance	taub		0.316	0.347	0.387	0.449	0.423	0.422	0.443	0.455	0.409	0.372	0.343	0.316
		taud	2.336	2.258	2.215	2.080	2.231	2.271	2.220	2.181	2.271	2.360	2.387	2.359
	Ebn at Noon		769	812	830	806	845	847	822	794	798	776	731	724
		Edh at Noon	76	100	121	152	135	131	136	136	114	90	73	67
(44) All-Sky Solar Radiation	RadAvg		1.28	2.07	3.24	4.39	5.61	5.90	5.99	5.43	3.89	2.51	1.35	1.04
	RadStd		0.16	0.25	0.33	0.41	0.48	0.51	0.49	0.40	0.38	0.29	0.12	0.11

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (60 neighbors)	+0.63	N/A	N/A	+0.67	N/A	N/A	-134	-180	+75	+20	

Nomenclature: See separate page