

TARGU SECUIESC, Romania

WMO: 152170

Lat: 45.9928N

Lon: 26.1150E

Elev: 1870

StdP: 13.73

Time Zone: 2.00 (EUE)

Period: 86-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-0.3	5.2	-5.3	4.4	1.0	-0.4	5.8	6.6	26.0	22.3	22.3	23.6	4.0	0	0.551

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	24.6	86.2	65.8	83.3	64.5	80.4	63.9	68.1	81.8	66.6	79.4	65.2	77.2	7.7	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.6	94.3	73.1	62.1	89.2	70.8	60.8	85.1	69.7	33.5	82.6	32.2	79.9	31.1	77.0	74.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
20.8	17.9	15.5	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	46.8	24.3	29.9	37.4	47.1	56.7	63.2	65.6	66.4	57.4	46.9	37.5	28.6
	DBStd	16.34	9.35	9.37	8.59	8.49	5.76	5.26	4.80	5.10	7.19	7.16	8.58	8.91
	HDD50	3124	796	564	394	152	13	0	0	16	143	382	664	
	HDD65	6852	1261	984	854	538	262	94	53	47	243	561	826	1129
	CDD50	1970	0	0	4	65	220	397	482	509	239	48	6	0
	CDD65	220	0	0	0	0	3	40	71	91	15	0	0	0
	CDH74	2786	0	0	0	22	97	477	807	1112	262	9	0	0
	CDH80	712	0	0	0	0	11	90	224	326	61	0	0	0
Wind	WSAvg	5.6	5.8	6.2	6.6	6.3	5.7	5.2	4.9	5.1	5.5	5.7	4.5	5.5
Precipitation	PrecAvg	24.1	1.0	0.9	1.2	2.1	3.2	3.8	3.4	2.9	2.0	1.7	1.1	1.1
	PrecMax	34.5	2.2	1.6	2.2	3.8	7.0	6.2	6.4	6.3	4.4	3.5	2.2	2.4
	PrecMin	16.7	0.2	0.2	0.3	0.5	1.3	1.1	1.2	1.1	0.3	0.1	0.0	0.2
	PrecStd	4.1	0.5	0.4	0.5	0.9	1.5	1.6	1.5	1.4	1.0	0.9	0.6	0.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	45.7	57.6	68.7	77.0	81.9	86.6	89.0	90.8	86.4	75.1	64.1	50.5
		MCWB	41.3	49.7	52.6	56.6	60.9	70.6	67.1	67.4	64.3	57.6	52.7	45.3
	2%	DB	40.7	49.7	61.2	73.0	76.7	82.4	85.4	86.7	80.3	70.3	58.3	45.2
		MCWB	37.3	43.9	48.1	55.3	59.7	66.2	65.5	64.8	61.9	55.5	49.8	41.6
	5%	DB	37.8	44.8	55.1	68.0	73.4	79.6	82.0	83.5	76.3	65.4	53.6	41.3
		MCWB	34.9	40.5	45.2	53.2	59.1	65.1	65.1	63.9	60.4	53.2	46.9	38.3
	10%	DB	35.5	40.7	50.0	62.8	69.7	76.3	78.6	80.5	71.9	60.2	49.5	38.3
		MCWB	33.0	37.3	42.7	50.8	57.4	63.3	64.0	63.7	58.7	51.4	44.7	36.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	41.5	49.7	52.9	58.1	65.0	70.8	70.3	69.0	65.5	60.1	53.6	46.3
		MCDB	45.2	58.8	66.9	73.1	78.2	83.5	83.4	84.7	81.9	72.5	62.7	49.5
	2%	WB	37.7	44.0	49.3	55.9	61.9	68.1	67.7	67.5	63.1	56.6	50.9	41.9
		MCDB	40.5	49.3	60.5	70.4	72.6	80.1	80.7	82.9	77.9	68.0	57.9	45.1
	5%	WB	35.5	40.7	46.4	53.8	59.8	66.2	66.3	65.7	61.3	54.4	48.1	38.5
		MCDB	37.8	44.5	54.6	66.7	70.3	77.6	78.1	79.5	74.5	63.9	53.2	40.9
	10%	WB	33.3	37.8	43.3	51.6	58.1	64.3	64.9	64.4	59.7	52.0	45.3	36.2
		MCDB	35.3	40.7	49.3	61.6	68.2	74.6	76.3	76.8	70.5	59.8	49.4	38.2
Mean Daily Temperature Range	5% DB	MDBR	13.9	15.4	18.5	21.4	20.9	21.5	22.9	24.6	21.8	20.9	16.0	11.7
		MCDBR	13.4	19.7	29.2	31.9	27.4	27.5	29.3	30.6	29.5	31.2	23.7	14.6
		MCWBR	10.6	14.2	17.1	16.3	12.6	13.8	12.2	11.4	12.5	17.5	15.0	11.3
	5% WB	MCDBR	12.1	19.3	28.0	29.5	23.6	25.9	25.5	26.2	27.3	29.4	22.3	13.3
		MCWBR	10.0	14.4	16.6	15.1	12.2	13.8	11.6	11.1	12.1	16.7	14.7	10.7
Clear-Sky Solar Irradiance	taub	0.310	0.342	0.387	0.451	0.425	0.423	0.442	0.455	0.408	0.368	0.339	0.310	
	taud	2.309	2.223	2.173	2.042	2.192	2.238	2.192	2.146	2.243	2.343	2.367	2.340	
	Ebn at Noon	247	259	263	255	268	268	261	252	254	248	234	233	
	Edh at Noon	25	33	40	50	45	43	44	45	37	29	24	22	
All-Sky Solar Radiation	RadAvg	416	674	1033	1388	1741	1854	1876	1704	1228	815	453	336	
	RadStd	50	80	109	139	154	157	153	133	121	96	46	39	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (66 neighbors)	+1.10	N/A	N/A	+1.21	N/A	N/A	-238	-324	+140	+45

Nomenclature: See separate page