

TARGU SECUIESC, Romania

WMO: 152170

Lat: 45.9928N

Lon: 26.1150E

Elev: 570

StdP: 94.66

Time Zone: 2.00 (EUE)

Period: 86-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-18.0	-14.9	-20.7	0.6	-17.2	-18.0	0.8	-14.1	11.6	-5.4	10.0	-4.7	1.8	0	0.551

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	13.6	30.1	18.8	28.5	18.1	26.9	17.7	20.1	27.7	19.2	26.3	18.4	25.1	3.4	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.6	13.5	22.8	16.7	12.7	21.6	16.0	12.2	20.9	60.1	28.1	57.0	26.6	54.4	25.0	23.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.3	8.0	6.9	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	8.2	-4.3	-1.2	3.0	8.4	13.7	17.3	18.6	19.1	14.1	8.3	3.0	-1.9
	DBStd	9.08	5.20	5.21	4.77	4.72	3.20	2.92	2.67	2.83	4.00	3.98	4.77	4.95
	HDD10.0	1736	442	313	219	84	7	0	0	0	9	79	212	369
	HDD18.3	3807	701	547	474	299	146	52	29	26	135	312	459	627
	CDD10.0	1094	0	0	2	36	122	221	268	283	133	27	3	0
	CDD18.3	122	0	0	0	0	2	22	39	51	8	0	0	0
	CDH23.3	1548	0	0	0	12	54	265	448	618	146	5	0	0
	CDH26.7	396	0	0	0	0	6	50	124	181	34	0	0	0
Wind	WSAvg	2.5	2.6	2.8	2.9	2.8	2.5	2.3	2.2	2.3	2.4	2.5	2.0	2.5
Precipitation	PrecAvg	612	25	23	30	53	81	96	86	73	50	42	27	28
	PrecMax	876	55	41	56	96	179	157	163	161	112	90	56	61
	PrecMin	425	5	5	8	13	32	29	31	27	7	2	1	6
	PrecStd	105	12	10	13	22	37	40	38	35	25	23	14	13
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.6	14.2	20.4	25.0	27.7	30.4	31.6	32.7	30.2	24.0	17.8	10.3
		MCWB	5.2	9.8	11.4	13.7	16.0	21.4	19.5	19.7	18.0	14.2	11.5	7.4
	2%	DB	4.8	9.9	16.2	22.8	24.8	28.0	29.6	30.4	26.8	21.3	14.6	7.3
		MCWB	2.9	6.6	8.9	12.9	15.4	19.0	18.6	18.2	16.6	13.1	9.9	5.3
	5%	DB	3.2	7.1	12.8	20.0	23.0	26.4	27.8	28.6	24.6	18.5	12.0	5.2
		MCWB	1.6	4.7	7.4	11.8	15.0	18.4	18.4	17.7	15.8	11.8	8.3	3.5
	10%	DB	2.0	4.8	10.0	17.1	20.9	24.6	25.9	26.9	22.1	15.6	9.7	3.5
		MCWB	0.6	2.9	6.0	10.4	14.1	17.4	17.8	17.6	14.8	10.8	7.0	2.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.3	9.8	11.6	14.5	18.3	21.6	21.3	20.6	18.6	15.6	12.0	7.9
		MCDB	7.3	14.9	19.4	22.8	25.7	28.6	28.6	29.3	27.7	22.5	17.0	9.7
	2%	WB	3.2	6.7	9.6	13.3	16.6	20.0	19.8	19.7	17.3	13.6	10.5	5.5
		MCDB	4.7	9.6	15.8	21.3	22.6	26.7	27.0	28.3	25.5	20.0	14.4	7.3
	5%	WB	2.0	4.8	8.0	12.1	15.5	19.0	19.0	18.7	16.3	12.5	8.9	3.6
		MCDB	3.2	6.9	12.6	19.3	21.3	25.4	25.6	26.4	23.6	17.7	11.8	5.0
	10%	WB	0.7	3.2	6.3	10.9	14.5	18.0	18.3	18.0	15.4	11.1	7.4	2.3
		MCDB	1.9	4.8	9.6	16.5	20.1	23.7	24.6	24.9	21.4	15.4	9.7	3.5
Mean Daily Temperature Range	5% DB	MDBR	7.7	8.6	10.3	11.9	11.6	12.0	12.7	13.6	12.1	11.6	8.9	6.5
		MCDBR	7.5	11.0	16.2	17.7	15.2	15.3	16.3	17.0	16.4	17.4	13.1	8.1
		MCWBR	5.9	7.9	9.5	9.0	7.0	7.7	6.8	6.3	6.9	9.7	8.3	6.3
	5% WB	MCDBR	6.7	10.7	15.5	16.4	13.1	14.4	14.2	14.6	15.2	16.3	12.4	7.4
		MCWBR	5.5	8.0	9.2	8.4	6.8	7.7	6.5	6.2	6.7	9.3	8.1	5.9
Clear-Sky Solar Irradiance	taub	0.310	0.342	0.387	0.451	0.425	0.423	0.442	0.455	0.408	0.368	0.339	0.310	
	taud	2.309	2.223	2.173	2.042	2.192	2.238	2.192	2.146	2.243	2.343	2.367	2.340	
	Ebn at Noon	778	818	829	805	844	846	823	793	800	782	738	735	
	Edh at Noon	78	104	127	158	141	135	140	141	117	92	75	69	
All-Sky Solar Radiation	RadAvg	1.31	2.12	3.26	4.38	5.49	5.84	5.91	5.37	3.87	2.57	1.43	1.06	
	RadStd	0.16	0.25	0.34	0.44	0.48	0.49	0.48	0.42	0.38	0.30	0.14	0.12	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (66 neighbors)	+0.61	N/A	N/A	+0.67	N/A	N/A	-132	-180	+78	+25

Nomenclature: See separate page