

ADJUD, Romania

WMO: 152190

Lat: 46.1047N

Lon: 27.1703E

Elev: 336

StdP: 14.52

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 8.2	(c) 12.8	(d) 5.7	(e) 7.5	(f) 10.4	(g) 9.6	(h) 9.1	(i) 16.1	(j) 35.2	(k) 20.6	(l) 27.9	(m) 23.9	(n) 6.5	(o) 320	(p) 0.507

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 22.4	(c) 91.0	(d) 70.2	(e) 88.0	(f) 69.5	(g) 85.5	(h) 69.0	(i) 74.6	(j) 84.2	(k) 72.9	(l) 82.1	(m) 71.4	(n) 80.5	(o) 5.7	(p) 150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
72.3	121.0	77.6	70.3	113.1	75.9	68.7	106.7	74.8	38.4	83.4	36.8	82.4	35.4	80.8	83.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 26.7	(b) 20.6	(c) 17.7	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	51.7	26.6	34.1	41.5	51.2	62.5	70.1	71.8	72.4	64.1	51.4	41.4	32.9		
	DBStd	17.28	8.00	9.03	8.37	7.96	6.06	5.01	4.69	5.39	7.59	7.19	7.85	8.12		
	HDD50	2420	726	448	278	85	4	0	0	0	1	70	276	532		
	HDD65	5582	1191	866	729	417	116	13	6	8	108	424	708	996		
	CDD50	3056	0	2	14	119	393	603	676	694	424	112	19	0		
	CDD65	744	0	0	0	1	40	166	217	238	81	1	0	0		
	CDH74	6996	0	0	4	46	478	1530	1902	2255	759	21	1	0		
	CDH80	2450	0	0	0	3	101	485	682	953	225	1	0	0		
(14) Wind	WSAvg	6.8	7.5	7.3	8.1	8.2	7.0	6.7	6.1	6.4	6.0	5.6	6.1	6.6		
(15) Precipitation	PrecAvg	21.9	0.9	0.8	1.1	1.9	2.7	3.3	2.8	2.1	1.9	2.0	1.2	1.3		
	PrecMax	32.9	2.1	2.8	2.4	3.5	6.4	7.4	7.4	6.5	5.8	8.1	3.3	4.0		
	PrecMin	13.2	0.1	0.1	0.1	0.7	0.6	0.7	0.4	0.6	0.3	0.1	0.1	0.1		
	PrecStd	5.2	0.6	0.6	0.6	0.9	1.5	2.0	1.8	1.4	1.3	1.6	0.8	1.0		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	48.8	61.5	70.6	78.6	87.1	91.5	93.6	94.8	89.1	77.2	67.8	55.2		
		MCWB	43.8	52.3	55.6	63.2	67.0	74.4	71.8	72.8	66.9	63.4	57.1	47.3		
	2%	DB	43.7	54.5	63.3	74.5	82.8	87.7	90.1	91.5	85.3	72.0	61.2	51.0		
		MCWB	40.9	49.2	51.6	59.8	65.2	71.8	70.7	68.8	65.6	60.4	53.7	46.7		
	5%	DB	39.8	49.2	59.0	70.3	79.5	85.3	86.7	88.5	82.3	67.9	56.1	47.4		
		MCWB	37.9	44.7	49.9	58.1	64.5	70.4	70.1	68.9	63.8	58.4	51.6	43.8		
	10%	DB	36.9	45.1	54.7	66.1	76.1	82.7	83.7	85.4	78.4	63.2	52.2	42.7		
		MCWB	35.3	42.8	46.8	55.9	62.7	68.8	69.2	68.5	63.5	56.0	49.2	40.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	44.7	54.0	57.3	65.8	73.6	77.3	76.4	76.2	72.4	68.1	57.9	50.5		
		MCDB	48.1	59.5	68.1	74.2	77.4	85.3	87.1	86.3	79.8	74.6	66.1	52.5		
	2%	WB	41.7	50.0	53.8	62.0	69.0	74.7	73.8	73.8	69.2	63.0	55.0	46.9		
		MCDB	43.6	53.5	61.6	71.2	76.3	84.5	82.9	83.8	77.2	68.2	60.6	51.3		
	5%	WB	38.4	45.9	50.7	59.4	66.8	72.6	72.3	71.9	66.8	60.0	53.0	44.1		
		MCDB	40.0	48.5	57.6	68.8	75.1	82.2	81.2	81.9	76.7	64.9	56.1	47.4		
	10%	WB	35.8	42.9	48.3	56.7	64.6	70.7	70.9	70.5	65.0	57.5	49.8	40.8		
		MCDB	37.0	44.6	53.7	64.9	72.5	80.3	79.6	80.1	74.8	62.4	52.5	42.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	11.3	12.8	17.2	19.6	21.5	21.0	20.7	22.4	21.3	17.8	12.7	10.2		
		MCDBR	14.6	20.5	26.8	28.1	27.0	24.7	25.6	27.5	28.3	25.4	21.0	16.4		
		MCWBR	11.1	14.1	15.8	14.8	12.1	10.5	9.5	9.2	10.7	14.9	13.2	12.2		
	5% WB	MCDBR	14.4	18.8	24.1	25.9	22.3	23.1	21.3	23.0	24.1	22.4	18.7	15.9		
		MCWBR	11.4	14.3	15.2	14.8	13.4	11.8	9.9	9.9	10.3	14.5	12.4	12.3		
(40) Clear-Sky Solar Irradiance	taub		0.328	0.359	0.397	0.458	0.430	0.429	0.449	0.462	0.418	0.382	0.354	0.327		
	taud		2.308	2.240	2.194	2.054	2.215	2.256	2.207	2.162	2.246	2.325	2.350	2.326		
	Ebn at Noon		239	253	260	253	266	267	259	250	251	242	227	225		
	Edh at Noon		25	33	39	49	44	42	44	44	37	30	24	22		
(44) All-Sky Solar Radiation	RadAvg		408	659	1029	1398	1780	1875	1905	1727	1240	801	434	333		
	RadStd		51	80	105	134	152	158	153	126	120	92	40	38		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (57 neighbors)	+1.06	N/A	N/A	N/A	N/A	N/A	N/A	-230	-306	+128	+41

Nomenclature: See separate page