

PALTINIS SIBIU, Romania

WMO: 152540

Lat: 45.6572N

Lon: 23.9325E

Elev: 1454

StdP: 85.03

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-15.3	-13.1	-20.8	0.7	-10.7	-17.6	1.0	-8.1	15.8	1.4	9.3	-3.2	1.2	60	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.8	23.9	16.3	22.2	15.3	20.7	14.6	17.2	21.8	16.3	20.5	15.6	19.6	1.5	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.6	13.2	18.5	14.8	12.5	17.9	14.0	11.9	17.5	54.2	21.6	51.3	20.6	49.1	19.6	19.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	10.4	7.8	5.4	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)				N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	5.8	-3.8	-1.7	-0.4	4.4	9.3	13.2	14.2	15.2	10.8	6.8	3.3	-1.9
	DBStd	7.93	5.34	4.80	4.54	5.59	3.80	3.80	3.22	3.42	4.92	4.85	4.73	4.90
	HDD10.0	2088	429	328	324	181	57	14	4	3	51	124	204	369
	HDD18.3	4593	687	561	582	418	280	157	133	107	230	359	451	627
	CDD10.0	556	0	0	1	12	36	111	134	163	74	23	2	0
	CDD18.3	20	0	0	0	0	0	3	4	9	3	0	0	0
	CDH23.3	74	0	0	0	0	0	10	20	36	9	0	0	0
	CDH26.7	4	0	0	0	0	0	1	1	2	1	0	0	0
Wind	WSAvg	1.4	1.3	1.7	1.7	1.7	1.5	1.1	1.0	1.0	1.3	1.1	1.6	1.6
Precipitation	PrecAvg	801	34	31	42	73	99	115	120	81	74	53	43	43
	PrecMax	1043	76	82	85	139	189	195	210	149	158	125	127	105
	PrecMin	530	9	9	17	17	39	29	40	14	12	0	2	9
	PrecStd	147	17	16	19	31	42	45	48	34	37	29	26	24
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.0	10.5	13.4	19.0	20.6	24.5	25.5	26.1	24.3	19.6	15.5	10.5
		MCWB	3.3	4.2	6.5	10.4	12.6	16.0	16.4	17.1	15.3	10.9	7.7	2.7
	2%	DB	5.9	8.1	9.9	16.3	18.6	22.6	23.3	24.1	21.5	17.4	12.6	7.4
		MCWB	2.1	3.9	4.3	9.3	12.0	15.4	16.3	16.3	13.8	10.5	6.7	2.7
	5%	DB	4.1	6.1	7.8	13.9	16.9	20.9	21.0	22.0	19.2	15.1	10.7	5.5
		MCWB	1.1	2.3	3.2	7.9	11.3	14.9	15.3	15.5	12.9	9.5	6.0	2.2
	10%	DB	2.7	4.3	5.7	11.7	15.1	19.2	19.2	20.4	17.3	12.9	9.2	3.9
		MCWB	0.5	1.5	2.2	6.9	10.6	14.3	14.6	14.9	12.5	8.5	5.4	1.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.0	6.2	6.7	11.6	14.2	17.9	18.0	18.4	16.1	12.9	8.6	5.3
		MCDB	6.9	8.8	12.4	17.1	18.9	21.5	22.7	24.1	21.6	16.8	12.2	7.6
	2%	WB	2.8	4.2	5.1	9.9	12.7	16.6	17.0	17.3	14.7	11.4	7.7	3.7
		MCDB	4.9	7.9	9.6	15.6	16.7	20.8	21.1	22.6	19.9	15.6	10.7	6.3
	5%	WB	1.8	2.9	3.7	8.6	11.8	15.7	16.1	16.2	13.6	10.3	7.1	2.7
		MCDB	3.8	5.4	7.2	13.3	15.9	20.0	19.6	20.7	17.9	14.2	9.7	4.8
	10%	WB	0.8	1.8	2.6	7.4	10.9	14.8	15.4	15.5	12.8	9.3	6.1	1.8
		MCDB	2.4	4.1	5.2	11.1	14.5	18.8	18.7	19.7	16.6	12.6	8.5	3.7
Mean Daily Temperature Range	5% DB	MDBR	6.4	6.9	6.9	7.4	7.2	7.8	8.0	7.8	6.8	7.1	6.1	5.9
		MCDBR	8.1	8.7	9.5	10.0	9.2	9.8	9.8	9.5	8.9	9.3	7.8	7.7
		MCWBR	5.4	5.7	5.9	6.1	5.5	5.7	6.2	5.7	5.6	6.1	5.1	4.9
	5% WB	MCDBR	7.1	7.5	8.5	9.7	8.6	9.3	8.7	8.7	8.3	8.6	6.7	6.7
		MCWBR	5.0	4.9	5.5	6.0	5.6	5.9	5.9	5.7	5.3	5.9	4.5	4.7
Clear-Sky Solar Irradiance	taub	0.264	0.288	0.323	0.372	0.361	0.359	0.373	0.382	0.345	0.314	0.292	0.266	
	taud	2.409	2.359	2.348	2.265	2.344	2.371	2.329	2.300	2.391	2.484	2.496	2.447	
	Ebn at Noon	857	895	907	885	906	907	888	865	871	857	817	816	
	Edh at Noon	70	90	106	127	121	118	122	121	101	80	65	61	
All-Sky Solar Radiation	RadAvg	1.34	2.15	3.23	4.31	5.17	5.72	5.70	5.19	3.74	2.61	1.53	1.09	
	RadStd	0.16	0.27	0.41	0.47	0.49	0.53	0.49	0.48	0.39	0.31	0.18	0.14	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (77 neighbors)	+0.67	N/A	N/A	+0.90	N/A	N/A	-123	-183	+92	+36

Nomenclature: See separate page