

INTORSURA BUZAUULI, Romania

WMO: 152610

Lat: 45.6683N

Lon: 26.0567E

Elev: 2323

StdP: 13.50

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-6.8	1.9	-9.0	3.7	-6.0	-1.3	5.6	3.1	31.8	30.3	27.5	30.4	0.4	0	0.550

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.2	82.8	67.2	80.3	66.0	77.7	64.7	69.9	78.0	68.0	76.5	66.4	74.9	6.0	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.4	109.8	73.5	65.2	101.6	71.9	63.4	95.4	70.1	35.4	78.6	33.8	76.8	32.4	74.8	80.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.9	17.2	14.3	DB	-16.5	86.7	8.0	2.7	-22.2	88.7	-26.9	90.2	-31.4	91.8	-37.2	93.7
			WB	-16.7	73.6	8.0	3.1	-22.4	75.8	-27.1	77.6	-31.6	79.3	-37.4	81.6

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	45.4	25.0	29.8	35.8	45.4	54.2	61.6	63.7	63.1	55.1	46.1	37.1	26.6
	DBStd	15.66	9.94	9.56	8.07	7.51	5.54	4.85	4.45	4.63	6.52	6.75	8.55	10.78
	HDD50	3279	774	567	441	169	26	1	0	0	27	155	394	725
	HDD65	7253	1239	987	904	588	336	120	76	90	299	586	838	1190
	CDD50	1592	0	0	2	32	156	349	426	406	180	35	6	0
	CDD65	87	0	0	0	0	0	18	36	31	2	0	0	0
	CDH74	1532	0	0	0	4	59	314	492	545	115	3	0	0
	CDH80	241	0	0	0	0	4	40	77	108	12	0	0	0
Wind	WSAvg	4.7	4.7	5.1	5.5	5.6	4.9	4.4	4.0	3.4	4.3	4.7	5.2	4.4
Precipitation	PrecAvg	26.5	1.2	1.0	1.3	2.2	3.3	4.1	3.7	3.1	2.2	1.9	1.3	1.3
	PrecMax	36.1	2.4	2.0	2.7	4.6	7.1	6.9	7.8	5.7	4.6	4.0	3.1	2.9
	PrecMin	17.1	0.2	0.1	0.3	0.7	1.2	1.7	1.4	1.0	0.4	0.0	0.0	0.4
	PrecStd	4.6	0.6	0.5	0.6	1.1	1.6	1.6	1.7	1.4	1.1	1.1	0.7	0.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	47.5	59.4	64.9	73.7	79.4	84.2	85.1	86.4	81.7	73.6	64.7	49.9
		MCWB	42.5	48.6	50.3	55.8	61.5	69.2	70.0	67.8	63.2	59.4	53.5	45.4
	2%	DB	42.8	51.7	58.5	69.5	75.1	80.5	82.1	83.0	77.5	69.7	59.0	45.1
		MCWB	39.2	44.4	47.7	55.0	59.7	67.3	68.4	66.0	62.2	57.2	50.5	41.8
	5%	DB	39.4	46.5	53.5	64.9	71.5	77.6	79.6	80.2	73.7	64.8	54.4	41.3
		MCWB	36.8	40.5	44.9	53.0	59.2	65.5	66.9	64.9	60.7	55.4	48.5	38.9
	10%	DB	36.5	42.2	48.8	60.5	68.1	74.9	76.5	76.7	69.8	59.4	50.1	38.2
		MCWB	34.8	38.2	42.3	50.5	57.7	64.4	65.4	64.2	59.4	53.3	46.4	36.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	42.8	48.7	52.0	58.1	65.8	72.0	73.5	70.9	65.6	63.1	54.6	46.3
		MCDB	46.7	57.4	62.9	69.4	75.7	79.6	80.9	79.2	77.8	68.7	62.2	48.9
	2%	WB	39.8	44.4	48.3	56.0	62.3	69.3	70.2	68.8	63.5	58.9	52.0	41.6
		MCDB	42.2	50.7	57.3	66.4	70.1	76.9	78.5	77.2	73.8	66.5	58.1	44.5
	5%	WB	37.0	41.4	45.6	54.0	60.5	67.4	68.0	67.0	61.8	56.2	49.2	39.1
		MCDB	38.8	45.6	52.6	63.1	68.6	74.9	77.2	76.0	71.3	63.2	53.8	41.2
	10%	WB	35.1	38.9	43.0	51.6	58.6	65.6	66.2	65.3	60.0	53.5	46.5	36.9
		MCDB	36.3	41.9	47.8	58.8	66.6	73.1	74.3	74.5	68.2	58.4	50.0	38.4
Mean Daily Temperature Range	5% DB	MDBR	15.8	18.4	18.2	20.6	21.8	21.9	21.2	24.2	21.9	21.0	16.4	14.1
		MCDBR	16.9	24.7	28.1	31.5	30.3	28.0	28.4	31.7	31.3	33.7	26.5	17.6
		MCWBR	12.6	17.1	17.3	17.6	16.5	15.5	14.9	15.7	16.6	21.5	17.7	13.4
	5% WB	MCDBR	14.6	23.2	26.2	27.9	26.3	25.7	25.4	26.1	28.1	29.3	24.7	15.6
		MCWBR	11.7	16.2	16.9	16.6	15.8	16.3	14.8	14.8	15.6	19.5	16.9	12.1
Clear-Sky Solar Irradiance	taub	0.299	0.328	0.369	0.428	0.406	0.406	0.422	0.435	0.391	0.355	0.328	0.300	
	taud	2.347	2.268	2.233	2.112	2.246	2.279	2.240	2.198	2.292	2.385	2.410	2.380	
	Ebn at Noon	254	266	270	263	273	273	267	258	260	254	241	241	
	Edh at Noon	24	32	38	47	43	41	43	43	36	28	23	21	
All-Sky Solar Radiation	RadAvg	423	682	1036	1387	1725	1843	1872	1697	1233	824	464	347	
	RadStd	48	82	108	145	154	154	151	130	117	98	46	42	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (70 neighbors)	+1.03	N/A	N/A	+1.15	N/A	N/A	-218	-297	+126	+41

Nomenclature: See separate page