

LACAUTI, Romania

WMO: 152620

Lat: 45.8239N

Lon: 26.3756E

Elev: 1778

StdP: 81.71

Time Zone: 2.00 (EUE)

Period: 90-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -18.7	(c) -16.8	(d) -25.9	(e) 0.4	(f) -7.6	(g) -21.8	(h) 0.7	(i) -11.6	(j) 28.0	(k) -9.9	(l) 24.2	(m) -9.6	(n) 8.5	(o) 290	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 5.9	(c) 20.2	(d) 14.0	(e) 18.5	(f) 13.0	(g) 17.1	(h) 12.3	(i) 15.4	(j) 18.7	(k) 14.3	(l) 17.1	(m) 13.5	(n) 16.1	(o) 3.8	(p) 230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.2	12.6	16.3	13.3	11.8	15.3	12.4	11.1	14.6	49.8	18.7	46.4	17.2	43.9	16.3	19.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 20.0	(b) 16.5	(c) 13.8	(d) DB	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A	(q) N/A
(a) 20.0	(b) 16.5	(c) 13.8	(d) WB	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A	(q) N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	2.5	-7.5	-5.6	-3.8	0.8	6.4	10.5	11.7	12.0	7.2	3.6	-0.4	-5.9
	DBStd	8.34	5.28	5.20	5.03	5.49	3.81	3.58	3.34	3.63	4.99	5.44	5.23	5.01
	HDD10.0	3013	543	437	428	277	123	37	21	23	112	209	311	493
	HDD18.3	5797	802	670	686	525	371	237	205	197	334	458	561	752
	CDD10.0	262	0	0	0	2	11	52	74	86	28	9	0	0
	CDD18.3	2	0	0	0	0	0	1	1	1	0	0	0	0
	CDH23.3	3	0	0	0	0	0	2	1	1	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
	WSAvg	6.4	7.8	7.7	7.1	6.3	5.5	5.2	5.3	4.5	6.1	6.4	6.9	7.9
(15) Precipitation	PrecAvg	669	29	26	36	56	85	102	95	82	53	44	29	32
	PrecMax	955	67	57	71	99	175	178	185	176	137	104	59	61
	PrecMin	413	6	4	5	16	37	33	30	28	10	2	1	7
	PrecStd	120	15	13	16	24	40	45	43	38	28	25	15	15
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	4.2	6.9	10.2	14.6	18.1	22.1	22.4	22.1	21.0	17.3	11.9	6.7
		MCWB	-0.8	3.3	4.1	7.9	10.5	13.8	15.7	15.2	14.7	7.8	5.7	0.0
	2%	DB	1.7	4.8	7.7	12.0	15.1	18.8	19.9	19.8	17.6	14.8	9.8	3.0
		MCWB	-0.8	2.1	2.9	6.3	9.5	13.1	14.1	14.0	12.3	7.8	3.4	0.7
	5%	DB	0.4	2.1	5.3	10.0	13.4	17.1	18.0	18.0	15.5	12.7	8.1	1.5
		MCWB	-1.1	-0.4	1.7	5.3	9.0	12.5	13.0	13.1	11.1	6.6	3.1	0.0
	10%	DB	-1.0	0.7	2.8	7.8	11.7	15.5	16.4	16.5	13.8	10.8	6.5	0.2
		MCWB	-2.3	-0.9	0.5	4.3	8.0	11.8	12.4	12.4	10.1	6.4	3.1	-0.9
	0.4%	WB	1.1	4.6	5.1	8.6	11.7	16.2	16.8	16.2	15.7	10.8	7.9	2.4
		MCDB	2.3	6.4	9.7	13.4	14.9	19.2	20.0	19.7	19.4	15.3	10.5	3.4
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	0.3	2.5	3.6	7.3	10.4	14.4	15.4	15.1	13.8	9.3	5.9	1.3
		MCDB	1.2	4.6	7.0	10.9	13.3	17.1	18.4	18.8	16.6	12.2	7.7	2.5
	5%	WB	-0.8	0.6	2.3	6.2	9.4	13.3	14.1	14.1	11.6	8.2	4.9	0.4
		MCDB	0.1	1.8	4.7	9.3	12.4	16.1	16.8	16.9	14.8	11.5	6.9	1.5
	10%	WB	-2.0	-0.5	0.8	5.0	8.5	12.4	13.3	13.3	10.6	7.0	3.7	-0.8
		MCDB	-1.2	0.5	2.8	7.7	11.2	14.9	15.6	15.9	13.3	10.0	5.3	0.2
	5% DB	MDBR	4.9	5.1	5.6	6.0	5.8	6.5	6.3	5.9	5.4	5.6	4.7	4.5
		MCDBR	5.1	6.3	8.5	8.7	7.7	8.4	8.2	7.3	7.4	7.4	6.4	5.3
		MCWBR	3.8	4.5	5.1	5.3	4.8	5.1	5.5	4.5	5.0	4.9	4.1	4.1
		MCDBR	4.6	5.2	6.8	7.7	7.3	7.3	7.4	7.0	6.7	7.2	5.4	4.5
(38) Mean Daily Temperature Range	5% WB	MCWBR	3.8	4.2	4.8	5.1	4.8	5.0	5.4	4.7	5.1	5.0	4.2	3.9
(40) Clear-Sky Solar Irradiance	taub		0.253	0.276	0.307	0.352	0.336	0.336	0.348	0.357	0.325	0.298	0.278	0.254
	taud		2.437	2.391	2.396	2.312	2.402	2.414	2.375	2.347	2.427	2.505	2.522	2.467
	Ebn at Noon		874	913	926	906	930	928	911	890	894	876	838	835
	Edh at Noon		68	87	101	120	114	113	116	115	97	77	63	59
(44) All-Sky Solar Radiation	RadAvg		1.30	2.11	3.26	4.41	5.57	5.90	5.99	5.43	3.92	2.56	1.41	1.07
	RadStd		0.16	0.25	0.34	0.44	0.47	0.48	0.47	0.40	0.37	0.30	0.14	0.13

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (66 neighbors)		+0.60	N/A	N/A	+0.64	N/A	N/A	-128	-172	+75	+24

Nomenclature: See separate page