

FOCSANI, Romania

WMO: 152640

Lat: 45.6875N

Lon: 27.1997E

Elev: 191

StdP: 14.59

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.8	14.8	5.4	7.3	14.3	9.6	9.0	17.8	32.0	24.7	26.5	26.1	3.9	320	0.450

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.5	92.9	70.2	89.9	69.5	87.2	68.6	73.4	87.6	71.9	85.6	70.5	83.2	5.3	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.0	107.3	78.3	67.5	101.8	77.2	66.2	97.3	75.9	37.0	86.9	35.7	85.3	34.5	83.6	84.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 22.0	18.2	14.7	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	53.3	27.7	35.5	43.4	52.6	64.1	71.8	73.7	73.9	64.9	53.1	44.2	33.5
	DBStd	17.30	7.72	8.94	8.36	7.61	5.81	5.20	4.56	5.71	7.54	7.38	7.39	7.62
	HDD50	2163	691	409	229	61	1	0	0	0	1	54	205	512
	HDD65	5194	1156	827	668	374	84	8	1	5	99	372	624	976
	CDD50	3366	0	3	26	140	440	653	736	742	446	149	31	0
	CDD65	921	0	0	0	3	57	211	272	282	94	2	0	0
	CDH74	8756	0	0	8	70	620	1937	2500	2723	863	34	1	0
	CDH80	3332	0	0	0	7	141	699	989	1204	291	1	0	0
(14) Wind	WSAvg	5.1	5.3	5.5	6.5	6.1	5.2	5.4	4.7	5.0	4.2	4.2	4.3	4.7
(15) Precipitation	PrecAvg	22.6	1.1	1.0	1.3	1.8	2.7	3.0	2.6	2.0	2.0	2.0	1.4	1.5
	PrecMax	31.6	2.8	3.0	2.9	3.9	6.3	5.9	6.8	5.5	5.2	7.2	4.2	4.3
	PrecMin	14.0	0.1	0.2	0.0	0.8	0.4	0.4	0.3	0.4	0.5	0.1	0.0	0.1
	PrecStd	5.1	0.8	0.8	0.7	0.9	1.6	1.4	1.5	1.4	1.2	1.6	1.0	1.3
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.1	64.9	74.1	80.1	88.2	94.1	95.9	96.2	90.6	78.2	69.9	56.5
		MCWB	43.1	51.0	55.0	62.0	65.6	72.3	72.5	70.8	65.9	63.0	58.1	48.5
	2%	DB	43.9	57.0	66.0	75.7	84.0	90.1	91.8	93.3	86.8	73.5	64.5	51.6
		MCWB	39.8	48.7	51.8	60.1	64.3	71.5	70.5	69.3	65.9	61.2	55.1	46.7
	5%	DB	40.5	51.5	61.2	71.1	80.7	87.2	88.7	90.2	83.2	69.3	59.0	47.3
		MCWB	37.9	44.9	50.0	57.2	63.7	69.7	69.8	68.9	64.4	58.6	52.4	43.7
	10%	DB	37.9	47.1	56.8	67.1	77.5	84.2	85.6	86.9	78.6	65.0	54.7	43.2
		MCWB	35.7	43.0	47.4	55.0	61.8	68.4	69.5	68.1	64.4	57.1	50.5	40.0
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	44.0	54.5	56.5	63.8	69.6	75.4	74.8	74.7	70.9	65.9	58.6	50.7
		MCDB	48.5	62.0	67.8	76.8	81.4	87.3	90.8	91.5	84.0	75.0	68.2	53.8
	2%	WB	41.1	49.0	53.1	60.9	67.1	73.2	73.0	72.7	68.2	62.9	56.1	47.5
		MCDB	43.6	56.0	64.6	73.1	79.4	86.5	86.9	87.6	79.9	70.0	63.6	51.5
	5%	WB	38.3	45.7	50.8	58.5	65.1	71.6	71.7	70.9	66.5	60.4	53.5	44.0
		MCDB	40.4	50.2	60.4	69.3	76.3	85.4	84.8	84.5	78.7	66.9	57.7	47.3
	10%	WB	36.0	43.3	48.2	56.1	63.4	70.0	70.2	69.6	64.9	58.1	50.8	40.4
		MCDB	37.6	46.4	54.7	64.9	74.1	81.9	81.9	82.4	77.4	63.6	54.4	42.8
(35) Mean Daily Temperature Range	5% DB	MDBR	11.6	13.7	17.1	19.6	21.0	20.1	20.5	20.9	20.6	17.3	13.4	11.3
		MCDBR	15.5	23.5	27.5	28.7	26.6	24.7	26.2	26.2	27.5	25.3	22.8	18.2
	5% WB	MCWBR	10.9	15.1	15.2	15.4	11.3	9.6	9.2	8.4	10.3	13.4	13.2	13.0
		MCWBR	13.7	21.5	25.6	27.7	23.4	22.8	22.7	23.4	24.7	22.4	19.3	18.2
(40) Clear-Sky Solar Irradiance	taub		0.329	0.360	0.396	0.456	0.429	0.429	0.446	0.461	0.418	0.383	0.356	0.330
		taud	2.328	2.251	2.207	2.063	2.221	2.257	2.216	2.167	2.247	2.328	2.354	2.339
	Ebn at Noon		241	254	261	254	267	267	260	251	251	243	228	226
		Edn at Noon	25	33	39	49	43	42	43	44	37	30	24	23
(44) All-Sky Solar Radiation	RadAvg		410	667	1033	1409	1780	1883	1917	1735	1256	816	446	342
	RadStd		50	79	107	142	147	148	146	122	115	93	42	41

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (58 neighbors)	+1.01	N/A	N/A	N/A	N/A	N/A	N/A	-207	-279	+130	+52

Nomenclature: See separate page