

BOITA, Romania

WMO: 152770

Lat: 45.6531N

Lon: 24.2717E

Elev: 519

StdP: 95.24

Time Zone: 2.00 (EUE)

Period: 86-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.9	-9.9	-16.0	1.0	-11.5	-12.9	1.3	-8.7	28.0	2.1	24.0	1.7	1.5	340	0.535

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.8	29.9	20.5	28.5	19.9	27.0	19.4	21.9	27.8	21.0	27.1	20.2	25.6	2.8	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
20.0	15.7	24.7	19.0	14.7	23.8	18.2	14.0	23.0	66.6	28.0	63.4	27.2	60.5	25.7	26.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.4	13.9	9.9	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.3	-1.4	1.9	5.4	10.3	15.2	18.9	20.1	20.8	15.5	10.6	5.4	0.2
	DBStd	8.67	4.77	4.62	4.77	5.20	3.38	3.17	2.76	3.12	4.01	4.21	5.04	4.34
	HDD10.0	1306	354	228	156	59	4	0	0	0	3	46	153	303
	HDD18.3	3171	613	460	400	241	105	31	14	14	103	241	388	562
	CDD10.0	1415	0	1	14	69	167	268	314	334	167	64	15	0
	CDD18.3	237	0	0	0	1	9	49	70	90	17	1	0	0
	CDH23.3	1652	0	0	1	17	68	336	468	641	119	3	0	0
	CDH26.7	392	0	0	0	1	7	68	107	185	24	0	0	0
Wind	WSAvg	3.2	3.4	3.6	3.5	3.7	3.2	2.7	2.6	2.9	2.9	3.1	3.8	3.0
Precipitation	PrecAvg	849	45	41	49	72	95	110	117	85	74	62	52	48
	PrecMax	1273	91	84	91	166	208	211	206	165	166	133	137	93
	PrecMin	536	9	6	15	15	41	9	20	16	8	1	2	8
	PrecStd	184	22	20	21	34	46	53	49	45	38	35	32	24
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.7	14.8	21.2	25.0	27.7	30.5	31.3	32.1	29.2	23.5	18.5	12.6
		MCWB	6.8	8.9	12.4	16.3	17.5	20.7	21.7	20.8	18.8	14.7	12.8	8.7
	2%	DB	7.6	11.9	17.8	23.2	25.2	28.6	29.3	30.1	26.4	21.5	16.1	9.8
		MCWB	5.0	7.0	10.4	14.3	17.7	20.1	20.6	20.5	17.9	13.6	11.2	6.8
	5%	DB	5.9	10.0	14.8	20.7	23.2	26.9	27.5	28.8	24.1	19.3	14.2	7.8
		MCWB	3.9	6.3	8.9	12.9	16.8	19.2	20.2	20.1	16.9	13.0	10.4	5.3
	10%	DB	4.3	8.2	12.2	18.0	21.5	25.1	25.9	27.1	21.8	16.9	12.4	5.9
		MCWB	2.5	5.1	7.3	11.7	16.1	18.3	19.5	19.9	16.0	12.2	9.3	4.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.0	8.7	13.5	19.1	23.3	22.5	22.9	22.7	20.5	16.7	13.9	9.9
		MCDB	10.1	12.1	20.6	21.1	23.3	28.4	29.6	29.3	27.5	19.0	17.4	12.6
	2%	WB	5.4	7.5	11.1	15.4	19.4	21.0	21.6	21.7	18.8	14.8	12.2	7.3
		MCDB	7.2	10.4	16.9	21.7	22.1	27.5	27.5	28.5	24.7	19.7	15.5	9.7
	5%	WB	3.9	6.4	9.5	13.8	17.6	19.9	20.8	20.9	17.7	13.7	11.0	5.7
		MCDB	5.4	9.3	14.7	20.0	22.6	25.7	26.5	27.6	23.2	18.1	14.5	7.7
	10%	WB	2.7	5.2	8.1	12.3	16.3	19.0	20.0	20.1	16.7	12.8	9.7	4.5
		MCDB	3.9	7.6	11.9	17.7	21.2	24.3	24.6	26.0	21.3	16.6	12.5	6.0
Mean Daily Temperature Range	5% DB	MDBR	6.1	7.3	9.0	9.8	9.8	10.3	10.3	10.8	9.5	9.2	6.7	5.2
		MCDBR	7.1	8.9	12.9	13.3	12.5	12.6	12.1	13.0	12.4	13.1	8.9	7.9
		MCWBR	4.8	5.5	7.5	6.5	6.4	5.9	5.9	5.6	5.4	6.6	4.9	5.0
	5% WB	MCDBR	6.1	8.7	12.8	11.9	11.8	11.4	11.0	11.8	11.2	11.2	8.3	7.3
		MCWBR	4.5	5.3	7.4	6.4	7.6	5.8	5.6	5.7	5.3	6.4	4.9	4.8
Clear-Sky Solar Irradiance	taub	0.300	0.328	0.368	0.425	0.410	0.409	0.426	0.438	0.393	0.356	0.331	0.302	
	taud	2.354	2.292	2.260	2.146	2.255	2.290	2.249	2.212	2.311	2.411	2.426	2.393	
	Ebn at Noon	800	841	854	832	859	859	839	811	819	803	759	758	
	Edh at Noon	75	98	117	143	133	129	133	132	110	87	71	66	
All-Sky Solar Radiation	RadAvg	1.36	2.18	3.26	4.29	5.20	5.68	5.71	5.19	3.77	2.62	1.53	1.11	
	RadStd	0.15	0.27	0.37	0.47	0.50	0.52	0.49	0.46	0.38	0.33	0.17	0.13	

Historical Trends

		Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47) Regional (79 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		+0.64	N/A	N/A	+0.81	N/A	N/A	-128	-180	+82	+25

Nomenclature: See separate page