

RESITA, Romania

WMO: 153140

Lat: 45.3144N

Lon: 21.8869E

Elev: 281

StdP: 98.00

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-10.0	-7.6	-11.9	1.4	-8.5	-9.9	1.7	-5.4	9.5	4.6	7.3	4.5	0.8	170	0.447

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	12.0	32.6	20.7	30.8	20.6	29.1	20.2	22.4	28.9	21.6	28.0	20.9	27.5	2.8	30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
20.5	15.7	25.0	19.7	14.9	24.2	19.0	14.2	23.4	67.1	28.7	64.3	28.0	61.8	27.6	25.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.5	6.8	5.2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	11.6	0.3	3.8	6.6	11.5	16.1	19.7	21.0	21.5	16.7	11.6	7.5	2.3		
	DBStd	8.27	4.87	4.55	4.34	4.81	3.39	3.15	2.87	3.10	4.22	4.18	4.74	4.44		
	HDD10.0	1024	302	179	121	41	2	0	0	0	1	33	103	241		
	HDD18.3	2773	559	408	363	209	84	22	9	8	79	211	324	497		
	CDD10.0	1600	1	5	17	84	190	289	341	357	202	83	29	2		
	CDD18.3	309	0	0	0	2	14	62	92	107	31	2	0	0		
	CDH23.3	3179	0	0	1	40	153	612	941	1091	307	34	0	0		
	CDH26.7	1059	0	0	0	1	17	166	336	450	89	2	0	0		
(14) Wind	WSAvg	1.6	1.1	1.7	1.8	2.0	1.8	1.7	1.7	1.5	1.5	1.4	1.7	1.4		
(15) Precipitation	PrecAvg	826	52	46	47	72	83	103	97	66	82	65	55	61		
	PrecMax	1076	102	136	127	118	194	242	228	135	213	138	133	153		
	PrecMin	524	13	4	12	17	34	17	18	7	13	3	1	10		
	PrecStd	155	25	28	28	27	37	52	53	35	45	36	31	34		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.2	17.0	21.6	26.1	28.2	32.0	34.6	35.4	32.2	26.5	20.9	15.5		
		MCWB	8.9	10.1	12.4	15.6	18.8	21.6	20.4	20.4	19.3	16.3	12.9	9.8		
	2%	DB	11.4	15.2	18.9	24.4	26.8	30.3	32.2	33.0	29.2	24.0	18.7	12.8		
		MCWB	7.3	9.4	10.7	14.7	18.1	21.6	20.6	20.7	18.5	15.3	12.6	8.7		
	5%	DB	9.4	13.2	16.5	22.3	25.1	28.7	30.1	31.1	26.9	21.9	17.1	10.9		
		MCWB	6.3	7.9	9.6	13.4	17.1	20.6	20.6	20.3	17.8	14.9	11.9	7.4		
	10%	DB	7.1	11.2	14.2	20.1	23.3	27.1	28.1	29.1	24.7	19.2	15.1	8.4		
		MCWB	4.8	6.8	8.5	12.4	16.3	20.0	19.9	20.3	17.5	13.9	11.0	6.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.5	11.2	12.9	17.2	20.2	24.0	23.0	23.2	20.6	18.0	13.7	11.3		
		MCDB	13.6	15.7	21.5	24.4	26.7	30.0	29.1	30.9	29.1	23.5	19.1	13.3		
	2%	WB	8.2	9.8	11.3	15.5	19.0	22.5	22.0	22.3	19.7	16.5	13.0	9.1		
		MCDB	11.0	13.8	17.7	22.7	25.3	28.2	28.0	29.2	27.3	21.6	17.7	13.2		
	5%	WB	6.5	8.5	10.2	14.2	18.0	21.5	21.3	21.5	18.8	15.5	12.3	7.6		
		MCDB	8.9	12.5	15.7	21.0	23.6	27.4	27.8	28.1	24.5	20.6	16.5	10.6		
	10%	WB	4.9	7.4	8.9	13.1	16.9	20.6	20.6	20.8	18.1	14.3	11.4	6.4		
		MCDB	7.1	10.9	13.6	18.4	22.0	26.1	27.1	27.4	23.1	18.8	14.9	8.5		
(35) Mean Daily Temperature Range	5% DB	MDBR	6.8	8.3	9.5	10.5	10.5	11.0	11.8	12.0	10.2	10.6	8.4	6.3		
		MCDBR	10.4	11.3	13.4	14.3	13.9	13.4	15.0	16.0	14.3	15.3	10.6	9.8		
	5% WB	MCWBR	6.0	6.3	6.9	6.7	6.4	6.1	5.6	5.3	5.5	7.5	5.7	6.2		
		MCWBR	9.1	9.9	11.7	13.0	13.0	12.4	12.9	13.4	12.1	13.6	10.0	9.5		
(40) Clear-Sky Solar Irradiance	taub		0.328	0.356	0.395	0.450	0.437	0.429	0.440	0.454	0.422	0.382	0.350	0.327		
	taud		2.334	2.251	2.213	2.076	2.173	2.237	2.207	2.167	2.225	2.331	2.371	2.364		
	Ebn at Noon		766	809	827	809	835	842	826	797	789	772	733	725		
	Edh at Noon		79	103	123	154	144	136	138	139	121	95	76	70		
(44) All-Sky Solar Radiation	RadAvg		1.24	2.07	3.27	4.51	5.44	6.06	6.04	5.42	3.81	2.61	1.56	1.02		
	RadStd		0.15	0.27	0.43	0.47	0.50	0.55	0.47	0.52	0.40	0.29	0.16	0.14		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (69 neighbors)	+0.67	N/A	N/A	N/A	N/A	N/A	-110	-174	+119	+63

Nomenclature: See separate page