

TARGU LOGRESTI, Romania

WMO: 153690

Lat: 44.8781N

Lon: 23.7086E

Elev: 263

StdP: 98.20

Time Zone: 2.00 (EUE)

Period: 86-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-13.8	-10.4	-15.3	1.0	-13.5	-12.2	1.4	-8.9	7.0	7.3	5.7	5.3	0.5	40	0.443

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.7	32.1	21.1	30.7	20.7	29.3	20.5	23.1	29.3	22.1	28.2	21.3	27.3	1.7	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.2	16.3	25.6	20.2	15.4	24.8	19.3	14.6	24.0	69.7	29.5	66.1	28.3	63.2	27.5	26.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	5.5	4.3	3.4	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)				N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.7	-1.4	2.0	5.6	10.9	15.9	19.9	21.0	21.3	16.1	10.5	5.3	1.0
	DBStd	8.60	4.62	4.27	4.23	3.73	2.68	2.64	2.57	2.67	3.69	3.60	4.05	3.93
	HDD10.0	1222	353	224	144	33	1	0	0	0	1	38	147	279
	HDD18.3	3051	612	457	394	223	81	14	7	7	85	243	390	537
	CDD10.0	1486	0	1	8	61	185	296	341	349	185	54	7	0
	CDD18.3	273	0	0	0	0	7	61	89	98	19	0	0	0
	CDH23.3	3361	0	0	0	35	152	693	1042	1128	287	24	0	0
	CDH26.7	1096	0	0	0	2	14	193	358	454	74	1	0	0
Wind	WSAvg	1.0	0.7	1.0	1.1	1.3	1.2	1.3	1.2	1.1	1.0	0.9	0.7	0.8
Precipitation	PrecAvg	691	41	35	38	58	74	81	86	58	56	57	47	54
	PrecMax	1135	92	80	100	138	197	153	217	147	111	144	111	138
	PrecMin	377	6	4	1	10	26	18	20	5	1	0	1	1
	PrecStd	165	25	22	26	28	37	39	51	37	33	34	28	41
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.8	16.7	22.3	26.4	28.3	32.3	33.7	34.4	31.0	25.9	19.0	14.6
		MCWB	7.4	9.7	13.1	15.8	18.6	21.7	21.9	21.3	19.0	16.4	12.0	8.0
	2%	DB	9.8	13.6	19.5	24.1	26.6	30.4	31.9	32.4	28.7	23.3	16.3	11.5
		MCWB	6.2	8.4	11.3	15.2	17.9	21.3	21.5	20.6	18.0	15.2	11.6	7.4
	5%	DB	7.3	11.1	16.5	21.3	25.1	28.9	30.2	30.9	26.5	20.5	13.9	9.2
		MCWB	4.5	7.0	9.9	13.1	17.2	21.1	21.2	20.4	17.5	13.8	10.6	6.0
	10%	DB	5.0	8.8	13.9	19.0	23.5	27.3	28.7	29.3	24.2	17.8	11.8	6.9
		MCWB	3.1	5.5	8.2	12.3	16.2	20.0	20.5	20.4	17.1	12.7	9.5	4.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.1	11.0	14.6	16.9	20.3	23.7	24.0	24.2	20.8	17.3	13.5	9.7
		MCDB	12.0	15.7	20.8	24.4	26.0	28.9	29.3	30.0	29.1	24.1	16.8	11.5
	2%	WB	6.5	9.1	12.0	15.6	19.0	22.6	22.8	23.1	19.3	15.7	12.6	7.8
		MCDB	9.2	13.2	18.4	22.8	24.7	28.6	29.2	29.3	25.8	21.6	15.5	10.8
	5%	WB	4.8	7.6	10.2	14.4	17.9	21.6	22.0	22.0	18.3	14.5	11.3	6.5
		MCDB	6.6	10.4	15.6	20.7	23.3	27.5	28.0	27.9	24.3	19.5	13.7	9.0
	10%	WB	3.3	6.1	8.9	12.9	17.0	20.7	21.2	21.0	17.6	13.3	9.9	5.1
		MCDB	4.8	8.2	12.9	17.6	21.9	26.5	27.1	27.1	23.0	17.1	11.7	6.8
Mean Daily Temperature Range	5% DB	MDBR	9.6	10.3	11.7	12.4	12.2	12.8	13.7	14.2	13.3	12.2	8.4	8.8
		MCDBR	13.2	14.6	17.7	17.6	15.5	15.0	16.0	17.3	16.9	18.1	13.2	13.2
		MCWBR	9.5	9.5	9.7	8.9	7.5	7.1	6.9	6.6	7.0	10.1	8.3	8.8
	5% WB	MCDBR	11.6	13.9	15.7	16.5	13.7	13.7	14.4	14.9	14.4	16.7	11.2	12.6
		MCWBR	8.4	9.1	8.9	8.4	7.2	6.8	7.0	6.9	6.3	9.5	7.3	8.7
Clear-Sky Solar Irradiance	taub	0.330	0.364	0.403	0.467	0.445	0.444	0.459	0.480	0.434	0.393	0.364	0.333	
	taud	2.300	2.214	2.175	2.018	2.150	2.195	2.160	2.091	2.184	2.287	2.308	2.324	
	Ebn at Noon	764	801	819	794	829	830	810	775	779	761	715	719	
	Edh at Noon	82	108	128	163	148	142	145	150	126	100	82	74	
All-Sky Solar Radiation	RadAvg	1.39	2.20	3.39	4.58	5.58	6.21	6.19	5.51	3.96	2.63	1.50	1.13	
	RadStd	0.20	0.32	0.42	0.47	0.45	0.51	0.44	0.46	0.36	0.34	0.20	0.16	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (71 neighbors)	+0.57	N/A	N/A	+0.85	N/A	N/A	N/A	-154	+76	+34	

Nomenclature: See separate page