

PITESTI, Romania

WMO: 153730

Lat: 44.8489N

Lon: 24.8661E

Elev: 317

StdP: 97.57

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-10.3	-8.2	-12.9	1.3	-8.5	-10.6	1.6	-5.7	7.5	4.0	5.8	3.1	1.6	330	0.447

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	12.6	32.6	20.3	31.2	19.9	29.8	19.6	21.8	29.2	21.2	28.5	20.5	27.6	2.0	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.7	15.0	24.2	19.0	14.3	23.7	18.2	13.6	22.9	65.3	29.4	62.8	28.6	60.5	27.7	24.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)		
(4) 6.0	4.8	4.1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	11.7	-0.4	3.1	6.1	11.1	16.7	20.9	22.1	22.4	17.4	11.6	6.2	2.3
	DBStd	8.75	4.31	4.58	4.29	4.51	2.98	2.90	2.65	2.93	4.14	3.92	4.32	4.23
	HDD10.0	1091	323	196	132	41	1	0	0	0	1	29	127	241
	HDD18.3	2828	581	427	381	217	67	9	3	5	67	210	363	498
	CDD10.0	1698	0	2	10	75	208	327	376	384	223	79	13	1
	CDD18.3	394	0	0	0	1	14	87	121	131	39	1	0	0
	CDH23.3	3745	0	0	0	36	151	770	1111	1274	377	27	0	0
	CDH26.7	1317	0	0	0	3	21	257	397	526	112	1	0	0
(14) Wind	WSAvg	1.9	1.6	1.9	2.0	2.3	2.2	2.0	2.0	2.1	2.0	1.8	1.7	1.7
(15) Precipitation	PrecAvg	694	39	33	40	63	81	87	84	57	60	56	44	48
	PrecMax	1127	80	76	99	179	171	158	175	151	174	137	110	132
	PrecMin	362	4	4	1	20	18	27	31	13	1	1	0	0
	PrecStd	157	22	19	25	37	38	35	41	34	43	34	29	35
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.7	17.9	21.2	26.8	29.1	34.1	34.1	35.2	32.3	26.0	19.6	15.3
		MCWB	7.4	10.5	11.3	15.6	18.4	20.5	20.8	20.7	19.3	15.8	12.6	8.0
	2%	DB	9.4	14.6	18.3	23.9	26.7	31.5	32.2	32.5	29.6	23.4	16.9	12.1
		MCWB	5.6	8.7	10.2	15.1	17.4	20.6	20.6	19.9	17.8	15.1	11.5	7.4
	5%	DB	7.3	11.9	15.5	21.5	25.0	29.7	30.5	31.3	27.5	20.8	14.4	10.0
		MCWB	4.6	7.2	9.1	13.6	16.8	20.2	20.2	19.5	17.2	13.9	10.7	7.4
	10%	DB	5.2	9.7	13.4	19.1	23.3	27.9	28.9	29.7	25.3	18.3	12.0	7.7
		MCWB	3.4	5.9	7.7	12.4	15.7	19.2	19.8	19.4	16.8	12.9	9.4	5.2
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.2	11.4	12.1	16.6	19.9	22.8	22.7	22.8	20.7	16.5	13.7	9.7
		MCDB	12.0	16.5	20.0	24.3	26.5	30.3	29.5	29.9	29.7	23.7	18.0	11.6
	2%	WB	6.5	9.2	10.6	15.4	18.2	21.6	21.8	21.6	19.0	15.5	12.6	8.4
		MCDB	8.9	13.7	17.1	22.9	24.6	29.2	29.0	29.1	26.0	21.8	16.2	11.7
	5%	WB	5.1	7.8	9.4	14.2	17.4	20.9	21.2	20.7	18.1	14.5	11.2	7.0
		MCDB	6.8	11.4	14.7	20.1	23.4	28.0	28.2	28.2	24.6	19.8	13.7	10.0
	10%	WB	3.7	6.4	8.3	13.1	16.4	20.1	20.5	20.1	17.3	13.4	10.1	5.6
		MCDB	5.2	9.2	12.6	17.8	21.9	26.4	27.1	27.4	23.5	17.2	12.2	7.7
(35) Mean Daily Temperature Range	5% DB	MDBR	7.4	8.5	9.4	10.5	10.9	11.6	11.8	12.6	11.3	10.0	7.5	7.4
		MCDBR	10.9	12.6	14.3	15.2	13.7	14.2	14.1	14.9	14.8	14.7	12.4	11.1
	5% WB	MCWBR	7.1	7.6	7.5	6.9	5.9	5.3	4.8	4.3	5.0	6.9	7.2	7.0
		MCWBR	8.9	12.3	13.0	13.1	12.7	13.0	12.6	13.3	12.4	13.3	10.5	10.7
(40) Clear-Sky Solar Irradiance	taub	taub	0.324	0.355	0.392	0.450	0.428	0.433	0.444	0.463	0.419	0.381	0.356	0.327
		taud	2.327	2.251	2.212	2.064	2.198	2.221	2.197	2.138	2.228	2.325	2.342	2.352
	Ebn at Noon	Ebn at Noon	776	814	832	810	844	839	823	790	795	776	728	731
		Edh at Noon	80	104	124	156	141	138	140	143	121	96	79	72
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.41	2.25	3.42	4.58	5.62	6.15	6.22	5.53	4.02	2.67	1.51	1.15
	RadStd	RadStd	0.19	0.33	0.37	0.47	0.47	0.47	0.45	0.39	0.34	0.34	0.18	0.16

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (73 neighbors)	+0.54	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-150	+74	+33

Nomenclature: See separate page