

TARGOVISTE, Romania

WMO: 153750

Lat: 44.9295N

Lon: 25.4263E

Elev: 298

StdP: 97.80

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.2	-9.4	-14.8	1.1	-11.2	-12.2	1.4	-8.2	11.7	2.4	7.9	3.3	1.9	320	0.468

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.2	32.0	20.6	30.7	20.2	29.3	19.8	22.5	29.0	21.6	27.8	20.9	26.9	2.2	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
20.7	15.9	24.9	19.7	14.9	24.1	18.9	14.2	23.5	67.8	29.0	64.5	27.9	61.8	27.0	26.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.1	5.7	4.7	-16.9	34.6	2.8	2.2	-19.0	36.2	-20.6	37.5	-22.2	38.8	-24.3	40.4		
			-17.1	25.0	2.8	1.5	-19.2	26.1	-20.8	27.0	-22.4	27.9	-24.5	29.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	11.1	-0.6	2.1	5.6	10.9	16.0	20.4	21.5	21.8	17.2	11.3	5.3	1.0
	DBStd	8.83	4.57	4.75	4.31	4.05	3.26	2.67	2.61	2.72	3.95	3.93	4.46	4.57
	HDD10.0	1197	327	222	144	38	2	0	0	0	1	32	152	279
	HDD18.3	2979	586	453	394	224	84	11	6	5	68	220	391	537
	CDD10.0	1597	0	2	8	64	189	311	358	366	216	72	11	0
	CDD18.3	338	0	0	0	1	13	72	105	113	33	2	0	0
	CDH23.3	3446	0	0	0	29	173	686	1005	1145	380	28	0	0
	CDH26.7	1116	0	0	0	2	29	189	335	452	107	2	0	0
Wind	WSAvg	2.1	1.8	2.0	2.3	2.5	2.4	2.2	2.2	2.3	2.0	1.8	1.8	
Precipitation	PrecAvg	682	37	30	38	59	78	92	85	59	60	54	42	46
	PrecMax	1046	71	80	95	161	165	199	201	252	147	103	98	146
	PrecMin	375	2	2	1	20	15	31	27	4	8	0	2	1
	PrecStd	158	20	20	25	36	38	38	47	49	37	30	27	34
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.6	18.9	21.4	26.5	29.5	32.3	33.5	34.5	32.1	26.1	20.2	15.6
		MCWB	8.3	11.1	11.7	15.9	18.8	21.7	21.9	21.3	19.2	17.0	13.1	9.4
	2%	DB	9.7	14.9	18.3	23.5	27.0	30.5	31.5	32.2	29.4	23.4	17.3	12.0
		MCWB	6.0	9.1	10.5	14.7	17.9	20.9	21.3	20.1	18.2	16.0	11.9	7.9
	5%	DB	7.6	12.0	15.9	20.9	25.2	28.8	30.0	31.0	27.5	20.9	14.3	9.5
		MCWB	5.0	7.5	9.3	13.2	17.0	20.0	20.7	19.8	17.9	14.5	10.5	6.9
	10%	DB	5.2	9.2	13.5	18.7	23.3	27.3	28.6	29.4	25.4	18.3	11.7	6.9
		MCWB	3.6	5.9	8.1	12.3	16.1	19.2	20.1	19.6	17.2	13.1	9.0	5.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.6	11.8	12.7	16.7	20.3	23.4	24.1	23.6	21.2	19.2	13.9	10.0
		MCDB	13.2	18.0	20.2	24.7	26.6	29.7	30.7	30.4	27.8	23.9	18.3	12.8
	2%	WB	6.7	9.5	10.9	15.3	18.9	22.1	22.6	22.1	20.1	16.6	12.6	8.6
		MCDB	8.8	14.2	17.2	22.3	25.4	28.3	29.0	28.7	26.3	21.0	16.8	11.5
	5%	WB	5.2	7.8	9.7	14.0	17.7	21.1	21.7	21.2	18.8	15.0	11.0	6.9
		MCDB	7.2	11.7	15.2	19.7	23.7	27.3	27.7	27.5	24.6	20.3	13.6	9.4
	10%	WB	3.7	6.3	8.5	12.8	16.7	20.2	21.0	20.4	17.7	13.8	9.5	5.2
		MCDB	5.1	8.6	12.8	17.5	21.9	25.9	26.6	26.7	23.3	17.5	11.4	6.7
Mean Daily Temperature Range	5% DB	MDBR	8.4	9.5	10.4	11.2	11.4	11.7	12.2	12.7	11.9	10.5	8.3	8.6
		MCDBR	11.5	14.5	15.4	15.9	14.6	14.3	14.6	15.3	15.5	14.9	13.3	12.4
		MCWBR	7.7	9.1	8.7	8.2	6.9	6.4	5.8	5.4	5.8	7.6	7.8	8.0
	5% WB	MCDBR	10.5	13.9	14.3	14.2	13.7	13.3	13.1	13.2	13.5	13.9	11.6	11.7
		MCWBR	7.3	8.9	8.4	7.6	7.1	6.4	6.2	5.7	5.6	7.4	7.0	7.7
Clear-Sky Solar Irradiance	taub	0.327	0.359	0.399	0.457	0.433	0.438	0.450	0.468	0.423	0.386	0.359	0.330	
	taud	2.315	2.229	2.181	2.042	2.182	2.207	2.184	2.124	2.216	2.302	2.326	2.336	
	Ebn at Noon	770	807	824	804	839	835	819	785	790	768	722	724	
	Edh at Noon	81	106	127	159	143	140	142	145	122	98	81	73	
All-Sky Solar Radiation	RadAvg	1.40	2.22	3.39	4.53	5.57	6.04	6.13	5.48	3.99	2.67	1.51	1.14	
	RadStd	0.18	0.32	0.36	0.47	0.48	0.47	0.45	0.38	0.34	0.34	0.18	0.16	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (72 neighbors)	+0.51	N/A	N/A	N/A	N/A	N/A	N/A	-147	+70	+30	

Nomenclature: See separate page