

MOLDOVA VECHE, RomaniaWMO: **153880**Lat: **44.7225N**Lon: **21.6333E**Elev: **273**StdP: **14.55**Time Zone: **2.00 (EUE)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	16.7	20.8	10.8	9.6	20.0	14.4	11.5	24.5	27.7	33.7	24.9	35.5	5.1	320	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	21.3	94.5	69.6	91.1	69.4	87.8	69.2	73.0	86.4	71.7	85.5	70.5	84.1	6.7	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
69.0	107.8	78.9	67.5	102.2	76.8	66.2	97.6	75.2	36.7	86.7	35.5	85.1	34.5	84.5	79.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 23.6	20.5	17.2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	55.0	33.1	39.2	45.4	54.7	63.9	70.5	73.3	74.5	65.4	55.2	46.5	36.8	
	DBStd	15.82	7.77	7.66	7.59	8.83	6.33	5.92	5.85	6.23	7.90	7.84	8.02	6.51	
	HDD50	1676	524	308	179	56	1	0	0	0	0	39	158	411	
	HDD65	4596	988	723	607	320	95	16	6	7	93	313	554	874	
	CDD50	3489	0	5	38	198	432	616	723	758	461	201	55	2	
	CDD65	933	0	0	0	12	61	182	264	300	104	10	0	0	
	CDH74	9297	0	0	2	125	502	1733	2797	3122	935	81	0	0	
	CDH80	3662	0	0	0	10	84	591	1233	1434	303	7	0	0	
Wind	WSAvg	5.6	5.5	6.5	6.1	6.8	5.4	4.7	4.4	5.0	5.2	5.6	7.4	5.2	
Precipitation	PrecAvg	26.1	1.7	1.7	1.6	2.2	2.7	2.9	2.8	2.0	2.4	2.1	1.9	1.9	
	PrecMax	35.8	3.2	3.6	5.0	4.3	6.1	7.4	7.8	5.5	6.9	5.9	6.2	4.5	
	PrecMin	15.3	0.3	0.1	0.4	0.1	0.7	0.6	0.2	0.2	0.5	0.1	0.0	0.3	
	PrecStd	5.4	0.8	1.0	1.1	1.1	1.6	1.7	2.0	1.5	1.5	1.5	1.2	1.1	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.1	63.4	73.2	81.2	86.3	93.4	98.8	99.3	92.0	80.5	67.7	56.3	
		MCWB	46.8	51.4	55.9	62.0	68.1	72.2	70.3	69.5	68.3	62.4	55.7	48.3	
	2%	DB	50.0	57.5	67.6	77.9	82.5	89.6	94.7	94.9	87.0	75.9	63.9	52.1	
		MCWB	44.1	49.3	53.2	61.1	66.4	71.1	69.5	69.3	66.8	60.6	55.0	45.8	
	5%	DB	46.3	53.7	62.5	73.5	79.5	86.4	90.5	91.7	83.2	72.0	61.1	48.9	
		MCWB	41.8	46.8	50.6	57.8	64.4	70.2	69.3	69.2	65.3	59.6	53.5	44.3	
	10%	DB	42.8	51.1	58.5	69.7	76.5	83.1	86.7	87.9	79.6	68.3	58.0	45.0	
		MCWB	39.8	45.1	48.3	56.4	63.5	68.7	68.8	68.8	64.4	57.8	52.1	41.7	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	47.5	53.6	56.9	64.3	69.7	76.3	74.6	74.4	70.3	64.8	57.6	49.3
			MCDB	53.1	63.5	71.8	78.8	84.2	88.5	86.3	89.2	88.8	74.5	65.6	54.5
2%		WB	45.3	50.2	53.9	61.5	67.5	73.2	72.6	72.5	68.5	62.8	56.1	46.9	
		MCDB	49.5	56.3	66.4	74.9	80.3	85.4	86.5	86.9	83.4	72.6	62.8	51.9	
5%		WB	42.5	47.8	51.5	59.5	65.9	71.4	71.2	71.1	66.8	60.7	54.5	44.5	
		MCDB	46.0	52.9	61.3	71.8	77.5	83.1	85.6	85.5	79.4	69.9	60.4	48.6	
10%		WB	40.1	45.5	49.3	57.2	63.9	69.7	70.0	70.0	65.3	58.8	52.7	42.3	
		MCDB	43.0	50.2	57.2	67.6	73.7	81.9	83.6	84.0	76.7	67.7	58.3	44.9	
Mean Daily Temperature Range	5% DB	MDBR	10.4	13.7	16.8	18.4	18.2	20.2	21.9	21.3	18.3	16.2	11.6	10.2	
		MCDBR	16.0	20.2	26.3	25.8	23.1	24.3	27.8	27.7	24.8	24.1	16.2	16.8	
		MCWBR	10.6	13.1	14.0	12.5	10.6	9.9	8.9	8.4	9.0	11.4	9.1	11.6	
	5% WB	MCDBR	15.3	19.2	22.3	23.9	21.2	22.0	23.7	23.3	21.2	23.0	15.1	16.3	
		MCWBR	10.2	12.5	12.3	12.6	10.7	9.7	9.3	8.5	8.3	11.2	8.6	11.7	
Clear-Sky Solar Irradiance	taub		0.354	0.385	0.425	0.488	0.472	0.462	0.471	0.489	0.457	0.412	0.376	0.351	
	taud		2.256	2.151	2.121	1.974	2.080	2.155	2.136	2.080	2.127	2.239	2.288	2.291	
	Ebn at Noon		233	246	252	246	255	258	254	244	240	234	222	220	
	Edh at Noon		28	36	43	54	50	47	47	48	43	33	27	24	
All-Sky Solar Radiation	RadAvg		393	655	1041	1439	1738	1941	1956	1743	1221	823	496	333	
	RadStd		50	87	136	152	174	188	153	171	128	102	53	47	