

MOLDOVA VECHE, RomaniaWMO: **153880**Lat: **44.7225N**Lon: **21.6333E**Elev: **83**StdP: **100.33**Time Zone: **2.00 (EUE)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-8.5	-6.2	-11.8	1.4	-6.6	-9.8	1.6	-4.2	12.4	0.9	11.1	2.0	2.3	320	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.8	34.7	20.9	32.8	20.8	31.0	20.6	22.8	30.2	22.0	29.7	21.4	29.0	3.0	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
20.6	15.4	26.0	19.7	14.6	24.9	19.0	13.9	24.0	67.5	30.4	64.8	29.5	62.3	29.2	26.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.6	9.2	7.7	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	12.8	0.6	4.0	7.5	12.6	17.7	21.4	23.0	23.6	18.5	12.9	8.1	2.7
	DBStd	8.79	4.32	4.26	4.22	4.90	3.52	3.29	3.25	3.46	4.39	4.36	4.45	3.62
	HDD10.0	931	291	171	99	31	1	0	0	0	0	22	88	228
	HDD18.3	2553	549	402	337	178	53	9	3	4	52	174	308	486
	CDD10.0	1938	0	3	21	110	240	342	402	421	256	112	31	1
	CDD18.3	518	0	0	0	7	34	101	147	167	58	6	0	0
	CDH23.3	5165	0	0	1	69	279	963	1554	1734	519	45	0	0
	CDH26.7	2034	0	0	0	6	47	328	685	797	168	4	0	0
Wind	WSAvg	2.5	2.4	2.9	2.7	3.1	2.4	2.1	2.0	2.2	2.3	2.5	3.3	2.3
Precipitation	PrecAvg	664	44	43	41	57	69	74	70	51	62	54	49	49
	PrecMax	909	82	91	126	109	154	188	199	140	176	149	157	115
	PrecMin	388	8	3	9	3	17	14	4	5	13	2	1	7
	PrecStd	137	21	26	27	27	40	43	51	37	37	37	31	27
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.3	17.5	22.9	27.3	30.1	34.1	37.1	37.4	33.3	26.9	19.8	13.5
		MCWB	8.2	10.8	13.3	16.7	20.1	22.3	21.3	20.8	20.2	16.9	13.2	9.1
	2%	DB	10.0	14.2	19.8	25.5	28.1	32.0	34.8	35.0	30.6	24.4	17.7	11.2
		MCWB	6.7	9.6	11.8	16.1	19.1	21.7	20.9	20.7	19.4	15.9	12.8	7.7
	5%	DB	7.9	12.0	17.0	23.1	26.4	30.2	32.5	33.2	28.4	22.2	16.2	9.4
		MCWB	5.5	8.2	10.4	14.3	18.0	21.2	20.7	20.7	18.5	15.3	12.0	6.8
	10%	DB	6.0	10.6	14.7	21.0	24.7	28.4	30.4	31.1	26.4	20.1	14.4	7.2
		MCWB	4.3	7.3	9.1	13.6	17.5	20.4	20.4	20.4	18.0	14.3	11.1	5.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.6	12.0	13.8	18.0	21.0	24.6	23.7	23.6	21.3	18.2	14.2	9.6
		MCDB	11.7	17.5	22.1	26.0	29.0	31.4	30.2	31.8	31.6	23.6	18.7	12.5
	2%	WB	7.4	10.1	12.2	16.4	19.7	22.9	22.5	22.5	20.3	17.1	13.4	8.3
		MCDB	9.7	13.5	19.1	23.8	26.9	29.7	30.3	30.5	28.5	22.6	17.1	11.0
	5%	WB	5.8	8.8	10.8	15.3	18.9	21.9	21.8	21.7	19.3	16.0	12.5	6.9
		MCDB	7.8	11.6	16.3	22.1	25.3	28.4	29.8	29.7	26.3	21.1	15.8	9.2
	10%	WB	4.5	7.5	9.6	14.0	17.7	21.0	21.1	21.1	18.5	14.9	11.5	5.7
		MCDB	6.1	10.1	14.0	19.8	23.2	27.7	28.7	28.9	24.8	19.8	14.6	7.2
Mean Daily Temperature Range	5% DB	MDBR	5.8	7.6	9.3	10.2	10.1	11.2	12.2	11.8	10.2	9.0	6.4	5.7
		MCDBR	8.9	11.2	14.6	14.3	12.8	13.5	15.4	15.4	13.8	13.4	9.0	9.3
		MCWBR	5.9	7.3	7.8	7.0	5.9	5.5	4.9	4.7	5.0	6.4	5.1	6.5
	5% WB	MCDBR	8.5	10.7	12.4	13.3	11.8	12.2	13.2	13.0	11.8	12.8	8.4	9.1
		MCWBR	5.7	6.9	6.8	7.0	5.9	5.4	5.1	4.7	4.6	6.2	4.8	6.5
Clear-Sky Solar Irradiance	taub		0.354	0.385	0.425	0.488	0.472	0.462	0.471	0.489	0.457	0.412	0.376	0.351
	taud		2.256	2.151	2.121	1.974	2.080	2.155	2.136	2.080	2.127	2.239	2.288	2.291
	Ebn at Noon		733	774	796	776	805	814	801	768	756	738	701	695
	Edh at Noon		87	115	136	171	159	148	149	152	134	105	84	77
All-Sky Solar Radiation	RadAvg		1.24	2.06	3.28	4.54	5.48	6.12	6.17	5.50	3.85	2.60	1.56	1.05
	RadStd		0.16	0.28	0.43	0.48	0.55	0.59	0.48	0.54	0.40	0.32	0.17	0.15