

DRAGASANI, Romania

WMO: 153950

Lat: 44.6656N

Lon: 24.2372E

Elev: 923

StdP: 14.21

Time Zone: 2.00 (EUE)

Period: 86-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.5	18.0	10.2	9.6	18.7	13.6	11.4	22.4	21.3	40.3	18.7	38.7	3.9	20	0.453

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	20.7	91.3	69.1	89.0	68.7	86.2	68.1	73.3	84.6	71.4	83.1	69.9	82.0	5.3	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.6	112.4	80.0	67.7	105.2	77.1	66.0	99.1	75.3	37.4	84.7	35.7	83.5	34.4	81.9	81.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
21.3	17.7	14.4	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	54.0	31.1	37.9	44.7	53.3	63.0	70.6	73.5	74.7	65.2	54.2	43.4	35.6
	DBStd	16.50	7.82	8.72	8.97	8.39	5.67	5.35	5.09	5.71	7.20	7.96	8.26	7.49
	HDD50	1933	587	344	210	62	1	0	0	0	0	50	230	449
	HDD65	4909	1052	758	629	356	103	13	3	6	87	340	649	913
	CDD50	3401	0	6	46	163	406	618	727	766	456	180	31	2
	CDD65	901	0	0	0	6	42	181	265	308	93	6	0	0
	CDH74	7786	0	0	2	54	293	1472	2361	2847	710	47	0	0
	CDH80	2748	0	0	0	3	33	452	868	1191	199	2	0	0
Wind	WSAvg	5.5	4.6	6.0	6.4	7.1	6.4	5.4	5.0	4.8	5.6	4.8	4.7	5.0
Precipitation	PrecAvg	24.3	1.5	1.2	1.5	2.1	2.8	2.8	2.9	1.9	2.2	2.0	1.6	1.8
	PrecMax	44.4	2.9	2.5	4.5	5.8	6.3	5.5	7.9	5.3	5.1	4.9	4.3	5.6
	PrecMin	12.8	0.2	0.2	0.2	0.6	0.6	0.6	0.7	0.0	0.1	0.0	0.0	0.0
	PrecStd	6.5	0.8	0.7	1.1	1.1	1.4	1.3	1.8	1.2	1.5	1.2	1.0	1.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.9	64.0	72.6	79.5	83.7	91.8	93.5	95.1	89.4	79.0	66.4	57.5
		MCWB	46.3	51.0	56.5	60.7	64.0	70.0	71.7	70.0	67.5	61.0	56.5	50.4
	2%	DB	48.4	57.8	67.0	74.7	79.9	88.2	90.7	91.9	85.3	74.3	61.8	52.8
		MCWB	42.9	48.3	52.8	59.7	63.7	69.3	69.8	68.9	64.4	59.3	53.7	46.5
	5%	DB	44.7	53.7	62.5	70.5	77.3	85.0	88.0	89.6	81.3	70.6	57.8	49.1
		MCWB	40.4	45.4	50.8	56.8	62.8	68.8	69.1	68.5	63.8	57.7	51.8	44.7
	10%	DB	41.6	49.9	58.3	66.6	74.4	81.9	85.0	86.7	77.5	66.4	54.2	46.0
		MCWB	38.3	43.8	48.6	54.7	61.0	67.1	68.4	68.0	63.0	56.4	50.3	42.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.8	53.1	60.8	62.9	68.8	73.4	76.3	76.2	70.2	62.8	57.4	52.4
		MCDB	52.2	60.6	66.6	75.9	79.5	86.8	88.6	89.3	82.4	72.0	63.6	56.2
	2%	WB	43.9	49.4	54.2	60.2	65.7	71.6	73.3	73.7	67.5	60.8	55.4	47.9
		MCDB	47.8	57.3	63.3	72.5	75.6	84.2	83.5	85.5	79.3	69.7	59.6	51.2
	5%	WB	41.2	46.5	51.4	58.4	64.0	70.0	71.2	71.1	65.4	59.3	53.2	45.0
		MCDB	43.7	52.3	60.8	69.4	73.5	82.1	82.5	82.9	76.5	68.4	56.9	49.1
	10%	WB	38.5	44.2	49.0	55.9	62.5	68.5	69.7	69.6	64.0	57.6	50.9	42.5
		MCDB	41.2	48.6	56.9	64.9	71.6	80.2	81.9	81.8	75.2	65.3	53.7	45.8
Mean Daily Temperature Range	5% DB	MDBR	10.7	13.3	15.6	17.0	17.9	19.0	19.5	20.7	18.2	15.8	10.9	10.8
		MCDBR	15.9	18.8	22.7	22.0	21.5	22.0	22.3	23.3	22.7	22.3	16.9	15.3
		MCWBR	10.4	11.5	11.8	11.3	9.2	8.9	7.7	7.3	8.0	10.0	9.6	10.4
	5% WB	MCDBR	13.2	18.3	20.8	20.9	19.7	21.1	20.6	21.1	19.2	19.7	13.8	14.8
	MCWBR	9.6	11.5	11.5	11.2	10.0	9.3	8.6	8.6	8.4	9.2	8.1	10.5	
Clear-Sky Solar Irradiance	taub	0.324	0.355	0.389	0.445	0.424	0.428	0.440	0.458	0.417	0.381	0.356	0.328	
	taud	2.332	2.259	2.232	2.089	2.216	2.240	2.212	2.156	2.238	2.334	2.351	2.356	
	Ebn at Noon	247	259	266	259	269	268	263	252	253	247	232	232	
	Edh at Noon	25	33	39	48	44	43	44	45	38	30	25	23	
All-Sky Solar Radiation	RadAvg	449	716	1098	1484	1823	2013	2022	1785	1293	846	475	365	
	RadStd	64	110	126	147	141	149	136	130	109	111	62	51	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (66 neighbors)	+0.95	N/A	N/A	N/A	N/A	N/A	N/A	-265	+130	+63	

Nomenclature: See separate page