

CORUGEA, Romania

WMO: 154080

Lat: 44.7344N

Lon: 28.3419E

Elev: 723

StdP: 14.32

Time Zone: 2.00 (EUE)

Period: 90-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.8	14.6	5.2	7.4	16.2	9.5	9.2	16.8	36.3	21.9	34.4	23.7	9.1	0	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.3	89.1	68.8	86.8	68.1	84.4	67.3	74.3	81.9	72.1	80.1	70.3	78.4	9.3	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
72.9	125.4	75.0	70.0	113.5	74.2	68.0	105.6	73.0	38.3	82.3	36.3	80.0	34.7	78.1	90.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 26.3	22.8	20.7	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	52.1	28.4	34.8	41.1	49.6	61.2	69.8	72.2	72.3	63.6	52.6	44.0	34.1	
	DBStd	16.68	8.04	9.01	8.31	7.27	6.02	5.32	4.05	5.97	7.48	7.08	8.32	7.78	
	HDD50	2251	669	428	294	94	4	0	0	0	0	55	214	493	
	HDD65	5449	1134	845	742	463	147	17	1	9	119	384	631	957	
	CDD50	3005	0	4	17	82	350	593	689	692	407	137	33	1	
	CDD65	729	0	0	0	2	29	159	226	236	76	1	0	0	
	CDH74	6062	0	0	2	33	228	1249	1878	2093	571	8	0	0	
	CDH80	1894	0	0	0	5	37	343	587	775	147	0	0	0	
Wind	WSAvg	8.5	9.0	8.6	9.9	10.5	8.9	7.8	7.0	7.2	7.9	8.2	8.5	8.7	
Precipitation	PrecAvg	17.4	1.1	0.7	1.1	1.3	1.9	2.1	2.0	1.6	1.8	1.3	1.2	1.3	
	PrecMax	25.5	3.2	1.9	2.8	3.1	4.8	4.3	5.0	4.5	4.1	2.7	2.9	3.5	
	PrecMin	10.2	0.1	0.1	0.0	0.1	0.4	0.5	0.4	0.2	0.1	0.1	0.0	0.1	
	PrecStd	3.6	0.8	0.5	0.7	0.7	1.1	0.9	1.2	1.2	1.3	0.7	0.7	0.9	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	49.6	62.5	69.9	78.2	83.9	89.5	91.8	91.8	87.7	74.8	68.1	54.3	
		MCWB	46.8	54.8	54.7	61.9	66.3	71.4	70.7	69.5	69.0	62.0	59.0	51.1	
	2%	DB	45.1	55.4	63.1	71.5	79.5	86.6	88.5	89.5	84.0	71.2	62.2	50.7	
		MCWB	42.7	49.2	51.1	57.7	65.1	69.4	67.8	68.7	64.2	59.3	57.3	49.1	
	5%	DB	41.8	50.4	58.1	66.8	75.9	83.9	85.5	87.3	80.1	67.3	58.1	47.0	
		MCWB	40.6	46.3	48.9	55.4	62.2	68.9	67.3	68.0	63.4	58.3	54.1	45.2	
	10%	DB	39.4	46.1	53.4	62.9	73.0	80.9	83.1	84.4	76.3	63.1	54.9	43.8	
		MCWB	38.4	43.3	45.8	53.2	60.9	66.9	66.5	67.4	62.5	55.6	52.2	42.5	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	47.8	55.4	56.2	63.2	71.3	75.4	76.0	85.8	79.0	66.1	62.8	53.1
			MCDB	48.8	58.6	67.1	75.9	78.8	84.2	81.4	85.8	79.0	68.5	64.3	54.1
2%		WB	43.6	50.2	52.7	60.0	67.6	73.0	73.0	74.7	69.0	62.0	58.2	49.6	
		MCDB	45.0	54.9	60.6	69.5	75.3	81.4	80.4	82.4	74.2	67.8	60.6	50.4	
5%		WB	40.9	46.2	49.9	57.0	65.1	71.0	71.2	71.6	66.5	59.8	55.3	45.9	
		MCDB	42.0	49.8	56.8	65.0	72.8	79.3	78.9	80.4	72.8	64.5	58.0	47.5	
10%		WB	38.6	43.4	46.9	54.2	63.1	69.4	69.5	69.4	64.6	57.5	52.5	42.7	
		MCDB	39.5	45.6	52.1	61.4	70.5	77.9	77.2	78.7	73.7	61.8	55.2	43.9	
Mean Daily Temperature Range		5% DB	MDBR	10.3	12.1	15.7	18.1	18.0	18.9	19.3	18.7	18.1	15.3	12.3	9.9
			MCDBR	12.8	19.3	24.7	24.9	22.2	22.1	23.2	21.5	22.8	20.8	17.2	13.9
	MCWBR		10.8	14.5	14.4	13.7	11.0	10.1	9.7	10.4	10.3	10.9	12.1	11.7	
	5% WB	MCDBR	12.1	17.6	21.3	22.4	20.1	20.4	20.1	19.7	19.1	18.8	16.1	14.3	
		MCWBR	10.7	14.3	14.1	13.7	12.2	11.1	10.5	12.2	11.2	12.3	12.5	12.1	
Clear-Sky Solar Irradiance	taub	0.335	0.362	0.394	0.428	0.407	0.408	0.423	0.432	0.404	0.377	0.355	0.335		
	taud	2.322	2.260	2.218	2.143	2.283	2.305	2.274	2.239	2.290	2.343	2.352	2.347		
	Ebn at Noon	242	256	264	264	274	273	268	260	258	248	233	229		
	Edh at Noon	26	33	39	46	41	40	41	41	36	30	25	23		
All-Sky Solar Radiation	RadAvg	408	664	1050	1508	1905	2057	2059	1844	1338	844	465	353		
	RadStd	60	91	104	148	121	119	111	101	102	81	59	50		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (37 neighbors)		+0.88	N/A	N/A	N/A	N/A	N/A	N/A	-220	+160	+103

Nomenclature: See separate page