

JURILOVCA, RomaniaWMO: **154090**Lat: **44.7661N**Lon: **28.8764E**Elev: **130**StdP: **14.63**Time Zone: **2.00 (EUE)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.4	16.8	5.1	7.2	14.3	9.4	9.0	18.9	45.2	20.5	38.9	24.1	15.6	0	0.509

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	16.3	87.8	69.9	85.5	69.6	83.2	68.7	73.5	82.9	72.0	81.4	70.7	80.0	9.5	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
70.3	112.2	79.1	68.8	106.4	77.9	67.3	100.8	76.5	37.2	83.1	35.8	81.2	34.6	80.2	81.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 27.5	23.2	21.0	DB	4.1	93.2	5.6	3.1	0.1	95.4	-3.2	97.1	-6.4	98.9	-10.5	101.1	(4)
(5)			WB	3.9	76.1	5.0	1.4	0.4	77.1	-2.6	77.9	-5.4	78.7	-9.0	79.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	53.5	31.5	35.8	41.9	51.4	61.5	70.2	73.4	74.0	65.7	54.3	46.0	35.5
	DBStd	16.22	7.86	8.34	6.99	6.40	5.62	5.00	3.77	5.42	6.69	6.41	7.74	8.31
	HDD50	1941	573	398	261	58	3	0	0	0	0	34	163	451
	HDD65	5021	1038	816	717	407	134	11	1	3	76	334	570	914
	CDD50	3230	0	2	10	101	360	605	724	744	472	167	43	2
	CDD65	835	0	0	0	1	26	166	260	282	98	2	0	0
	CDH74	5840	0	0	0	10	133	1061	1889	2250	487	10	0	0
	CDH80	1417	0	0	0	0	10	227	401	716	62	1	0	0
Wind	WSAvg	9.0	10.8	10.2	10.3	8.8	8.1	7.9	7.8	8.9	8.0	8.8	8.5	10.4
Precipitation	PrecAvg	15.6	1.1	0.7	1.0	1.1	1.6	1.9	1.5	1.2	1.6	1.4	1.3	1.3
	PrecMax	25.6	3.4	2.7	2.7	3.2	4.1	3.6	4.7	3.6	4.8	4.1	4.1	3.7
	PrecMin	10.1	0.0	0.1	0.0	0.3	0.3	0.2	0.3	0.2	0.1	0.1	0.0	0.0
	PrecStd	3.9	0.9	0.6	0.7	0.6	1.0	0.9	1.0	1.0	1.3	1.1	1.1	1.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.4	58.7	66.5	74.5	81.1	88.2	88.8	93.1	84.5	75.0	67.2	56.7
		MCWB	43.9	48.7	51.3	59.1	64.5	71.4	72.0	73.3	65.0	64.2	57.3	50.5
	2%	DB	46.7	52.8	59.3	69.0	77.4	85.4	86.1	89.0	81.3	70.4	62.2	53.5
		MCWB	42.5	46.8	48.7	56.8	63.4	69.9	70.2	69.9	66.6	60.6	56.0	49.4
	5%	DB	43.7	48.9	54.6	64.9	74.9	82.5	84.1	86.6	78.9	66.8	59.1	49.3
		MCWB	41.1	43.9	46.5	54.8	62.3	68.6	69.5	69.6	66.2	58.7	54.1	45.5
	10%	DB	41.6	45.6	51.2	61.4	72.1	79.9	82.1	83.9	76.6	63.9	55.9	45.8
		MCWB	39.6	42.1	45.0	53.2	61.4	67.1	69.0	68.9	65.8	56.9	51.7	42.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	45.7	51.0	52.5	61.4	67.9	74.4	75.5	75.4	72.0	65.9	59.7	52.2
		MCDB	48.8	57.3	62.5	70.8	76.7	84.2	83.8	86.6	77.7	71.9	63.6	55.1
	2%	WB	43.2	47.1	49.6	57.9	65.9	72.0	73.5	73.4	70.1	62.0	57.1	49.6
		MCDB	45.7	51.8	57.9	66.1	74.5	81.1	81.7	84.2	76.2	68.6	61.8	53.2
	5%	WB	41.4	44.4	47.5	55.7	64.0	70.3	71.9	72.0	68.7	59.9	54.5	46.0
		MCDB	43.5	47.7	53.8	63.5	72.2	79.4	80.8	82.5	75.4	65.4	58.8	49.4
	10%	WB	39.6	42.5	45.8	53.7	62.2	69.0	70.5	70.4	67.2	58.2	52.3	42.9
		MCDB	41.8	45.4	50.3	60.6	69.8	77.8	79.7	81.1	74.6	62.9	55.4	45.7
Mean Daily Temperature Range	5% DB	MDBR	10.0	11.4	13.5	14.4	15.4	16.1	16.1	16.3	15.6	13.5	11.4	11.2
		MCDBR	13.4	16.9	19.8	19.6	20.0	18.4	18.0	18.4	17.7	17.4	16.0	15.5
		MCWBR	10.0	11.4	11.7	10.0	10.1	9.6	9.1	9.6	10.2	9.8	10.1	11.2
	5% WB	MCDBR	12.3	14.9	17.6	18.2	18.1	16.4	16.0	16.7	16.0	15.5	14.3	15.3
		MCWBR	10.1	10.7	11.0	10.4	10.4	9.5	9.4	10.0	10.0	9.9	9.9	11.1
Clear-Sky Solar Irradiance	taub	0.347	0.376	0.407	0.429	0.409	0.411	0.425	0.433	0.408	0.389	0.366	0.347	
	taud	2.310	2.243	2.200	2.177	2.314	2.337	2.307	2.273	2.317	2.330	2.334	2.329	
	Ebn at Noon	237	251	259	264	273	273	267	260	257	244	227	223	
	Edh at Noon	26	33	40	44	40	39	40	40	35	30	26	23	
All-Sky Solar Radiation	RadAvg	394	643	1054	1528	1939	2094	2082	1859	1346	836	456	342	
	RadStd	61	88	106	142	120	115	103	99	101	76	63	51	