

JURILOVCA, RomaniaWMO: **154090**Lat: **44.7661N**Lon: **28.8764E**Elev: **40**StdP: **100.85**Time Zone: **2.00 (EUE)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-10.9	-8.4	-14.9	1.0	-9.8	-12.5	1.3	-7.3	20.2	-6.4	17.4	-4.4	7.0	0	0.509

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.1	31.0	21.0	29.7	20.9	28.5	20.4	23.1	28.3	22.2	27.4	21.5	26.7	4.2	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
21.3	16.0	26.2	20.5	15.2	25.5	19.6	14.4	24.7	68.5	28.4	65.5	27.3	62.7	26.8	27.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.3	10.4	9.4	-15.5	34.0	3.1	1.7	-17.7	35.2	-19.6	36.2	-21.3	37.1	-23.6	38.4		
(5)			-15.6	24.5	2.8	0.8	-17.6	25.0	-19.2	25.5	-20.8	26.0	-22.8	26.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	12.0	-0.3	2.1	5.5	10.8	16.4	21.2	23.0	23.3	18.7	12.4	7.8	1.9	(6)
(7)		DBStd	9.01	4.37	4.64	3.88	3.55	3.12	2.78	2.09	3.01	3.72	3.56	4.30	4.62	(7)
(8)		HDD10.0	1078	318	221	145	32	2	0	0	0	0	19	91	251	(8)
(9)		HDD18.3	2789	577	453	398	226	74	6	1	2	42	186	317	508	(9)
(10)		CDD10.0	1794	0	1	6	56	200	336	402	413	262	93	24	1	(10)
(11)		CDD18.3	464	0	0	0	1	14	92	144	157	54	1	0	0	(11)
(12)		CDH23.3	3244	0	0	0	6	74	589	1049	1250	271	6	0	0	(12)
(13)		CDH26.7	787	0	0	0	0	6	126	223	398	34	1	0	0	(13)
(14)	Wind	WSAvg	4.0	4.8	4.5	4.6	4.0	3.6	3.5	4.0	3.6	3.9	3.8	4.6	(14)	
(15)	Precipitation	PrecAvg	395	28	18	25	29	40	48	39	31	41	36	33	34	(15)
(16)		PrecMax	651	87	68	68	82	104	91	119	91	123	105	105	94	(16)
(17)		PrecMin	256	1	2	1	7	8	5	7	5	2	3	1	1	(17)
(18)		PrecStd	100	23	16	17	16	26	22	26	26	33	27	28	27	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.2	14.8	19.1	23.6	27.3	31.2	31.6	34.0	29.1	23.9	19.6	13.7	(19)
(20)			MCWB	6.6	9.3	10.7	15.1	18.1	21.9	22.2	22.9	18.3	17.9	14.0	10.3	(20)
(21)		2%	DB	8.2	11.6	15.2	20.6	25.2	29.7	30.1	31.7	27.4	21.3	16.8	12.0	(21)
(22)			MCWB	5.9	8.2	9.3	13.8	17.5	21.1	21.2	21.0	19.2	15.9	13.4	9.6	(22)
(23)		5%	DB	6.5	9.4	12.6	18.3	23.9	28.1	28.9	30.3	26.1	19.3	15.0	9.6	(23)
(24)			MCWB	5.0	6.6	8.1	12.7	16.8	20.3	20.8	20.9	19.0	14.8	12.3	7.5	(24)
(25)		10%	DB	5.3	7.5	10.7	16.3	22.3	26.6	27.8	28.9	24.8	17.7	13.3	7.7	(25)
(26)			MCWB	4.2	5.6	7.2	11.8	16.3	19.5	20.6	20.5	18.8	13.8	11.0	5.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.6	10.5	11.4	16.3	20.0	23.5	24.2	24.1	22.2	18.8	15.4	11.2	(27)
(28)			MCDWB	9.3	14.0	17.0	21.6	24.8	29.0	28.8	30.3	25.4	22.2	17.6	12.9	(28)
(29)		2%	WB	6.2	8.4	9.8	14.4	18.8	22.2	23.1	23.0	21.2	16.6	13.9	9.8	(29)
(30)			MCDWB	7.6	11.0	14.4	19.0	23.6	27.3	27.6	29.0	24.6	20.3	16.5	11.8	(30)
(31)		5%	WB	5.2	6.9	8.6	13.2	17.8	21.3	22.2	22.2	20.4	15.5	12.5	7.8	(31)
(32)			MCDWB	6.4	8.7	12.1	17.5	22.3	26.3	27.1	28.1	24.1	18.5	14.9	9.7	(32)
(33)		10%	WB	4.2	5.9	7.7	12.1	16.8	20.5	21.4	21.3	19.6	14.5	11.3	6.1	(33)
(34)			MCDWB	5.4	7.4	10.2	15.9	21.0	25.5	26.5	27.3	23.7	17.2	13.0	7.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	5.6	6.3	7.5	8.0	8.5	8.9	8.9	9.1	8.7	7.5	6.3	6.2	(35)
(36)			MCDBR	7.4	9.4	11.0	10.9	11.1	10.2	10.0	10.2	9.8	9.7	8.9	8.6	(36)
(37)			MCWBR	5.6	6.3	6.5	5.6	5.6	5.3	5.0	5.3	5.7	5.5	5.6	6.2	(37)
(38)		5% WB	MCDWR	6.9	8.3	9.8	10.1	10.1	9.1	8.9	9.3	8.9	8.6	8.0	8.5	(38)
(39)			MCWBR	5.6	6.0	6.1	5.8	5.8	5.3	5.2	5.6	5.6	5.5	5.5	6.2	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.347	0.376	0.407	0.429	0.409	0.411	0.425	0.433	0.408	0.389	0.366	0.347	(40)	
(41)		taud	2.310	2.243	2.200	2.177	2.314	2.337	2.307	2.273	2.317	2.330	2.334	2.329	(41)	
(42)		Ebn at Noon	746	791	817	832	862	860	842	819	809	768	717	704	(42)	
(43)		Edh at Noon	83	105	126	140	125	123	126	126	111	96	81	74	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.24	2.03	3.32	4.82	6.11	6.60	6.56	5.86	4.24	2.63	1.44	1.08	(44)	
(45)		RadStd	0.19	0.28	0.33	0.45	0.38	0.36	0.32	0.31	0.32	0.24	0.20	0.16	(45)	