

CAMPIA TURZII, Romania

WMO: 154215

Lat: 46.502N

Lon: 23.886E

Elev: 1083

StdP: 14.13

Time Zone: 2.00 (EUE)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	5.2	11.9	1.3	6.1	6.0	8.3	8.7	13.3	21.2	34.8	18.3	32.9	1.8	330	0.484

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.6	90.0	68.2	87.5	67.6	84.3	66.6	71.1	83.7	69.8	82.6	68.1	80.4	6.7	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.5	101.7	76.8	64.8	95.7	74.4	64.2	93.5	73.6	35.7	84.1	34.5	82.2	33.0	80.5	78.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
18.6	15.6	12.5	1.2	95.2	8.9	3.6	-5.2	97.8	-10.4	99.9	-15.4	102.0	-21.9	104.6		
			2.0	73.9	8.3	1.7	-3.9	75.1	-8.8	76.1	-13.5	77.0	-19.5	78.3		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	50.5	27.8	32.6	42.3	52.6	60.5	66.9	70.0	70.1	61.1	50.3	40.1	30.8	(6)
	DBStd	16.33	8.95	9.20	7.46	5.61	5.82	5.39	4.97	4.96	5.97	6.71	7.52	7.26	(7)
	HDD50	2447	688	487	252	35	3	0	0	0	2	80	305	595	(8)
	HDD65	5774	1153	907	705	373	160	43	13	13	145	456	746	1060	(9)
	CDD50	2637	0	0	12	112	330	507	619	624	334	90	9	0	(10)
	CDD65	488	0	0	0	1	22	100	166	172	26	1	0	0	(11)
	CDH74	5515	0	0	0	51	353	1004	1768	1892	424	23	0	0	(12)
	CDH80	1844	0	0	0	5	51	278	656	752	98	4	0	0	(13)
(14) Wind	WSAvg	4.8	3.7	4.7	6.3	5.8	5.7	5.5	5.3	4.7	4.9	4.0	3.6	3.8	(14)
(15) Precipitation	PrecAvg	21.1	0.9	0.7	1.0	1.7	2.5	3.5	3.3	1.9	2.1	1.7	1.3	1.2	(15)
	PrecMax	28.7	1.7	1.8	2.8	3.0	4.2	7.5	5.4	3.6	5.6	3.5	2.8	2.1	(16)
	PrecMin	13.6	0.3	0.3	0.2	0.2	0.8	0.7	0.6	0.1	0.2	0.0	0.0	0.2	(17)
	PrecStd	4.0	0.4	0.4	0.7	0.7	0.9	1.4	1.3	1.0	1.2	0.9	0.6	0.7	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	49.8	57.5	69.7	80.2	84.3	89.7	94.9	94.9	87.5	76.9	64.5	51.9	(19)
		MCWB	44.3	48.2	52.6	60.1	61.8	69.0	67.2	67.0	62.5	60.3	55.2	46.9	(20)
	2%	DB	44.8	52.0	64.4	73.6	80.8	86.2	90.0	91.1	82.5	71.8	59.1	46.4	(21)
		MCWB	42.3	45.6	50.0	57.5	62.6	68.7	68.2	68.4	62.5	58.3	52.5	44.0	(22)
	5%	DB	41.2	48.2	59.3	69.8	78.5	83.8	86.4	87.6	78.9	68.0	55.3	42.8	(23)
		MCWB	39.7	43.7	48.1	55.1	62.0	67.4	68.0	67.3	61.1	57.4	49.7	41.2	(24)
	10%	DB	38.5	44.6	55.4	66.2	73.8	80.5	83.1	84.1	75.2	62.9	51.7	39.5	(25)
		MCWB	37.0	41.7	46.1	53.2	60.7	66.2	66.7	67.0	61.0	54.2	47.7	38.4	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	45.4	49.5	54.5	61.4	67.3	72.9	72.2	73.3	66.2	62.1	56.4	47.3	(27)
		MCDB	48.1	56.2	66.3	75.8	79.5	85.4	85.0	87.7	80.6	73.8	62.5	50.8	(28)
	2%	WB	42.3	46.5	51.1	58.8	64.6	70.6	70.6	71.1	64.4	59.6	53.2	43.7	(29)
		MCDB	44.3	51.6	61.9	72.7	76.3	82.5	83.8	83.7	78.2	69.2	58.1	45.7	(30)
	5%	WB	39.5	44.0	48.9	56.4	62.8	68.6	69.4	69.5	62.8	57.6	50.8	40.9	(31)
		MCDB	40.9	47.1	58.5	67.2	74.7	79.5	82.7	82.6	75.1	66.3	54.7	42.2	(32)
	10%	WB	36.8	41.4	46.6	54.3	61.2	67.1	67.8	67.8	61.2	55.6	48.0	38.2	(33)
		MCDB	37.8	44.1	54.3	63.2	72.0	77.4	80.5	80.3	71.4	62.6	50.7	39.1	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	11.8	14.5	19.7	22.6	22.2	21.9	23.6	24.8	23.5	21.8	15.5	9.7	(35)
		MCDBR	13.9	19.4	28.3	29.6	28.7	27.3	29.2	30.8	30.5	28.8	22.3	14.4	(36)
	5% WB	MCWBR	11.1	13.6	15.9	15.2	13.0	11.8	11.1	11.5	13.1	16.5	15.5	11.4	(37)
		MCWBR	13.4	18.3	25.8	26.2	25.5	23.9	25.6	26.2	26.1	26.5	20.2	13.6	(38)
(40) Clear-Sky Solar Irradiance	taub		0.312	0.338	0.379	0.427	0.412	0.409	0.427	0.433	0.394	0.363	0.339	0.313	(40)
		taud	2.347	2.307	2.252	2.153	2.256	2.293	2.246	2.228	2.309	2.378	2.396	2.373	(41)
	Ebn at Noon		245	261	266	263	271	272	265	258	258	249	233	230	(42)
		Edh at Noon	24	30	37	45	42	41	42	41	35	28	23	21	(43)
(44) All-Sky Solar Radiation	RadAvg		393	653	1013	1379	1680	1842	1811	1670	1188	815	463	305	(44)
	RadStd		54	79	136	139	157	155	157	156	134	98	62	39	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (71 neighbors)		+1.33	N/A	N/A	+1.78	N/A	N/A	-268	-387	+166	+41

Nomenclature: See separate page