

SLOBOZIA, Romania

WMO: 154250

Lat: 44.5528N

Lon: 27.3836E

Elev: 172

StdP: 14.60

Time Zone: 2.00 (EUE)

Period: 86-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.1	16.7	8.2	8.4	14.0	12.3	10.3	19.0	35.5	24.2	30.0	24.7	8.3	240	0.500

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	22.9	92.8	69.8	90.5	69.1	88.0	68.3	73.5	85.9	72.0	84.3	70.7	83.0	7.6	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
69.8	110.4	77.8	68.3	104.6	76.5	67.0	99.9	75.2	37.1	85.7	35.8	84.7	34.7	82.7	79.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 24.4	20.5	17.7	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	53.7	29.1	37.5	44.0	52.0	62.7	71.5	74.3	74.6	66.0	54.0	42.7	34.7
	DBStd	16.97	8.33	8.46	8.06	7.38	5.62	5.27	4.49	5.13	6.87	7.96	8.48	6.63
	HDD50	2067	647	356	216	66	2	0	0	0	0	53	251	476
	HDD65	5081	1112	770	650	393	112	10	1	3	73	347	670	940
	CDD50	3407	0	6	31	125	394	644	753	763	481	178	31	1
	CDD65	945	0	0	0	2	39	204	289	301	104	6	0	0
	CDH74	9519	0	0	6	55	440	1877	2882	3154	1022	81	2	0
	CDH80	3808	0	0	0	6	77	694	1234	1426	356	15	0	0
	WSAvg	7.6	8.8	8.9	8.8	8.8	7.3	6.7	6.4	6.8	6.5	6.9	6.9	8.5
	PrecAvg	19.5	1.2	0.8	1.2	1.3	2.3	2.7	1.8	1.6	2.0	1.6	1.4	1.6
(15) Precipitation	PrecMax	28.0	3.3	2.2	2.8	3.6	6.1	4.5	4.3	3.8	5.8	3.1	4.1	4.4
	PrecMin	12.6	0.1	0.0	0.0	0.2	0.4	0.5	0.3	0.4	0.0	0.1	0.0	0.1
	PrecStd	4.0	0.8	0.6	0.7	0.7	1.4	1.0	1.0	1.0	1.4	0.9	0.9	1.2
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.2	65.9	73.2	79.8	85.7	94.5	96.9	96.0	91.4	81.3	70.2	55.8
		MCWB	46.9	54.8	56.6	64.5	66.1	73.3	72.8	69.9	66.6	63.9	60.1	51.2
	2%	DB	46.8	58.3	67.1	74.3	81.9	90.2	92.6	92.7	87.3	75.3	62.6	50.8
		MCWB	43.3	49.9	54.1	61.0	65.1	70.7	70.1	69.2	65.5	61.0	56.3	47.2
	5%	DB	42.9	53.6	61.9	70.1	78.9	87.0	90.0	90.5	84.0	70.9	58.2	47.0
		MCWB	41.1	46.8	51.3	57.8	64.0	69.7	69.4	68.7	64.5	59.0	54.0	44.5
	10%	DB	39.5	49.2	57.0	66.3	75.5	83.8	87.0	87.9	80.0	66.7	54.6	43.3
		MCWB	37.8	45.0	48.4	55.7	61.9	68.8	68.9	68.0	63.9	57.4	51.6	40.9
	0.4%	WB	47.9	55.7	58.7	65.8	70.1	75.3	76.0	75.1	70.3	65.5	60.6	52.1
		MCDB	50.7	64.9	71.1	78.8	81.8	90.7	90.8	88.0	81.2	78.6	68.2	56.3
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	43.8	51.3	54.5	62.0	67.5	73.0	73.3	72.9	68.6	62.6	57.2	47.8
		MCDB	46.0	57.9	64.6	73.0	79.0	85.2	85.1	86.0	79.3	71.1	62.0	50.5
	5%	WB	41.0	47.8	51.8	59.4	65.5	71.7	71.9	71.2	67.0	60.5	54.9	45.1
		MCDB	42.7	52.5	60.4	69.2	75.8	84.3	83.8	83.8	78.0	69.6	57.8	47.6
	10%	WB	38.2	45.0	49.1	56.7	63.6	70.0	70.5	69.9	65.4	58.4	52.2	41.4
		MCDB	39.4	48.9	55.8	64.3	73.0	81.6	82.3	83.5	77.3	65.2	54.9	43.3
(35) Mean Daily Temperature Range	5% DB	MDBR	11.2	14.1	17.9	20.3	21.0	21.2	22.2	22.9	21.5	18.6	13.1	11.0
		MCDBR	14.5	22.6	27.5	27.5	25.9	26.1	27.4	26.7	27.3	25.7	18.9	16.3
		MCWBR	11.4	14.7	15.8	15.6	11.5	9.8	8.5	8.5	9.8	12.7	11.7	12.6
	5% WB	MCDBR	13.7	20.9	25.9	27.2	23.8	24.7	22.7	23.8	23.9	23.3	17.0	16.9
		MCWBR	11.3	14.3	15.6	15.8	12.1	10.2	8.6	9.2	10.0	12.5	10.9	13.2
(40) Clear-Sky Solar Irradiance	taub		0.344	0.373	0.406	0.459	0.433	0.437	0.450	0.463	0.430	0.392	0.366	0.346
	taud		2.296	2.223	2.184	2.049	2.207	2.228	2.200	2.153	2.211	2.304	2.325	2.316
	Ebn at Noon		238	252	259	255	267	266	260	251	249	243	228	224
	Edh at Noon		27	34	41	50	44	43	44	45	39	31	26	24
(44) All-Sky Solar Radiation	RadAvg		423	683	1065	1498	1892	2043	2067	1848	1343	855	470	356
	RadStd		64	102	110	153	128	135	122	103	96	94	56	47

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (54 neighbors)	+0.85	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-221	+126	+79

Nomenclature: See separate page