

CRAIOVA, Romania

WMO: 154500

Lat: 44.3103N

Lon: 23.8669E

Elev: 634

StdP: 14.36

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.1	14.6	6.3	7.8	12.3	11.2	10.0	17.1	27.6	40.5	22.3	36.0	4.8	90	0.491

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.2	93.5	69.5	90.6	68.9	87.8	68.4	73.3	86.1	71.7	84.4	70.4	82.6	5.5	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.6	111.3	77.5	68.0	105.2	76.3	66.4	99.6	75.2	37.3	86.6	35.8	84.3	34.7	82.8	81.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 22.8	18.9	16.5	3.7	97.9	6.0	4.4	-0.6	101.1	-4.0	103.7	-7.4	106.2	-11.7	109.4		
(5)			3.4	76.8	5.9	2.6	-0.9	78.6	-4.3	80.2	-7.7	81.7	-12.0	83.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	53.7	30.6	35.8	44.7	54.4	63.3	70.3	74.2	74.2	65.1	53.8	43.4	33.0		
	DBStd	16.94	8.96	9.45	8.25	6.46	6.07	5.84	5.16	5.43	6.58	7.51	7.70	7.90		
	HDD50	2038	603	402	202	31	1	0	0	0	0	47	225	527		
	HDD65	5038	1067	818	630	323	105	19	2	4	79	351	649	991		
	CDD50	3377	1	4	37	162	414	610	752	750	453	167	26	1		
	CDD65	900	0	0	0	4	53	178	289	289	82	5	0	0		
	CDH74	9178	0	0	1	62	511	1782	3004	2989	763	66	0	0		
	CDH80	3609	0	0	0	9	89	646	1303	1327	228	7	0	0		
	WSAvg	6.7	5.8	7.2	8.1	8.2	7.1	6.3	6.2	6.1	6.5	6.2	6.4	5.9		
	PrecAvg	24.9	1.7	1.3	1.7	2.0	2.7	2.7	2.7	2.2	2.3	2.0	1.7	1.9		
(15) Precipitation	PrecMax	44.1	3.8	2.5	5.1	5.1	5.9	5.4	7.4	8.5	5.3	5.4	4.3	5.6		
	PrecMin	12.0	0.2	0.1	0.3	0.0	0.4	0.5	0.4	0.1	0.1	0.0	0.0	0.0		
	PrecStd	7.0	0.9	0.7	1.2	1.1	1.3	1.3	1.9	1.9	1.6	1.4	1.2	1.5		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	56.0	63.1	71.4	80.8	86.1	94.9	99.2	98.0	90.7	80.5	68.0	56.0		
		MCWB	46.4	50.5	53.6	60.9	65.2	70.5	69.5	70.9	66.5	63.4	55.6	48.6		
	2%	DB	49.6	57.5	66.8	74.6	82.4	90.4	93.5	93.6	85.9	74.9	62.3	49.8		
		MCWB	43.8	47.9	52.3	59.2	64.6	69.3	69.7	69.5	65.1	61.1	54.7	45.3		
	5%	DB	45.4	52.9	62.6	70.1	79.7	86.8	90.2	90.6	82.2	70.5	57.6	45.9		
		MCWB	41.7	45.7	50.4	56.5	63.4	68.6	69.0	68.8	64.3	59.3	52.0	42.5		
	10%	DB	41.9	48.5	58.5	66.7	76.6	83.5	87.3	87.6	78.3	66.5	54.1	42.9		
		MCWB	39.5	43.3	48.0	54.7	62.3	67.5	68.6	68.2	62.7	57.5	50.4	40.9		
	0.4%	WB	47.7	52.2	56.4	62.9	69.4	74.1	75.4	75.8	70.6	66.2	57.6	49.6		
		MCDB	53.8	60.6	66.3	76.0	81.6	87.6	88.4	88.7	83.7	77.0	64.6	54.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	44.5	48.8	53.5	60.5	66.8	72.0	73.2	73.3	67.9	62.8	55.3	45.8		
		MCDB	48.4	56.0	63.5	71.9	78.3	85.1	85.7	86.4	79.3	70.3	60.8	49.1		
	5%	WB	42.2	46.3	51.2	58.2	65.0	70.4	71.7	71.5	65.8	60.4	53.1	43.2		
		MCDB	44.9	51.9	60.9	67.9	76.1	82.6	84.4	83.7	77.0	68.1	56.7	45.2		
	10%	WB	39.5	43.8	49.0	56.1	63.2	68.9	70.3	70.0	64.2	58.4	51.0	41.0		
		MCDB	41.8	47.9	57.4	64.3	73.6	80.2	82.6	82.2	75.0	65.2	53.7	42.7		
	5% DB	MDBR	11.6	14.1	17.8	18.9	20.3	21.1	22.2	22.5	20.3	17.4	12.4	11.0		
		MCDBR	17.6	21.6	25.3	24.8	24.6	25.6	26.4	26.8	26.2	24.5	19.5	16.0		
		MCWBR	12.4	13.6	14.3	12.5	11.0	9.5	9.2	8.7	10.0	12.2	12.1	11.6		
		MCWBR	16.5	19.7	23.2	22.2	22.7	22.7	23.1	23.1	22.6	21.8	16.5	14.0		
(40) Clear-Sky Solar Irradiance	taub		0.338	0.367	0.403	0.460	0.438	0.439	0.452	0.470	0.433	0.393	0.366	0.340		
		taud	2.300	2.222	2.189	2.045	2.177	2.212	2.181	2.124	2.194	2.298	2.319	2.322		
	Ebn at Noon		242	255	261	255	265	265	259	249	248	243	229	228		
		Edh at Noon	27	34	40	51	46	44	45	46	40	32	26	24		
(44) All-Sky Solar Radiation	RadAvg		453	717	1102	1501	1848	2053	2058	1815	1311	845	474	368		
	RadStd		69	110	127	150	140	148	130	135	107	113	67	53		

Historical Trends

		Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	-1.01	-1.48	N/A	N/A	N/A	N/A
(47) Regional (68 neighbors)		+0.99	N/A	N/A	N/A	N/A	N/A	N/A	-275	+142	N/A

Nomenclature: See separate page