

BAILESTI, Romania

WMO: 154650

Lat: 44.0292N

Lon: 23.3311E

Elev: 192

StdP: 14.59

Time Zone: 2.00 (EUE)

Period: 86-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 11.1	(c) 15.8	(d) 7.5	(e) 8.2	(f) 12.8	(g) 12.8	(h) 10.6	(i) 16.6	(j) 36.8	(k) 34.9	(l) 30.3	(m) 39.8	(n) 4.2	(o) 270	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 23.9	(c) 93.9	(d) 70.5	(e) 91.2	(f) 69.5	(g) 88.6	(h) 69.1	(i) 73.8	(j) 87.0	(k) 72.4	(l) 85.9	(m) 71.0	(n) 84.3	(o) 5.2	(p) 140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
70.0	111.1	78.9	68.3	104.7	76.9	66.9	99.7	75.7	37.4	87.1	36.1	86.7	34.9	84.1	83.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 25.4	(b) 20.3	(c) 16.6	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	54.4	30.4	38.0	46.0	54.2	64.2	71.5	74.5	75.3	66.3	54.6	42.1	34.7		
	DBStd	16.83	8.79	8.01	7.59	7.14	5.63	5.12	4.83	5.54	6.74	6.94	7.59	7.18		
	HDD50	1920	607	339	167	40	0	0	0	0	0	36	254	477		
	HDD65	4862	1072	756	590	327	82	8	1	5	66	327	687	941		
	CDD50	3528	0	3	43	167	441	645	758	785	490	178	17	1		
	CDD65	995	0	0	0	4	59	203	295	325	106	3	0	0		
	CDH74	10145	0	0	9	95	560	1959	3025	3417	1011	69	0	0		
	CDH80	4136	0	0	0	14	106	731	1315	1615	348	7	0	0		
(14) Wind	WSAvg	5.6	5.2	5.8	6.3	7.2	5.6	5.4	5.4	5.2	5.3	5.3	4.5	5.8		
(15) Precipitation	PrecAvg	21.9	1.5	1.2	1.5	1.9	2.4	2.1	2.2	1.4	2.2	1.8	1.5	2.0		
	PrecMax	40.9	3.0	2.7	3.9	4.4	4.4	4.3	5.1	3.3	7.3	4.4	4.1	4.9		
	PrecMin	11.4	0.2	0.0	0.2	0.6	0.5	0.5	0.2	0.1	0.2	0.1	0.0	0.0		
	PrecStd	6.1	0.9	0.8	1.1	0.9	1.1	1.0	1.4	0.9	1.7	1.2	1.1	1.5		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.0	64.8	75.4	81.8	88.4	95.4	96.4	98.0	91.8	80.3	68.7	57.0		
		MCWB	47.3	54.6	57.5	62.7	68.2	73.1	72.5	70.4	67.7	62.2	59.5	50.6		
	2%	DB	49.2	58.7	69.2	76.1	83.5	90.3	93.4	94.3	87.4	75.1	61.4	51.5		
		MCWB	44.0	50.5	55.2	60.7	66.7	70.8	71.2	69.6	65.7	60.8	55.7	46.6		
	5%	DB	44.5	53.3	63.8	71.5	80.4	87.3	90.6	91.6	83.8	71.5	56.2	47.3		
		MCWB	41.0	47.7	52.0	57.6	64.0	70.2	70.2	68.6	64.6	59.0	52.4	43.5		
	10%	DB	41.0	49.1	59.1	68.0	77.3	84.1	87.6	88.7	80.1	67.4	52.5	44.0		
		MCWB	38.6	45.1	49.6	55.8	62.8	68.4	69.8	68.4	64.2	57.3	49.3	41.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.1	56.7	59.5	64.3	70.1	75.5	78.0	74.3	70.6	65.1	60.4	50.9		
		MCDB	54.7	61.7	70.8	77.2	82.3	88.1	89.0	89.7	85.5	74.5	67.6	56.1		
	2%	WB	44.1	51.3	56.0	61.9	68.2	73.5	74.2	72.5	68.4	62.1	56.8	47.2		
		MCDB	47.9	57.6	67.3	75.5	80.6	85.8	87.0	87.7	81.2	71.8	61.8	51.2		
	5%	WB	41.2	48.0	53.3	59.2	66.1	72.1	72.5	71.3	66.6	60.1	53.4	44.2		
		MCDB	43.8	52.6	62.2	69.5	76.8	84.6	85.8	85.9	78.6	70.0	55.9	47.0		
	10%	WB	38.6	45.4	50.7	56.9	64.1	70.5	71.0	70.0	65.1	57.9	50.3	41.6		
		MCDB	40.7	49.0	58.4	65.8	73.7	82.1	84.0	83.9	77.2	66.7	52.6	43.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	12.5	15.1	18.7	20.4	20.0	21.7	22.7	23.9	22.0	19.4	13.0	12.1		
		MCDBR	19.0	23.8	28.6	28.2	25.5	26.5	27.2	27.8	28.0	28.1	20.8	17.7		
	5% WB	MCWBR	14.1	16.3	15.7	14.0	10.5	9.9	9.3	9.3	10.9	14.4	13.8	13.3		
		MCWBR	17.1	22.5	26.4	26.1	23.2	24.0	24.5	25.1	24.4	26.1	16.8	17.8		
(40) Clear-Sky Solar Irradiance	taub		0.348	0.377	0.416	0.477	0.455	0.451	0.464	0.482	0.448	0.405	0.375	0.349		
	taud		2.279	2.196	2.155	2.006	2.138	2.188	2.157	2.101	2.158	2.267	2.300	2.299		
	Ebn at Noon		238	251	257	250	261	262	256	246	244	239	226	225		
	Edh at Noon		27	36	42	53	48	45	46	48	42	33	27	25		
(44) All-Sky Solar Radiation	RadAvg		452	712	1084	1475	1807	2023	2038	1808	1302	842	480	372		
	RadStd		69	105	129	160	149	156	132	147	108	115	68	54		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (55 neighbors)	+1.03	N/A	N/A	N/A	+0.68	N/A	N/A	-268	+167	N/A

Nomenclature: See separate page