

BAILESTI, Romania

WMO: 154650

Lat: 44.0292N

Lon: 23.3311E

Elev: 59

StdP: 100.62

Time Zone: 2.00 (EUE)

Period: 86-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.6	-9.0	-13.6	1.2	-10.7	-10.7	1.5	-8.5	16.5	1.6	13.6	4.3	1.9	270	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	13.3	34.4	21.4	32.9	20.8	31.4	20.6	23.2	30.6	22.4	30.0	21.7	29.1	2.3	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.1	15.9	26.1	20.2	15.0	24.9	19.4	14.2	24.3	69.1	30.6	66.1	30.4	63.4	28.9	28.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.3	9.1	7.4	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	12.4	-0.9	3.3	7.8	12.3	17.9	21.9	23.6	24.1	19.1	12.5	5.6	1.5		
	DBStd	9.35	4.88	4.45	4.22	3.97	3.13	2.84	2.68	3.08	3.75	3.85	4.22	3.99		
	HDD10.0	1067	337	188	93	22	0	0	0	0	0	20	141	265		
	HDD18.3	2701	596	420	328	182	46	4	1	3	37	182	382	523		
	CDD10.0	1960	0	2	24	93	245	358	421	436	272	99	9	1		
	CDD18.3	553	0	0	0	2	33	113	164	181	59	2	0	0		
	CDH23.3	5636	0	0	5	53	311	1088	1681	1898	562	38	0	0		
	CDH26.7	2298	0	0	0	8	59	406	731	897	193	4	0	0		
(14) Wind	WSAvg	2.5	2.3	2.6	2.8	3.2	2.5	2.4	2.4	2.3	2.4	2.4	2.0	2.6		
(15) Precipitation	PrecAvg	556	37	31	38	49	60	54	57	36	55	46	39	50		
	PrecMax	1038	76	68	99	113	113	108	130	85	186	112	104	125		
	PrecMin	289	5	1	5	15	12	12	6	3	5	3	0	0		
	PrecStd	154	22	20	27	24	27	26	36	22	44	31	27	38		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.8	18.2	24.1	27.6	31.3	35.2	35.8	36.7	33.2	26.8	20.4	13.9		
		MCWB	8.5	12.5	14.2	17.1	20.1	22.8	22.5	21.3	19.9	16.8	15.3	10.3		
	2%	DB	9.6	14.8	20.7	24.5	28.6	32.4	34.1	34.6	30.8	24.0	16.3	10.8		
		MCWB	6.6	10.3	12.9	15.9	19.3	21.5	21.8	20.9	18.7	16.0	13.2	8.1		
	5%	DB	7.0	11.8	17.7	21.9	26.9	30.7	32.6	33.1	28.8	21.9	13.4	8.5		
		MCWB	5.0	8.7	11.1	14.2	17.8	21.2	21.2	20.4	18.1	15.0	11.3	6.4		
	10%	DB	5.0	9.5	15.1	20.0	25.2	29.0	30.9	31.5	26.7	19.7	11.4	6.7		
		MCWB	3.7	7.3	9.8	13.2	17.1	20.2	21.0	20.2	17.9	14.0	9.6	5.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.0	13.7	15.3	17.9	21.2	24.2	25.5	23.5	21.4	18.4	15.8	10.5		
		MCDB	12.6	16.5	21.6	25.1	27.9	31.2	31.7	32.0	29.7	23.6	19.8	13.4		
	2%	WB	6.7	10.7	13.3	16.6	20.1	23.1	23.5	22.5	20.2	16.7	13.8	8.5		
		MCDB	8.8	14.2	19.6	24.2	27.0	29.9	30.6	30.9	27.3	22.1	16.5	10.7		
	5%	WB	5.1	8.9	11.8	15.1	19.0	22.3	22.5	21.8	19.2	15.6	11.9	6.8		
		MCDB	6.6	11.4	16.8	20.8	24.9	29.2	29.9	29.9	25.9	21.1	13.3	8.3		
	10%	WB	3.7	7.4	10.4	13.8	17.8	21.4	21.6	21.1	18.4	14.4	10.2	5.3		
		MCDB	4.8	9.4	14.7	18.8	23.2	27.8	28.9	28.9	25.1	19.3	11.5	6.6		
(35) Mean Daily Temperature Range	5% DB	MDBR	6.9	8.4	10.4	11.3	11.1	12.1	12.6	13.3	12.2	10.8	7.2	6.7		
		MCDBR	10.5	13.2	15.9	15.6	14.2	14.7	15.1	15.5	15.6	15.6	11.6	9.8		
	5% WB	MCWBR	7.8	9.0	8.7	7.8	5.8	5.5	5.2	5.2	6.0	8.0	7.6	7.4		
		MCWBR	9.5	12.5	14.7	14.5	12.9	13.4	13.6	13.9	13.5	14.5	9.3	9.9		
(40) Clear-Sky Solar Irradiance	taub	taub	0.348	0.377	0.416	0.477	0.455	0.451	0.464	0.482	0.448	0.405	0.375	0.349		
		taud	2.279	2.196	2.155	2.006	2.138	2.188	2.157	2.101	2.158	2.267	2.300	2.299		
	Ebn at Noon	Ebn at Noon	751	792	811	789	822	825	808	776	769	753	712	708		
		Edh at Noon	86	112	132	166	150	143	146	150	131	103	85	78		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.43	2.25	3.42	4.65	5.70	6.38	6.43	5.70	4.10	2.65	1.51	1.17		
	RadStd	RadStd	0.22	0.33	0.41	0.51	0.47	0.49	0.41	0.46	0.34	0.36	0.21	0.17		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (55 neighbors)	+0.57	N/A	N/A	N/A	+0.38	N/A	N/A	-149	+93	N/A

Nomenclature: See separate page