

ROSIORII DE VEDE, Romania

WMO: 154700

Lat: 44.1072N

Lon: 24.9786E

Elev: 339

StdP: 14.52

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	5.9	11.8	2.5	6.3	8.1	8.6	8.6	13.8	24.3	33.8	21.2	36.2	3.4	270	0.460

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.6	94.7	69.4	91.7	68.8	88.8	68.1	73.4	86.3	71.8	84.4	70.4	82.6	5.1	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.9	111.2	76.8	68.3	105.2	75.9	66.7	99.4	74.7	37.1	86.2	35.7	84.5	34.5	82.4	83.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.6	17.4	14.9	DB	-1.5	99.0	7.4	3.9	-6.9	101.8	-11.2	104.1	-15.4	106.3	-20.8	109.1	(4)
(5)			WB	-1.8	75.7	7.4	2.3	-7.1	77.3	-11.5	78.7	-15.6	80.0	-20.9	81.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	53.5	28.9	34.4	44.3	54.1	63.5	70.8	74.9	74.8	65.7	54.0	43.3	32.3		
	DBStd	17.60	9.47	10.08	7.94	6.35	5.96	5.76	5.01	5.26	6.43	7.54	7.80	8.50		
	HDD50	2156	654	438	208	31	1	0	0	0	0	47	228	549		
	HDD65	5149	1119	856	643	329	99	15	1	3	69	348	653	1014		
	CDD50	3439	0	2	31	155	420	625	771	769	470	170	26	0		
	CDD65	957	0	0	0	3	54	190	308	306	90	6	0	0		
	CDH74	10190	0	0	1	60	576	1959	3312	3293	899	89	1	0		
	CDH80	4239	0	0	0	8	120	759	1518	1536	285	13	0	0		
(14) Wind	WSAvg	5.6	5.4	6.3	6.9	6.5	5.6	4.9	4.8	4.7	5.5	5.4	5.6	5.5		
(15) Precipitation	PrecAvg	21.1	1.3	1.0	1.3	1.7	2.3	2.6	2.4	1.9	2.0	1.8	1.3	1.5		
	PrecMax	37.5	3.3	2.3	3.3	5.4	5.1	5.4	7.5	8.9	6.3	4.6	3.7	6.0		
	PrecMin	10.9	0.1	0.1	0.0	0.1	0.4	0.9	0.7	0.2	0.0	0.0	0.0	0.0		
	PrecStd	5.7	0.7	0.6	0.9	1.0	1.1	1.1	1.8	1.8	1.5	1.1	0.9	1.2		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.6	62.8	71.0	80.7	87.1	95.8	100.4	98.9	91.8	81.7	69.5	54.8		
		MCWB	46.0	51.7	54.3	62.6	65.9	70.4	67.8	69.3	66.9	63.4	58.5	49.6		
	2%	DB	47.7	57.1	66.8	74.4	83.2	91.4	94.8	94.7	86.9	76.0	62.9	49.7		
		MCWB	44.1	48.5	52.9	59.3	64.6	69.7	69.4	69.1	65.0	60.9	55.6	46.2		
	5%	DB	43.5	51.9	62.5	70.1	80.3	87.5	91.4	91.6	82.9	71.0	58.2	45.5		
		MCWB	41.4	46.4	50.5	57.0	64.0	68.7	68.9	68.6	63.8	59.0	53.0	43.4		
	10%	DB	39.9	47.2	58.2	66.7	76.9	84.4	88.3	88.5	79.2	66.8	54.3	42.5		
		MCWB	38.4	43.4	48.6	55.2	62.6	67.5	68.2	67.9	62.7	57.5	50.9	40.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	47.8	52.9	56.6	64.1	70.0	74.9	74.8	75.4	69.3	65.5	59.2	50.1		
		MCDB	51.8	59.6	67.3	77.5	81.6	88.0	87.9	88.4	83.3	76.9	66.5	54.1		
	2%	WB	44.2	49.4	53.8	61.0	67.3	72.7	72.9	73.4	67.2	62.7	56.4	46.5		
		MCDB	47.0	55.7	64.7	72.3	78.9	85.9	85.8	85.7	80.3	71.9	62.1	49.3		
	5%	WB	41.6	46.6	51.6	58.6	65.6	70.7	71.6	71.5	65.7	60.6	53.9	43.9		
		MCDB	43.5	50.8	60.9	67.8	76.6	82.9	84.4	83.6	77.8	68.5	57.1	45.6		
	10%	WB	38.4	43.6	49.3	56.5	63.8	69.0	70.3	69.9	64.3	58.5	51.5	41.0		
		MCDB	39.8	47.0	57.0	64.3	74.1	80.6	82.3	82.6	75.7	65.5	53.9	42.3		
(35) Mean Daily Temperature Range	5% DB	MDBR	11.2	14.1	18.0	19.6	21.0	21.8	22.6	22.9	21.0	18.2	13.1	11.0		
		MCDBR	16.1	22.9	26.7	26.1	26.2	26.5	27.5	28.0	27.5	26.2	21.6	15.9		
		MCWBR	12.0	14.7	14.5	13.1	10.9	9.2	8.1	8.0	9.7	12.8	13.7	12.3		
	5% WB	MCDBR	15.4	21.2	24.3	23.1	23.5	23.9	23.6	22.9	23.2	22.8	18.5	15.4		
		MCWBR	11.7	14.4	13.7	12.1	10.9	9.6	8.2	8.1	9.0	11.9	12.1	12.2		
(40) Clear-Sky Solar Irradiance	taub		0.344	0.375	0.411	0.464	0.439	0.446	0.457	0.473	0.436	0.400	0.372	0.348		
	taud		2.284	2.212	2.167	2.036	2.183	2.200	2.175	2.126	2.193	2.280	2.307	2.303		
	Ebn at Noon		240	252	259	254	265	263	258	249	248	241	227	225		
	Edh at Noon		27	35	42	51	45	45	46	46	40	32	27	24		
(44) All-Sky Solar Radiation	RadAvg		456	720	1100	1507	1859	2041	2062	1829	1328	862	483	372		
	RadStd		68	104	115	150	145	138	132	115	104	106	65	54		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (66 neighbors)	+0.88	N/A	N/A	N/A	N/A	N/A	N/A	-247	+115	N/A

Nomenclature: See separate page